

2016 Consumer Confidence Report

Water System Name: VENTURA RIVER WATER DISTRICT Report Date: June 2017

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2016.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, this Sources Well 01 and Well 02 are Groundwater. This Assessment was done using the Default Groundwater System Method. Information regarding the type of water source of Well 03 and Well 04 is not available, as this water system does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

Your water comes from 4 source(s): Well 01 (1989), Well 02, Well 03 - Active and Well 04 (2007)
and from 2 treated location(s): Baldwin Tank #2 and Casitas TP Treated

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (805) 646-3403 and ask for Bert Rapp.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ppb)	22 (2016)	3.1	1	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (ppm)	22 (2016)	0.54	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (ppm)	(2011 - 2014)	44	38 - 48	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2012 - 2014)	432	409 - 458	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (ppm)	(2011 - 2014)	0.3	ND - 0.5	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Nitrate as N (ppm)	(2013 - 2016)	6.6	1.2 - 11.1	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (ppm)	(2011 - 2014)	3.4	0.8 - 6.5	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2010 - 2013)	1.013	ND - 2.51	15	(0)	Erosion of natural deposits.

Table 4 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Nitrate as N (ppm)	(2016)	5	n/a	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (ppm)	(2011 - 2014)	39	16 - 52	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2011 - 2014)	2	ND - 6	15	n/a	Naturally-occurring organic materials
Iron (ppb)	(2012 - 2014)	150	100 - 260	300	n/a	Leaching from natural deposits; Industrial wastes
Specific Conductance (umhos/cm)	(2011 - 2014)	904	791 - 1020	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (ppm)	(2011 - 2014)	202	180 - 241	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	(2012 - 2014)	630	610 - 660	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2011 - 2014)	0.5	ND - 2.1	5	n/a	Soil runoff

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (ppm)	(2011 - 2014)	0.5	0.5 - 0.6	1	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.

Table 7 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2012 - 2014)	122	116 - 129	n/a	n/a
Magnesium (mg/L)	(2012 - 2014)	31	29 - 33	n/a	n/a
pH (units)	(2011 - 2014)	7.7	7.2 - 8.0	n/a	n/a
Alkalinity (mg/L)	(2011 - 2014)	203	180 - 230	n/a	n/a
Aggressiveness Index	(2011 - 2014)	12.4	11.9 - 12.8	n/a	n/a
Langelier Index	(2011 - 2014)	0.52	-0.02 - 0.9	n/a	n/a

Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ppb)	(2016)	40.275	5.9 - 53.5	80	n/a	No	By-product of drinking water disinfection
Chlorine (ppm)	(2016)	3.35	.8 - 3.5	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ppb)	(2016)	27.25	ND - 37	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Ventura River Water District* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Lead: Infants and children who drink water containing lead in excess of the action level may experience delays in their physical or mental development. Children may show slight deficits in attention span and learning abilities. Adults who drink this water over many years may develop kidney problems or high blood pressure.

About our Nitrate as N: Infants below the age of six months who drink water containing nitrate in excess of the MCL may quickly become seriously ill and, if untreated, may die because high nitrate levels can interfere with the capacity of the infant's blood to carry oxygen. Symptoms include shortness of breath and blueness of the skin. High nitrate levels may also affect the oxygen-carrying ability of the blood of Pregnant women.

Systems with nitrate (as nitrogen) above 5 ppm (50% of the MCL), but below 10 ppm (the MCL): Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

2016 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

VRWD has four active groundwater wells as its groundwater sources. The active wells are Wells 1, 2, 3 and 4. There are no sewer lines or sewage disposal facilities located within 50 and 100 feet of well sites, respectively. The four well sites are fenced for security. The wells are located about 700 feet from an active stream (when water is flowing). VRWD conducted the drinking water source assessment of its active wells. Wells 1 and 2's assessments were completed back in August 2001; Well 4's assessment was completed in March 2007. The following table lists the top possible contaminating activities for the two wells. Currently VRWD is only able to pump from one of the four active wells, Well 1. VRWD is constructing a new well, Well 7. The well has been drilled and the permit amendment application was submitted on December 21, 2015. VRWD expects to turn the well on for service in late 2016. Well 7, when activated, is going to replace Wells 2 and 3, which will be abandoned.

- Well 01 (1989) - Moderate physical barrier effectiveness.
Possible Contaminating Activities (top ranked):
Sewer collection systems; animal grazing; low density septic systems, agricultural drainage; agricultural wells; NPDES/WDR permitted discharges; historic waste dumps/landfills; storm drain discharge; storm water detention facility, roads and freeways; surface water
- Well 02 - Low physical barrier effectiveness.
Possible Contaminating Activities (top ranked):
Sewer collection systems; utility stations; green waste transfer station; animal grazing; high and low density septic systems, agricultural drainage; agricultural wells; irrigated crops; NPDES/WDR permitted discharges; historic gas stations; historic waste dumps/landfills; abandoned wells; storm drain discharge; storm water detention facility; roads and freeways; surface water
- Well 03 - Active - --- physical barrier effectiveness.
Possible Contaminating Activities (top ranked):
Septic systems
- Well 04 (2007) - Moderate physical barrier effectiveness.
Possible Contaminating Activities (top ranked):
Sewer collection systems; green waste processing; high and low density septic systems; animal grazing; agricultural drainage; agricultural wells; fertilizer, pesticide/ herbicide application; NPDES/WDR permitted discharges; historic gas stations and waste dumps/landfills; underground storage tanks [confirmed]; above ground storage tanks; storm drain discharge; storm water detention facility; surface water

Discussion of Vulnerability

Well 1

The well was constructed in 1989 with a depth of 242 feet. An 8-inch sewer line is located about 60 feet west/northwest of the well and a single family residence's septic system is located about 120 feet east of the well. The well site is within the Ventura River flood zone. The well is located over 150 feet from the river and therefore not subject to the SWTR requirements. The well is housed in a concrete block building. It has a 55 feet deep annular seal and a concrete surface seal. The well is equipped with a 16-inch steel casing and is packed with gravel. The highest perforations are 92 feet below the ground level. There are no clay layers located above the highest perforations. The well has a deep water turbine pump which is powered by an electrical motor. The well's air release valve is screened. Well 1 is the primary well and the only one pumping currently.

Well 2

The well was constructed in 1958. It was re-constructed in 1996 with a depth of 230 feet. The well is housed in a concrete block building. The well site is located in Ventura River flood zone. However, it is located over 150 feet from the river and therefore not subject to the SWTR requirements. The well is equipped with a 16-inch steel casing and packed with gravel. The well is sealed at the surface and has an annular seal depth of 50 feet. The depth of the highest perforations is 65 feet. The well has no confining clay layers above the highest perforations. The well's air release

valve is screened. The well has been offline since 2014. VRWD shall sample the well for nitrate and bacteriological activities before putting it back into service. VRWD shall also complete the Title 22 chemical testing of the well water prior to providing it to customers.

Well 3

The well was constructed in 1969 with a depth of 220 feet. It is housed in a metal building in a fenced site behind an office yard. The well is equipped with a 16- inch steel casing and packed with gravel. It is surface sealed and has an annular depth of 50 feet. The perforations begin at 70 feet below surface. The well' s geological formation is a mix of rock and clay from the ground surface down to the highest perforations. VRWD screened the well' s air release valve during the Sanitary Survey. The well will be shut down for the rest of this year (last used in July).

Well 4

The well was constructed in 2007 with a depth of 250 feet. It is located in the Ventura River flood zone, but the flow in the river is over 150 feet away and therefore the well is not subjected to the SWTR requirements. An 8- inch sanitary sewer line runs about 125 feet from the well. A 16- inch 304 Stainless Steel casing was installed for the well. A cement grout annular seal was constructed from the surface to 50 feet below the ground surface. The well has a concrete surface seal. The well is housed in a concrete block building. The highest perforation is 73 feet deep and extends down to the 120 feet. The well' s air release valve is screened. The well has been offline since 2013. VRWD shall sample the well for nitrate and bacteriological activities before putting it back into service. VRWD shall also complete the Title 22 chemical testing of the well water prior to providing it to customers.

Acquiring Information

A copy of the complete assessment may be viewed at:
SWRCB Division of Drinking Water District Office
1180 Eugenia Place
Suite 200
Carpinteria, CA 930135

You may request a summary of the assessment be sent to you by contacting:
Jeff Densmore
District Engineer
(805) 566-1326
jeff.densmore@cdph.ca.gov

A copy of the report can also be downloaded at:
<http://venturariverwd.com/news-and-events/>

Ventura River Water District

Analytical Results By FGL - 2016

LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ppb	0	15	0.2			3.1	22
11078 Rodeo Dr.	SP 1607324-17	ppb				2016-06-28	ND		
11551 N. Oakcrest Ave.	SP 1607324-2	ppb				2016-06-28	ND		
1210 Woodland Ave.	SP 1607324-12	ppb				2016-06-28	ND		
1211 Avila Dr.	SP 1607324-25	ppb				2016-06-28	ND		
172 Burnham Rd.	SP 1607324-20	ppb				2016-06-28	ND		
1991 Country Pl.	SP 1607324-8	ppb				2016-06-28	ND		
209 Carillo Rd.	SP 1607324-19	ppb				2016-06-28	ND		
2131 Burnham Rd.	SP 1607324-23	ppb				2016-06-28	ND		
2187 Woodland Ave.	SP 1607324-1	ppb				2016-06-28	ND		
2235 Los Encinos Rd.	SP 1607324-11	ppb				2016-06-28	ND		
2256 Los Encinos Rd.	SP 1607324-10	ppb				2016-06-28	ND		
365 Burnham Rd.	SP 1607324-9	ppb				2016-06-28	ND		
400 Burnham Rd.	SP 1607324-21	ppb				2016-06-28	ND		
45 Almond Ave.	SP 1611582-1	ppb				2016-09-29	ND		
45 Almond Ave.	SP 1607324-13	ppb				2016-06-28	24.7		
478 Burnham Rd.	SP 1607324-22	ppb				2016-06-28	ND		
56 Grapevine Rd.	SP 1607324-14	ppb				2016-06-28	ND		
573 E. Katherine Ave.	SP 1607324-15	ppb				2016-06-28	ND		
617 Country Dr.	SP 1607324-3	ppb				2016-06-28	ND		
640 Holly	SP 1607324-5	ppb				2016-06-28	ND		
80 Pathelen Ave.	SP 1607324-16	ppb				2016-06-28	5.6		
98 Wormwood St.	SP 1607324-7	ppb				2016-06-28	ND		
Copper		ppm		1.3	.3			0.54	22
11078 Rodeo Dr.	SP 1607324-17	ppm				2016-06-28	0.17		
11551 N. Oakcrest Ave.	SP 1607324-2	ppm				2016-06-28	0.06		
1210 Woodland Ave.	SP 1607324-12	ppm				2016-06-28	0.08		
1211 Avila Dr.	SP 1607324-25	ppm				2016-06-28	0.09		
172 Burnham Rd.	SP 1607324-20	ppm				2016-06-28	0.41		
1991 Country Pl.	SP 1607324-8	ppm				2016-06-28	0.14		
209 Carillo Rd.	SP 1607324-19	ppm				2016-06-28	0.17		
2131 Burnham Rd.	SP 1607324-23	ppm				2016-06-28	0.57		
2187 Woodland Ave.	SP 1607324-1	ppm				2016-06-28	0.10		
2235 Los Encinos Rd.	SP 1607324-11	ppm				2016-06-28	0.35		
2256 Los Encinos Rd.	SP 1607324-10	ppm				2016-06-28	0.54		
365 Burnham Rd.	SP 1607324-9	ppm				2016-06-28	0.13		
400 Burnham Rd.	SP 1607324-21	ppm				2016-06-28	0.09		
45 Almond Ave.	SP 1611582-1	ppm				2016-09-29	0.12		
45 Almond Ave.	SP 1607324-13	ppm				2016-06-28	0.13		
478 Burnham Rd.	SP 1607324-22	ppm				2016-06-28	0.73		
56 Grapevine Rd.	SP 1607324-14	ppm				2016-06-28	0.86		
573 E. Katherine Ave.	SP 1607324-15	ppm				2016-06-28	0.32		
617 Country Dr.	SP 1607324-3	ppm				2016-06-28	0.14		
640 Holly	SP 1607324-5	ppm				2016-06-28	0.13		
80 Pathelen Ave.	SP 1607324-16	ppm				2016-06-28	0.10		
98 Wormwood St.	SP 1607324-7	ppm				2016-06-28	0.13		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		ppm		none	none			44	38 - 48
Well 01 (1989)	SP 1401882-1	ppm				2014-02-18	48		
Well 02	SP 1405147-1	ppm				2014-05-06	45		

Well 03 - Active	SP 1403705-1	ppm				2014-04-01	46		
Well 04 (2007)	SP 1106334-1	ppm				2011-06-27	38		
Hardness		ppm	none	none				432	409 - 458
Well 01 (1989)	SP 1401882-1	ppm				2014-02-18	458		
Well 02	SP 1405147-1	ppm				2014-05-06	409		
Well 03 - Active	SP 1403705-1	ppm				2014-04-01	429		
Well 04 (2007)	SP 1210355-4	ppm				2012-10-09	432		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		ppm		2	1			0.3	ND - 0.5
Well 01 (1989)	SP 1401882-1	ppm				2014-02-18	0.4		
Well 02	SP 1405147-1	ppm				2014-05-06	ND		
Well 03 - Active	SP 1403705-1	ppm				2014-04-01	0.3		
Well 04 (2007)	SP 1106334-1	ppm				2011-06-27	0.5		
Nitrate as N		ppm		10	10			6.6	1.15 - 11.1
Well 01 (1989)	SP 1615343-1	ppm				2016-12-27	10.2		
Well 01 (1989)	SP 1614852-1	ppm				2016-12-13	9.4		
Well 01 (1989)	SP 1614549-1	ppm				2016-12-06	8.6		
Well 01 (1989)	SP 1614225-1	ppm				2016-11-29	8.7		
Well 01 (1989)	SP 1614050-1	ppm				2016-11-22	8.5		
Well 01 (1989)	SP 1613708-1	ppm				2016-11-15	8.1		
Well 01 (1989)	SP 1613435-1	ppm				2016-11-08	8.4		
Well 01 (1989)	SP 1613119-1	ppm				2016-11-01	8.2		
Well 01 (1989)	SP 1612832-1	ppm				2016-10-25	7.3		
Well 01 (1989)	SP 1612515-1	ppm				2016-10-18	7.7		
Well 01 (1989)	SP 1612153-3	ppm				2016-10-11	8.2		
Well 01 (1989)	SP 1611784-1	ppm				2016-10-04	7.7		
Well 01 (1989)	SP 1611474-3	ppm				2016-09-27	7.3		
Well 01 (1989)	SP 1610369-1	ppm				2016-09-06	6.9		
Well 01 (1989)	SP 1608780-1	ppm				2016-08-02	5.2		
Well 01 (1989)	SP 1607831-1	ppm				2016-07-12	3.8		
Well 01 (1989)	SP 1606464-1	ppm				2016-06-07	2.4		
Well 01 (1989)	SP 1604898-1	ppm				2016-05-03	2.6		
Well 01 (1989)	SP 1603746-1	ppm				2016-04-05	3.9		
Well 01 (1989)	SP 1602311-1	ppm				2016-03-01	6.0		
Well 01 (1989)	SP 1602063-1	ppm				2016-02-23	5.8		
Well 01 (1989)	SP 1601518-1	ppm				2016-02-09	6.8		
Well 01 (1989)	SP 1601188-1	ppm				2016-02-02	7.4		
Well 01 (1989)	SP 1600932-3	ppm				2016-01-26	8.1		
Well 02	SP 1406653-1	ppm				2014-06-10	2.60		
Well 02	SP 1405147-1	ppm				2014-05-06	1.15		
Well 03 - Active	SP 1607831-2	ppm				2016-07-12	11.1		
Well 03 - Active	SP 1607323-1	ppm				2016-06-28	10.1		
Well 04 (2007)	SP 1309359-4	ppm				2013-09-10	3.80		
Well 04 (2007)	SP 1305548-1	ppm				2013-06-04	1.20		
Nitrate + Nitrite as N		ppm		10	10			3.4	0.8 - 6.5
Well 01 (1989)	SP 1401882-1	ppm				2014-02-18	6.5		
Well 02	SP 1405147-1	ppm				2014-05-06	1.2		
Well 03 - Active	SP 1403705-1	ppm				2014-04-01	5.2		
Well 04 (2007)	SP 1106334-1	ppm				2011-06-27	0.8		
Gross Alpha		pCi/L		15	(0)			1.013	ND - 2.51
Well 01 (1989)	SP 1305549-1	pCi/L				2013-06-04	1.62		
Well 01 (1989)	SP 1302830-1	pCi/L				2013-03-19	1.29		
Well 02	SP 1105600-1	pCi/L				2011-06-07	ND		
Well 02	SP 1102665-1	pCi/L				2011-03-15	ND		
Well 03 - Active	SP 1305552-1	pCi/L				2013-06-04	2.51		
Well 03 - Active	SP 1302833-1	pCi/L				2013-03-19	1.27		
Well 04 (2007)	SP 1005996-1	pCi/L				2010-06-22	ND		

Calcium		mg/L			n/a			122	116 - 129
Well 01 (1989)	SP 1401882-1	mg/L				2014-02-18	129		
Well 02	SP 1405147-1	mg/L				2014-05-06	116		
Well 03 - Active	SP 1403705-1	mg/L				2014-04-01	121		
Well 04 (2007)	SP 1210355-4	mg/L				2012-10-09	122		
Magnesium		mg/L			n/a			31	29 - 33
Well 01 (1989)	SP 1401882-1	mg/L				2014-02-18	33		
Well 02	SP 1405147-1	mg/L				2014-05-06	29		
Well 03 - Active	SP 1403705-1	mg/L				2014-04-01	31		
Well 04 (2007)	SP 1210355-4	mg/L				2012-10-09	31		
pH		units			n/a			7.7	7.2 - 8.0
Well 01 (1989)	SP 1401882-1	units				2014-02-18	7.7		
Well 02	SP 1405147-1	units				2014-05-06	7.7		
Well 03 - Active	SP 1403705-1	units				2014-04-01	8.0		
Well 04 (2007)	SP 1106334-1	units				2011-06-27	7.2		
Alkalinity		mg/L			n/a			203	180 - 230
Well 01 (1989)	SP 1401882-1	mg/L				2014-02-18	230		
Well 02	SP 1405147-1	mg/L				2014-05-06	180		
Well 03 - Active	SP 1403705-1	mg/L				2014-04-01	220		
Well 04 (2007)	SP 1106334-1	mg/L				2011-06-27	180		
Aggressiveness Index					n/a			12.4	11.9 - 12.8
Well 01 (1989)	SP 1401882-1					2014-02-18	12.6		
Well 02	SP 1405147-1					2014-05-06	12.4		
Well 03 - Active	SP 1403705-1					2014-04-01	12.8		
Well 04 (2007)	SP 1106334-1					2011-06-27	11.9		
Langelier Index					n/a			0.52	-0.02 - 0.9
Well 01 (1989)	SP 1401882-1					2014-02-18	0.7		
Well 02	SP 1405147-1					2014-05-06	0.5		
Well 03 - Active	SP 1403705-1					2014-04-01	0.9		
Well 04 (2007)	SP 1106334-1					2011-06-27	-0.02		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Trihalomethanes (TTHMs)		ppb		80	n/a			40.275	5.9 - 53.5
175 Rio Via - Stage 2 DBP	SP 1614546-1	ppb				2016-12-06	39.4		
175 Rio Via - Stage 2 DBP	SP 1610747-1	ppb				2016-09-13	35.9		
175 Rio Via - Stage 2 DBP	SP 1606787-1	ppb				2016-06-14	32.3		
175 Rio Via - Stage 2 DBP	SP 1602589-1	ppb				2016-03-08	53.5		
Average 175 Rio Via - Stage 2 DBP								40.28	
202 Valle Rio - Stage 2 DBP	SP 1614546-2	ppb				2016-12-06	5.9		
202 Valle Rio - Stage 2 DBP	SP 1610747-2	ppb				2016-09-13	7.8		
202 Valle Rio - Stage 2 DBP	SP 1606787-2	ppb				2016-06-14	32.7		
202 Valle Rio - Stage 2 DBP	SP 1602589-2	ppb				2016-03-08	6.9		
Average 202 Valle Rio - Stage 2 DBP								13.33	
Chlorine		ppm		4.0	4.0			3.35	.8 - 3.5
175 Rio Via	SP 1614051-1	ppm				2016-11-22	3.0		
175 Rio Via	SP 1611132-1	ppm				2016-09-20	3.5		
175 Rio Via	SP 1609071-1	ppm				2016-08-09	3.0		
175 Rio Via	SP 1607564-1	ppm				2016-07-05	3.0		
175 Rio Via	SP 1605941-1	ppm				2016-05-24	3.5		
175 Rio Via	SP 1604334-1	ppm				2016-04-19	3.5		
175 Rio Via	SP 1602590-1	ppm				2016-03-08	3.0		
175 Rio Via	SP 1601189-1	ppm				2016-02-02	3.2		
Average 175 Rio Via								3.21	
202 Valle Rio Ave. - Book 10A	SP 1605506-2	ppm				2016-06-21	3.0		
Average 202 Valle Rio Ave. - Book 10A								3	
2096 Sumac Dr. - Book 9B	SP 1608778-1	ppm				2016-08-02	3.0		

Ventura River Water District

CCR Login Linkage - 2016

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
SS - 1A	SP 1600644-1	2016-01-19	Coliform	1042 Moreno Dr. - Book 1A	Week 3 System Monitoring
	SP 1602064-1	2016-02-23	Coliform	1042 Moreno Dr. - Book 1A	Week 4 System Monitoring
	SP 1603747-1	2016-04-05	Coliform	1042 Moreno Dr. - Book 1A	Week 1 System Monitoring
	SP 1605208-1	2016-05-10	Coliform	1042 Moreno Dr. - Book 1A	Week 2 System Monitoring
	SP 1605506-1	2016-06-21	Coliform	1042 Moreno Dr. - Book 1A	Week 3 System Monitoring
	SP 1608485-1	2016-07-26	Coliform	1042 Moreno Dr. - Book 1A	Week 4 System Monitoring
	SP 1610372-1	2016-09-06	Coliform	1042 Moreno Dr. - Book 1A	Week 1 System Monitoring
	SP 1612153-1	2016-10-11	Coliform	1042 Moreno Dr. - Book 1A	Week 2 System Monitoring
	SP 1613433-1	2016-11-08	Coliform	1042 Moreno Dr. - Book 1A	Week 2 System Monitoring
	SP 1615236-1	2016-12-20	Coliform	1042 Moreno Dr. - Book 1A	Week 3 System Monitoring
11078 Rodeo Dr.	SP 1607324-17	2016-06-28	Metals, Total	11078 Rodeo Dr.	Lead & Copper Monitoring
11551 N. Oakcre	SP 1607324-2	2016-06-28	Metals, Total	11551 N. Oakcrest Ave.	Lead & Copper Monitoring
1210 Woodland A	SP 1607324-12	2016-06-28	Metals, Total	1210 Woodland Ave.	Lead & Copper Monitoring
1211 Avila Dr.	SP 1607324-25	2016-06-28	Metals, Total	1211 Avila Dr.	Lead & Copper Monitoring
172 Burnham Rd.	SP 1607324-20	2016-06-28	Metals, Total	172 Burnham Rd.	Lead & Copper Monitoring
SS - Wk4	SP 1601189-1	2016-02-02	Coliform	175 Rio Via	Week 1 System Monitoring
	SP 1601189-1	2016-02-02	Field Test	175 Rio Via	Week 1 System Monitoring
	SP 1602590-1	2016-03-08	Field Test	175 Rio Via	Week 2 System Monitoring
	SP 1602590-1	2016-03-08	Coliform	175 Rio Via	Week 2 System Monitoring
	SP 1604334-1	2016-04-19	Coliform	175 Rio Via	Week 3 System Monitoring
	SP 1604334-1	2016-04-19	Field Test	175 Rio Via	Week 3 System Monitoring
	SP 1605941-1	2016-05-24	Coliform	175 Rio Via	Week 4 System Monitoring
	SP 1605941-1	2016-05-24	Field Test	175 Rio Via	Week 4 System Monitoring
	SP 1607564-1	2016-07-05	Coliform	175 Rio Via	Week 1 System Monitoring
	SP 1607564-1	2016-07-05	Field Test	175 Rio Via	Week 1 System Monitoring
	SP 1609071-1	2016-08-09	Coliform	175 Rio Via	Week 2 System Monitoring
	SP 1609071-1	2016-08-09	Field Test	175 Rio Via	Week 2 System Monitoring
	SP 1611132-1	2016-09-20	Field Test	175 Rio Via	Week 3 System Monitoring
	SP 1611132-1	2016-09-20	Coliform	175 Rio Via	Week 3 System Monitoring
	SP 1614051-1	2016-11-22	Field Test	175 Rio Via	Week 4 System Monitoring
	SP 1614051-1	2016-11-22	Coliform	175 Rio Via	Week 4 System Monitoring
DBP 175RioVia	SP 1602589-1	2016-03-08	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1602589-1	2016-03-08	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1606787-1	2016-06-14	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1606787-1	2016-06-14	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1610747-1	2016-09-13	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1610747-1	2016-09-13	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1614546-1	2016-12-06	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1614546-1	2016-12-06	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
1991 Country Pl	SP 1607324-8	2016-06-28	Metals, Total	1991 Country Pl.	Lead & Copper Monitoring
DBP 202ValleRio	SP 1602589-2	2016-03-08	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1602589-2	2016-03-08	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1606787-2	2016-06-14	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1606787-2	2016-06-14	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1610747-2	2016-09-13	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1610747-2	2016-09-13	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1614546-2	2016-12-06	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1614546-2	2016-12-06	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
SS - 10A	SP 1600644-2	2016-01-19	Coliform	202 Valle Rio Ave. - Book 10A	Group 3 System Monitoring
202 Valle Rio A	SP 1602064-2	2016-02-23	Coliform	202 Valle Rio Ave. - Book 10A	Week 4 System Monitoring
SS - 10A	SP 1603747-2	2016-04-05	Coliform	202 Valle Rio Ave. - Book 10A	Week 1 System Monitoring
	SP 1605208-2	2016-05-10	Coliform	202 Valle Rio Ave. - Book 10A	Week 2 System Monitoring
	SP 1605506-2	2016-06-21	Coliform	202 Valle Rio Ave. - Book 10A	Group 3 System Monitoring
	SP 1605506-2	2016-06-21	Field Test	202 Valle Rio Ave. - Book 10A	Group 3 System Monitoring
	SP 1608485-2	2016-07-26	Coliform	202 Valle Rio Ave. - Book 10A	Week 4 System Monitoring

	SP 1610372-2	2016-09-06	Coliform	202 Valle Rio Ave. - Book 10A	Week 1 System Monitoring
	SP 1612153-2	2016-10-11	Coliform	202 Valle Rio Ave. - Book 10A	Week 2 System Monitoring
	SP 1613433-2	2016-11-08	Coliform	202 Valle Rio Ave. - Book 10A	Week 2 System Monitoring
	SP 1615236-2	2016-12-20	Coliform	202 Valle Rio Ave. - Book 10A	Week 3 System Monitoring
209 Carillo Rd.	SP 1607324-19	2016-06-28	Metals, Total	209 Carillo Rd.	Lead & Copper Monitoring
SS - 9B	SP 1600931-1	2016-01-26	Coliform	2096 Sumac Dr. - Book 9B	Week 4 System Monitoring
	SP 1602310-1	2016-03-01	Coliform	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
	SP 1604043-1	2016-04-12	Coliform	2096 Sumac Dr. - Book 9B	Week 2 System Monitoring
	SP 1605571-1	2016-05-17	Coliform	2096 Sumac Dr. - Book 9B	Week 3 System Monitoring
	SP 1607326-1	2016-06-28	Coliform	2096 Sumac Dr. - Book 9B	Week 4 System Monitoring
	SP 1608778-1	2016-08-02	Field Test	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
	SP 1608778-1	2016-08-02	Coliform	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
	SP 1610748-1	2016-09-13	Coliform	2096 Sumac Dr. - Book 9B	Week 2 System Monitoring
	SP 1612512-2	2016-10-18	Coliform	2096 Sumac Dr. - Book 9B	Week 3 System Monitoring
	SP 1613709-1	2016-11-15	Coliform	2096 Sumac Dr. - Book 9B	Week 3 System Monitoring
	SP 1615476-1	2016-12-27	Coliform	2096 Sumac Dr. - Book 9B	Week 4 System Monitoring
2131 Burnham Rd	SP 1607324-23	2016-06-28	Metals, Total	2131 Burnham Rd.	Lead & Copper Monitoring
2187 Woodland A	SP 1607324-1	2016-06-28	Metals, Total	2187 Woodland Ave.	Lead & Copper Monitoring
2235 Los Encino	SP 1607324-11	2016-06-28	Metals, Total	2235 Los Encinos Rd.	Lead & Copper Monitoring
2256 Los Encino	SP 1607324-10	2016-06-28	Metals, Total	2256 Los Encinos Rd.	Lead & Copper Monitoring
SS - 9A	SP 1601189-2	2016-02-02	Coliform	265 E. Villanova Rd. Book 9A	Week 1 System Monitoring
	SP 1602590-2	2016-03-08	Coliform	265 E. Villanova Rd. Book 9A	Week 2 System Monitoring
	SP 1604334-2	2016-04-19	Coliform	265 E. Villanova Rd. Book 9A	Group 3 System Monitoring
	SP 1605941-2	2016-05-24	Coliform	265 E. Villanova Rd. Book 9A	Week 4 System Monitoring
	SP 1607564-2	2016-07-05	Coliform	265 E. Villanova Rd. Book 9A	Week 1 System Monitoring
	SP 1609071-2	2016-08-09	Coliform	265 E. Villanova Rd. Book 9A	Week 2 System Monitoring
	SP 1611132-2	2016-09-20	Coliform	265 E. Villanova Rd. Book 9A	Group 3 System Monitoring
	SP 1614051-2	2016-11-22	Coliform	265 E. Villanova Rd. Book 9A	Week 4 System Monitoring
SS - 8	SP 1600357-2	2016-01-12	Coliform	290 Alto Dr. - Book 8	Week 2 System Monitoring
	SP 1601777-2	2016-02-16	Coliform	290 Alto Dr. - Book 8	Group 3 System Monitoring
	SP 1601777-2	2016-02-16	Field Test	290 Alto Dr. - Book 8	Group 3 System Monitoring
	SP 1603209-2	2016-03-22	Coliform	290 Alto Dr. - Book 8	Week 4 System Monitoring
	SP 1604903-2	2016-05-03	Coliform	290 Alto Dr. - Book 8	Week 1 System Monitoring
	SP 1606796-2	2016-06-14	Coliform	290 Alto Dr. - Book 8	Week 2 System Monitoring
	SP 1608195-2	2016-07-19	Coliform	290 Alto Dr. - Book 8	Group 3 System Monitoring
	SP 1609793-2	2016-08-23	Coliform	290 Alto Dr. - Book 8	Week 4 System Monitoring
	SP 1611786-2	2016-10-04	Coliform	290 Alto Dr. - Book 8	Week 1 System Monitoring
	SP 1613120-2	2016-11-01	Coliform	290 Alto Dr. - Book 8	Week 1 System Monitoring
	SP 1614853-2	2016-12-13	Coliform	290 Alto Dr. - Book 8	Week 2 System Monitoring
365 Burnham Rd.	SP 1607324-9	2016-06-28	Metals, Total	365 Burnham Rd.	Lead & Copper Monitoring
400 Burnham Rd.	SP 1607324-21	2016-06-28	Metals, Total	400 Burnham Rd.	Lead & Copper Monitoring
45 Almond Ave.	SP 1607324-13	2016-06-28	Metals, Total	45 Almond Ave.	Lead & Copper Monitoring
45 Almond Ave	SP 1611582-1	2016-09-29	Metals, Total	45 Almond Ave.	CU & PB-Resample
478 Burnham Rd.	SP 1607324-22	2016-06-28	Metals, Total	478 Burnham Rd.	Lead & Copper Monitoring
56 Grapevine Rd	SP 1607324-14	2016-06-28	Metals, Total	56 Grapevine Rd.	Lead & Copper Monitoring
573 E. Katherin	SP 1607324-15	2016-06-28	Metals, Total	573 E. Katherine Ave.	Lead & Copper Monitoring
SS - 7	SP 1600931-2	2016-01-26	Coliform	595 Riverside Rd. - Book 7	Week 4 System Monitoring
	SP 1602310-2	2016-03-01	Coliform	595 Riverside Rd. - Book 7	Week 1 System Monitoring
	SP 1604043-2	2016-04-12	Coliform	595 Riverside Rd. - Book 7	Week 2 System Monitoring
	SP 1605571-2	2016-05-17	Coliform	595 Riverside Rd. - Book 7	Group 3 System Monitoring
	SP 1605571-2	2016-05-17	Field Test	595 Riverside Rd. - Book 7	Group 3 System Monitoring
	SP 1607326-2	2016-06-28	Coliform	595 Riverside Rd. - Book 7	Week 4 System Monitoring
	SP 1607326-2	2016-06-28	Field Test	595 Riverside Rd. - Book 7	Week 4 System Monitoring
	SP 1608778-2	2016-08-02	Coliform	595 Riverside Rd. - Book 7	Week 1 System Monitoring
	SP 1608778-2	2016-08-02	Field Test	595 Riverside Rd. - Book 7	Week 1 System Monitoring
	SP 1610748-2	2016-09-13	Coliform	595 Riverside Rd. - Book 7	Week 2 System Monitoring
	SP 1610748-2	2016-09-13	Field Test	595 Riverside Rd. - Book 7	Week 2 System Monitoring
	SP 1612512-1	2016-10-18	Coliform	595 Riverside Rd. - Book 7	Week 3 System Monitoring
	SP 1612512-1	2016-10-18	Field Test	595 Riverside Rd. - Book 7	Week 3 System Monitoring
	SP 1613709-2	2016-11-15	Field Test	595 Riverside Rd. - Book 7	Week 3 System Monitoring

	SP 1613709-2	2016-11-15	Coliform	595 Riverside Rd. - Book 7	Week 3 System Monitoring
	SP 1615476-2	2016-12-27	Coliform	595 Riverside Rd. - Book 7	Week 4 System Monitoring
617 Country Dr.	SP 1607324-3	2016-06-28	Metals, Total	617 Country Dr.	Lead & Copper Monitoring
640 Holly	SP 1607324-5	2016-06-28	Metals, Total	640 Holly	Lead & Copper Monitoring
72 Catalina Dr.	SP 1600133-2	2016-01-06	Coliform	72 Catalina Dr. - Book 5A	Week 1 System Monitoring
SS - 5A	SP 1601517-2	2016-02-09	Coliform	72 Catalina Dr. - Book 5A	Week 2 System Monitoring
72 Catalina Dr.	SP 1602913-2	2016-03-15	Coliform	72 Catalina Dr. - Book 5A	Group 3 System Monitoring
SS - 5A	SP 1604631-2	2016-04-26	Coliform	72 Catalina Dr. - Book 5A	Week 4 System Monitoring
	SP 1606466-2	2016-06-07	Coliform	72 Catalina Dr. - Book 5A	Week 1 System Monitoring
	SP 1607828-2	2016-07-12	Coliform	72 Catalina Dr. - Book 5A	Week 2 System Monitoring
	SP 1609436-2	2016-08-16	Coliform	72 Catalina Dr. - Book 5A	Group 3 System Monitoring
	SP 1611474-2	2016-09-27	Coliform	72 Catalina Dr. - Book 5A	Week 4 System Monitoring
	SP 1612831-2	2016-10-25	Coliform	72 Catalina Dr. - Book 5A	Week 4 System Monitoring
	SP 1614547-2	2016-12-06	Coliform	72 Catalina Dr. - Book 5A	Week 1 System Monitoring
80 Pathelen Ave	SP 1607324-16	2016-06-28	Metals, Total	80 Pathelen Ave.	Lead & Copper Monitoring
85 Almond AVE	SP 1600133-1	2016-01-06	Coliform	85 Almond Ave. - Book 6B	Week 1 System Monitoring
	SP 1601517-1	2016-02-09	Coliform	85 Almond Ave. - Book 6B	Week 2 System Monitoring
	SP 1602913-1	2016-03-15	Coliform	85 Almond Ave. - Book 6B	Week 3 System Monitoring
	SP 1604631-1	2016-04-26	Coliform	85 Almond Ave. - Book 6B	Week 4 System Monitoring
SS - 6B	SP 1606466-1	2016-06-07	Coliform	85 Almond Ave. - Book 6B	Week 1 System Monitoring
85 Almond AVE	SP 1607828-1	2016-07-12	Coliform	85 Almond Ave. - Book 6B	Week 2 System Monitoring
	SP 1609436-1	2016-08-16	Coliform	85 Almond Ave. - Book 6B	Week 3 System Monitoring
	SP 1612831-1	2016-10-25	Coliform	85 Almond Ave. - Book 6B	Week 4 System Monitoring
	SP 1614547-1	2016-12-06	Coliform	85 Almond Ave. - Book 6B	Week 1 System Monitoring
DBP 85AlmondAve	SP 1611474-1	2016-09-27	Coliform	85 Almond Avenue - Stage 2 DBP	Week 4 System Monitoring
SS - 14	SP 1600357-1	2016-01-12	Field Test	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1600357-1	2016-01-12	Coliform	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1601777-1	2016-02-16	Coliform	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1601777-1	2016-02-16	Field Test	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1603209-1	2016-03-22	Coliform	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1603209-1	2016-03-22	Field Test	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1604903-1	2016-05-03	Coliform	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1604903-1	2016-05-03	Field Test	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1606796-1	2016-06-14	Coliform	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1606796-1	2016-06-14	Field Test	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1608195-1	2016-07-19	Coliform	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1608195-1	2016-07-19	Field Test	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1609793-1	2016-08-23	Coliform	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1609793-1	2016-08-23	Field Test	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1611786-1	2016-10-04	Field Test	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1611786-1	2016-10-04	Coliform	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1613120-1	2016-11-01	Coliform	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1613120-1	2016-11-01	Field Test	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1614853-1	2016-12-13	Coliform	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1614853-1	2016-12-13	Field Test	9148 Nye Rd. - Book 14	Week 2 System Monitoring
98 Wormwood St.	SP 1607324-7	2016-06-28	Metals, Total	98 Wormwood St.	Lead & Copper Monitoring
Bald Tnk 2	SP 1607831-3	2016-07-12	Wet Chemistry	Baldwin Tank #2	Nitrate Monitoring
	SP 1611583-1	2016-09-29	Coliform	Baldwin Tank #2	Baldwin Tank #1
Well 01	SP 1302831-1	2013-03-19	Asbestos	Well 01 (1989)	Source Asbestos - Wells 1,3,4
	SP 1302830-1	2013-03-19	Radio Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1305549-1	2013-06-04	Radio Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1401882-1	2014-02-18	General Mineral	Well 01 (1989)	Well 01 - Water Quality
	SP 1401882-1	2014-02-18	Wet Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1600932-3	2016-01-26	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1601188-1	2016-02-02	Wet Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1601518-1	2016-02-09	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1602063-1	2016-02-23	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1602311-1	2016-03-01	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1603746-1	2016-04-05	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1604898-1	2016-05-03	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring

	SP 1606464-1	2016-06-07	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1607831-1	2016-07-12	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1608780-1	2016-08-02	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1610369-1	2016-09-06	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1611474-3	2016-09-27	Wet Chemistry	Well 01 (1989)	Week 4 System Monitoring
	SP 1611784-1	2016-10-04	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1612153-3	2016-10-11	Wet Chemistry	Well 01 (1989)	Week 2 System Monitoring
	SP 1612515-1	2016-10-18	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1612832-1	2016-10-25	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1613119-1	2016-11-01	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1613435-1	2016-11-08	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1613708-1	2016-11-15	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1614050-1	2016-11-22	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1614225-1	2016-11-29	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1614549-1	2016-12-06	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1614852-1	2016-12-13	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1615343-1	2016-12-27	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
Well 02	SP 1102665-1	2011-03-15	Radio Chemistry	Well 02	Well 02 Title 22 Monitoring
	SP 1105600-1	2011-06-07	Radio Chemistry	Well 02	Well 02 Title 22 Monitoring
	SP 1405147-1	2014-05-06	General Mineral	Well 02	Well 02 - Water Quality
	SP 1405147-1	2014-05-06	Wet Chemistry	Well 02	Well 02 - Water Quality
	SP 1406653-1	2014-06-10	Wet Chemistry	Well 02	Well 02 - Water Quality
Well 03	SP 1302833-1	2013-03-19	Radio Chemistry	Well 03 - Active	Well 03 - Radio Monitoring
	SP 1305552-1	2013-06-04	Radio Chemistry	Well 03 - Active	Well 03 - Radio Monitoring
	SP 1403705-1	2014-04-01	Wet Chemistry	Well 03 - Active	Well 03 - Water Quality
	SP 1403705-1	2014-04-01	General Mineral	Well 03 - Active	Well 03 - Water Quality
	SP 1607323-1	2016-06-28	Wet Chemistry	Well 03 - Active	Well 03 - Water Quality
	SP 1607831-2	2016-07-12	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
Well 04	SP 1001299-1	2010-02-09	Radio Chemistry	Well 04 (2007)	Gross Alpha/Radium Well #4
	SP 1005996-1	2010-06-22	Radio Chemistry	Well 04 (2007)	Well #4 Radioactive/Radium
	SP 1106334-1	2011-06-27	General Mineral	Well 04 (2007)	Well 04 - Water Quality
	SP 1106334-1	2011-06-27	Wet Chemistry	Well 04 (2007)	Well 04 - Water Quality
	SP 1210355-4	2012-10-09	Metals, Total	Well 04 (2007)	Low Aquifer Samples
	SP 1210355-4	2012-10-09	Wet Chemistry	Well 04 (2007)	Low Aquifer Samples
	SP 1305548-1	2013-06-04	Wet Chemistry	Well 04 (2007)	Well 04 - Water Quality
	SP 1309359-4	2013-09-10	Wet Chemistry	Well 04 (2007)	Raw Water Monitoring