

# Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Board's website at [http://www.waterboards.ca.gov/drinking\\_water/certlic/drinkingwater/CCR.shtml](http://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml))

Water System Name: **VENTURA RIVER WATER DISTRICT**

Water System Number: **5610022**

The water system above hereby certifies that its Consumer Confidence Report was distributed on \_\_\_\_\_ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By: Name \_\_\_\_\_  
Signature \_\_\_\_\_  
Title \_\_\_\_\_  
Phone Number ( ) \_\_\_\_\_ Date \_\_\_\_\_

---

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

\_\_\_\_\_ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_ "Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

\_\_\_\_\_ Posted the CCR on the internet at http:// \_\_\_\_\_

\_\_\_\_\_ Mailed the CCR to postal patrons within the service area (attach zip codes used)

\_\_\_\_\_ Advertised the availability of the CCR in news media (attach a copy of press release)

\_\_\_\_\_ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)

\_\_\_\_\_ Posted the CCR in public places (attach a list of locations)

\_\_\_\_\_ Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools

\_\_\_\_\_ Delivery to community organizations (attach a list of organizations)

\_\_\_\_\_ Other (attach a list of other methods used)

\_\_\_\_\_ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: http:// \_\_\_\_\_

\_\_\_\_\_ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

# 2017 Consumer Confidence Report

Water System Name: VENTURA RIVER WATER DISTRICT Report Date: March 2018

*We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2017.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**

**Type of water source(s) in use:** According to SWRCB records, this Sources Well 01 and Well 02 are Groundwater. This Assessment was done using the Default Groundwater System Method. Information regarding the type of water source of Well 03 and Well 04 is not available, as this water system does not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

**Your water comes from 3 source(s):** Well 01 (1989), Well 03 - Active and Well 04 (2007)  
**and from 1 treated location(s):** Baldwin Tank #2 - NO3 BLEND

**Opportunities for public participation in decisions that affect drinking water quality:** Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (805) 646-3403 and ask for Bert Rapp.

## TERMS USED IN THIS REPORT

**Maximum Contaminant Level (MCL):** The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Secondary Drinking Water Standards (SDWS):** MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**ND:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter (mg/L)

**ppb:** parts per billion or micrograms per liter (µg/L)

**pCi/L:** picocuries per liter (a measure of radiation)

**NTU:** Nephelometric Turbidity Units

**umhos/cm:** micro mhos per centimeter

**The sources of drinking water:** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the USEPA and the State Water Resource Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

**Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent.** The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

<b>Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER</b>						
<b>Lead and Copper</b> (complete if lead or copper detected in last sample set)	<b>Sample Date</b>	<b>90th percentile level detected</b>	<b>No. Sites Exceeding AL</b>	<b>AL</b>	<b>PHG</b>	<b>Typical Sources of Contaminant</b>
Lead (ppb)	22 (2016)	3.1	1	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (ppm)	22 (2016)	0.54	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

<b>Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>MCL</b>	<b>PHG (MCLG)</b>	<b>Typical Sources of Contaminant</b>
Sodium (ppm)	(2017)	43	38 - 49	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	(2017)	387	371 - 403	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

<b>Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD</b>						
<b>Chemical or Constituent</b> (and reporting units)	<b>Sample Date</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>MCL [MRDL]</b>	<b>PHG (MCLG) [MRDLG]</b>	<b>Typical Sources of Contaminant</b>
Fluoride (ppm)	(2017)	0.5	0.4 - 0.5	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Nitrate as N (ppm)	(2017)	3.7	1.6 - 9.6	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (ppm)	(2017)	1.8	1.6 - 2.3	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2010 - 2013)	1.35	ND - 2.51	15	(0)	Erosion of natural deposits.

**Table 4 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Nitrate as N (ppm)	(2017)	4.6	2.0 - 7.1	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

**Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (ppm)	(2017)	42	28 - 53	500	n/a	Runoff/leaching from natural deposits; seawater influence
Specific Conductance (umhos/cm)	(2017)	955	888 - 1000	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (ppm)	(2017)	211	177 - 225	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	(2017)	648	590 - 690	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2017)	0.9	0.5 - 1.3	5	n/a	Soil runoff

**Table 6 - DETECTION OF UNREGULATED CONTAMINANTS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (ppm)	(2017)	0.6	0.5 - 0.7	1	The babies of some pregnant women who drink water containing boron in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals.

**Table 7 - ADDITIONAL DETECTIONS**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2017)	109	106 - 112	n/a	n/a
Magnesium (mg/L)	(2017)	28	26 - 30	n/a	n/a
pH (units)	(2017)	7.6	7.2 - 7.8	n/a	n/a
Alkalinity (mg/L)	(2017)	225	210 - 260	n/a	n/a
Aggressiveness Index	(2017)	12.3	12.0 - 12.6	n/a	n/a
Langelier Index	(2017)	0.47	0.08 - 0.8	n/a	n/a

**Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE**

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ppb)	(2017)	53.65	6 - 61	80	n/a	No	By-product of drinking water disinfection

Chlorine (ppm)	(2017)	3.14	.25 - 3.5	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ppb)	(2017)	33.25	1 - 37	60	n/a	No	By-product of drinking water disinfection

## Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Ventura River Water District* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

## Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

**About our Lead:** Infants and children who drink water containing lead in excess of the action level may experience delays in their physical or mental development. Children may show slight deficits in attention span and learning abilities. Adults who drink this water over many years may develop kidney problems or high blood pressure.

## 2017 Consumer Confidence Report Drinking Water Assessment Information

### Assessment Information

VRWD has four active groundwater wells as its groundwater sources. The active wells are Wells 1, 2, 3, and 4. There are no sewer lines or sewage disposal facilities located within 50 and 100 feet of well sites, respectively. The four well sites are fenced for security. The wells are located about 700 feet from an active stream (when water is flowing). VRWD conducted the drinking water source assessment of its active wells in 2016. The following table lists the top possible contaminating activities for the wells. VRWD is constructing a new well, Well 7. The well has been drilled and the permit amendment issued February 26, 2018. VRWD turned the well on for service in March 2018. Wells #2 & #3 will be abandoned in the fall of 2018.

Well 01 (1989) - ) - Moderate physical barrier effectiveness.  
Possible Contaminating Activities ( top ranked):  
Sewer collection systems; animal grazing; low density septic systems,  
agricultural drainage; agricultural wells; NPDES/WDR permitted  
discharges; historic waste dumps/ landfills; storm drain discharge; storm  
water detention facility, roads and freeways; surface water

Well 03 - Active - - --- physical barrier effectiveness.  
Possible Contaminating Activities ( top ranked):  
Septic systems

Well 04 (2007) - - Moderate physical barrier effectiveness.  
Possible Contaminating Activities ( top ranked):  
Sewer collection systems; green waste processing; high and low density  
septic systems; animal grazing; agricultural drainage; agricultural wells;  
fertilizer, pesticide/ herbicide application; NPDES/WDR permitted  
discharges; historic gas stations and waste dumps/ landfills; underground  
storage tanks □confirmed; above ground storage tanks; storm drain  
discharge; storm water detention facility; surface water

### **Discussion of Vulnerability**

#### Well 1

The well was constructed in 1989 with a depth of 242 feet. An 8- inch sewer line is located about 60 feet west/northwest of the well and a single family residence' s septic system is located about 120 feet east of the well. The well site is within the Ventura River flood zone. The well is located over 150 feet from the river and therefore not subject to the SWTR requirements. The well is housed in a concrete block building. It has a 55 feet deep annular seal and a concrete surface seal. The well is equipped with a 16- inch steel casing and is packed with gravel. The highest perforations are 92 feet below the ground level. There are no clay layers located above the highest perforations. The well has a deep water turbine pump which is powered by an electrical motor. The well's air release valve is screened. Well 1 is the primary well and the only one pumping currently.

#### Well 3

The well was constructed in 1969 with a depth of 220 feet. It is housed in a metal building in a fenced site behind an office yard. The well is equipped with a 16- inch steel casing and packed with gravel. It is surface sealed and has an annular depth of 50 feet. The perforations begin at 70 feet below surface. The well' s geological formation is a mix of rock and clay from the ground surface down to the highest perforations. VRWD screened the well' s air release valve during the Sanitary Survey. The well will be shut down for the rest of this year ( last used in July).

#### Well 4

The well was constructed in 2007 with a depth of 250 feet. It is located in the Ventura River flood zone, but the flow in the river is over 150 feet away and therefore the well is not subjected to the SWTR requirements. An 8- inch sanitary sewer line runs about 125 feet from the well. A 16- inch 304 Stainless Steel casing was installed for the well. A cement grout annular seal was constructed from the surface to 50 feet below the ground surface. The well has a concrete surface seal. The well is housed in a concrete block building. The highest perforation is 73 feet deep and extends down to the 120 feet. The well' s air release valve is screened. The well has been offline since 2013. VRWD shall sample the well for nitrate and bacteriological activities before putting it back into service. VRWD shall also complete the Title 22 chemical testing of the well water prior to providing it to customers.

### **Acquiring Information**

A copy of the complete assessment may be viewed at:  
SWRCB Division of Drinking Water District Office  
1180 Eugenia Place  
Suite 200  
Carpinteria, CA 930135

You may request a summary of the assessment be sent to you by contacting:

Jeff Densmore

District Engineer

(805) 566-1326

[jeff.densmore@cdph.ca.gov](mailto:jeff.densmore@cdph.ca.gov)

A copy of the report can also be downloaded at:

<http://venturariverwd.com/news-and-events/>

# Ventura River Water District

## Analytical Results By FGL - 2017

### LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
<b>Lead</b>		ppb	0	15	0.2			3.1	22
11078 Rodeo Dr.	SP 1607324-17	ppb				2016-06-28	ND		
11551 N. Oakcrest Ave.	SP 1607324-2	ppb				2016-06-28	ND		
1210 Woodland Ave.	SP 1607324-12	ppb				2016-06-28	ND		
1211 Avila Dr.	SP 1607324-25	ppb				2016-06-28	ND		
172 Burnham Rd.	SP 1607324-20	ppb				2016-06-28	ND		
1991 Country Pl.	SP 1607324-8	ppb				2016-06-28	ND		
209 Carillo Rd.	SP 1607324-19	ppb				2016-06-28	ND		
2131 Burnham Rd.	SP 1607324-23	ppb				2016-06-28	ND		
2187 Woodland Ave.	SP 1607324-1	ppb				2016-06-28	ND		
2235 Los Encinos Rd.	SP 1607324-11	ppb				2016-06-28	ND		
2256 Los Encinos Rd.	SP 1607324-10	ppb				2016-06-28	ND		
365 Burnham Rd.	SP 1607324-9	ppb				2016-06-28	ND		
400 Burnham Rd.	SP 1607324-21	ppb				2016-06-28	ND		
45 Almond Ave.	SP 1611582-1	ppb				2016-09-29	ND		
45 Almond Ave.	SP 1607324-13	ppb				2016-06-28	24.7		
478 Burnham Rd.	SP 1607324-22	ppb				2016-06-28	ND		
56 Grapevine Rd.	SP 1607324-14	ppb				2016-06-28	ND		
573 E. Katherine Ave.	SP 1607324-15	ppb				2016-06-28	ND		
617 Country Dr.	SP 1607324-3	ppb				2016-06-28	ND		
640 Holly	SP 1607324-5	ppb				2016-06-28	ND		
80 Pathelen Ave.	SP 1607324-16	ppb				2016-06-28	5.6		
98 Wormwood St.	SP 1607324-7	ppb				2016-06-28	ND		
<b>Copper</b>		ppm		1.3	.3			0.54	22
11078 Rodeo Dr.	SP 1607324-17	ppm				2016-06-28	0.17		
11551 N. Oakcrest Ave.	SP 1607324-2	ppm				2016-06-28	0.06		
1210 Woodland Ave.	SP 1607324-12	ppm				2016-06-28	0.08		
1211 Avila Dr.	SP 1607324-25	ppm				2016-06-28	0.09		
172 Burnham Rd.	SP 1607324-20	ppm				2016-06-28	0.41		
1991 Country Pl.	SP 1607324-8	ppm				2016-06-28	0.14		
209 Carillo Rd.	SP 1607324-19	ppm				2016-06-28	0.17		
2131 Burnham Rd.	SP 1607324-23	ppm				2016-06-28	0.57		
2187 Woodland Ave.	SP 1607324-1	ppm				2016-06-28	0.10		
2235 Los Encinos Rd.	SP 1607324-11	ppm				2016-06-28	0.35		
2256 Los Encinos Rd.	SP 1607324-10	ppm				2016-06-28	0.54		
365 Burnham Rd.	SP 1607324-9	ppm				2016-06-28	0.13		
400 Burnham Rd.	SP 1607324-21	ppm				2016-06-28	0.09		
45 Almond Ave.	SP 1611582-1	ppm				2016-09-29	0.12		
45 Almond Ave.	SP 1607324-13	ppm				2016-06-28	0.13		
478 Burnham Rd.	SP 1607324-22	ppm				2016-06-28	0.73		
56 Grapevine Rd.	SP 1607324-14	ppm				2016-06-28	0.86		
573 E. Katherine Ave.	SP 1607324-15	ppm				2016-06-28	0.32		
617 Country Dr.	SP 1607324-3	ppm				2016-06-28	0.14		
640 Holly	SP 1607324-5	ppm				2016-06-28	0.13		
80 Pathelen Ave.	SP 1607324-16	ppm				2016-06-28	0.10		
98 Wormwood St.	SP 1607324-7	ppm				2016-06-28	0.13		

### SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Sodium</b>		ppm		none	none			43	38 - 49
Well 01 (1989)	SP 1702592-1	ppm				2017-02-28	44		
Well 01 (1989)	SP 1701637-1	ppm				2017-02-07	49		



Well 03 - Active	SP 1702589-1	ppm				2017-02-28	38		
Well 04 (2007)	SP 1702840-1	ppm				2017-03-07	40		
<b>Hardness</b>		ppm	none	none				387	371 - 403
Well 01 (1989)	SP 1702592-1	ppm				2017-02-28	395		
Well 01 (1989)	SP 1701637-1	ppm				2017-02-07	403		
Well 03 - Active	SP 1702589-1	ppm				2017-02-28	378		
Well 04 (2007)	SP 1702840-1	ppm				2017-03-07	371		

**PRIMARY DRINKING WATER STANDARDS (PDWS)**

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Fluoride</b>		ppm		2	1			0.5	0.4 - 0.5
Well 01 (1989)	SP 1702592-1	ppm				2017-02-28	0.5		
Well 01 (1989)	SP 1701637-1	ppm				2017-02-07	0.5		
Well 03 - Active	SP 1702589-1	ppm				2017-02-28	0.4		
Well 04 (2007)	SP 1702840-1	ppm				2017-03-07	0.5		
<b>Nitrate as N</b>		ppm		10	10			3.7	1.6 - 9.6
Well 01 (1989)	SP 1715213-1	ppm				2017-12-12	3.0		
Well 01 (1989)	SP 1713697-1	ppm				2017-11-07	2.9		
Well 01 (1989)	SP 1712450-1	ppm				2017-10-10	2.9		
Well 01 (1989)	SP 1711453-1	ppm				2017-09-19	2.7		
Well 01 (1989)	SP 1710238-1	ppm				2017-08-22	2.6		
Well 01 (1989)	SP 1707971-1	ppm				2017-07-05	2.6		
Well 01 (1989)	SP 1706749-1	ppm				2017-06-06	2.3		
Well 01 (1989)	SP 1705862-1	ppm				2017-05-16	1.7		
Well 01 (1989)	SP 1704661-1	ppm				2017-04-18	1.7		
Well 01 (1989)	SP 1702592-1	ppm				2017-02-28	1.7		
Well 01 (1989)	SP 1701965-1	ppm				2017-02-14	1.7		
Well 01 (1989)	SP 1701636-1	ppm				2017-02-07	1.8		
Well 01 (1989)	SP 1701637-1	ppm				2017-02-07	1.6		
Well 01 (1989)	SP 1701339-1	ppm				2017-01-31	2.3		
Well 01 (1989)	SP 1700983-1	ppm				2017-01-24	8.2		
Well 01 (1989)	SP 1700656-1	ppm				2017-01-18	7.7		
Well 01 (1989)	SP 1700629-1	ppm				2017-01-17	6.9		
Well 01 (1989)	SP 1700479-1	ppm				2017-01-13	8.2		
Well 01 (1989)	SP 1700430-1	ppm				2017-01-12	9.6		
Well 01 (1989)	SP 1700339-1	ppm				2017-01-11	8.6		
Well 01 (1989)	SP 1700313-1	ppm				2017-01-10	9.4		
Well 01 (1989)	SP 1700241-1	ppm				2017-01-09	7.5		
Well 01 (1989)	SP 1700023-1	ppm				2017-01-03	9.3		
Well 03 - Active	SP 1715213-2	ppm				2017-12-12	4.1		
Well 03 - Active	SP 1713697-2	ppm				2017-11-07	3.5		
Well 03 - Active	SP 1712450-2	ppm				2017-10-10	3.4		
Well 03 - Active	SP 1711453-2	ppm				2017-09-19	3.2		
Well 03 - Active	SP 1710238-2	ppm				2017-08-22	3.0		
Well 03 - Active	SP 1707971-2	ppm				2017-07-05	2.6		
Well 03 - Active	SP 1706749-2	ppm				2017-06-06	2.3		
Well 03 - Active	SP 1705862-2	ppm				2017-05-16	2.3		
Well 03 - Active	SP 1704661-2	ppm				2017-04-18	2.1		
Well 03 - Active	SP 1702589-1	ppm				2017-02-28	2.3		
Well 03 - Active	SP 1702595-1	ppm				2017-02-28	2.4		
Well 04 (2007)	SP 1715213-3	ppm				2017-12-12	3.2		
Well 04 (2007)	SP 1713697-3	ppm				2017-11-07	2.7		
Well 04 (2007)	SP 1712450-3	ppm				2017-10-10	2.7		
Well 04 (2007)	SP 1711453-3	ppm				2017-09-19	2.5		
Well 04 (2007)	SP 1710238-3	ppm				2017-08-22	2.5		
Well 04 (2007)	SP 1707971-3	ppm				2017-07-05	2.6		
Well 04 (2007)	SP 1706749-3	ppm				2017-06-06	2.3		
Well 04 (2007)	SP 1705862-3	ppm				2017-05-16	1.9		
Well 04 (2007)	SP 1704661-3	ppm				2017-04-18	1.7		

Well 04 (2007)	SP 1702840-1	ppm				2017-03-07	1.6		
<b>Nitrate + Nitrite as N</b>		ppm		10	10			1.8	1.6 - 2.3
Well 01 (1989)	SP 1702592-1	ppm				2017-02-28	1.7		
Well 01 (1989)	SP 1701637-1	ppm				2017-02-07	1.6		
Well 03 - Active	SP 1702589-1	ppm				2017-02-28	2.3		
Well 04 (2007)	SP 1702840-1	ppm				2017-03-07	1.6		
<b>Gross Alpha</b>		pCi/L		15	(0)			1.350	ND - 2.51
Well 01 (1989)	SP 1305549-1	pCi/L				2013-06-04	1.62		
Well 01 (1989)	SP 1302830-1	pCi/L				2013-03-19	1.29		
Well 03 - Active	SP 1305552-1	pCi/L				2013-06-04	2.51		
Well 03 - Active	SP 1302833-1	pCi/L				2013-03-19	1.27		
Well 04 (2007)	SP 1005996-1	pCi/L				2010-06-22	ND		
Well 04 (2007)	SP 1001299-1	pCi/L				2010-02-09	1.41		

**TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)**

	Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Nitrate as N</b>	ppm		10	10			4.6	2.0 - 7.1
Baldwin Tank #2 - NO3 BLEND	SP 1700656-2	ppm			2017-01-18	3.2		
Baldwin Tank #2 - NO3 BLEND	SP 1700629-2	ppm			2017-01-17	6.4		
Baldwin Tank #2 - NO3 BLEND	SP 1700479-2	ppm			2017-01-13	2.0		
Baldwin Tank #2 - NO3 BLEND	SP 1700430-2	ppm			2017-01-12	7.1		
Baldwin Tank #2 - NO3 BLEND	SP 1700339-2	ppm			2017-01-11	4.4		
Baldwin Tank #2 - NO3 BLEND	SP 1700313-2	ppm			2017-01-10	3.8		
Baldwin Tank #2 - NO3 BLEND	SP 1700241-2	ppm			2017-01-09	5.0		

**SECONDARY DRINKING WATER STANDARDS (SDWS)**

	Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Chloride</b>	ppm		500	n/a			42	28 - 53
Well 01 (1989)	SP 1702592-1	ppm			2017-02-28	47		
Well 01 (1989)	SP 1701637-1	ppm			2017-02-07	53		
Well 03 - Active	SP 1702589-1	ppm			2017-02-28	28		
Well 04 (2007)	SP 1702840-1	ppm			2017-03-07	40		
<b>Specific Conductance</b>	umhos/cm		1600	n/a			955	888 - 1000
Well 01 (1989)	SP 1702592-1	umhos/cm			2017-02-28	1000		
Well 01 (1989)	SP 1701637-1	umhos/cm			2017-02-07	1000		
Well 03 - Active	SP 1702589-1	umhos/cm			2017-02-28	888		
Well 04 (2007)	SP 1702840-1	umhos/cm			2017-03-07	932		
<b>Sulfate</b>	ppm		500	n/a			211	177 - 225
Well 01 (1989)	SP 1702592-1	ppm			2017-02-28	225		
Well 01 (1989)	SP 1701637-1	ppm			2017-02-07	218		
Well 03 - Active	SP 1702589-1	ppm			2017-02-28	177		
Well 04 (2007)	SP 1702840-1	ppm			2017-03-07	224		
<b>Total Dissolved Solids</b>	ppm		1000	n/a			648	590 - 690
Well 01 (1989)	SP 1702592-1	ppm			2017-02-28	660		
Well 01 (1989)	SP 1701637-1	ppm			2017-02-07	690		
Well 03 - Active	SP 1702589-1	ppm			2017-02-28	590		
Well 04 (2007)	SP 1702840-1	ppm			2017-03-07	650		
<b>Turbidity</b>	NTU		5	n/a			0.9	0.5 - 1.3
Well 01 (1989)	SP 1701637-1	NTU			2017-02-07	0.8		
Well 03 - Active	SP 1702589-1	NTU			2017-02-28	0.5		
Well 04 (2007)	SP 1702840-1	NTU			2017-03-07	1.3		

**UNREGULATED CONTAMINANTS**

	Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Boron</b>	ppm		NS	n/a			0.6	0.5 - 0.7
Well 01 (1989)	SP 1702592-1	ppm			2017-02-28	0.6		

Well 01 (1989)	SP 1701637-1	ppm				2017-02-07	0.7		
Well 03 - Active	SP 1702589-1	ppm				2017-02-28	0.5		
Well 04 (2007)	SP 1702840-1	ppm				2017-03-07	0.6		

ADDITIONAL DETECTIONS									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Calcium</b>		mg/L			n/a			109	106 - 112
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	112		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	112		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	107		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	106		
<b>Magnesium</b>		mg/L			n/a			28	26 - 30
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	28		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	30		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	27		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	26		
<b>pH</b>		units			n/a			7.6	7.2 - 7.8
Well 01 (1989)	SP 1702592-1	units				2017-02-28	7.8		
Well 01 (1989)	SP 1701637-1	units				2017-02-07	7.2		
Well 03 - Active	SP 1702589-1	units				2017-02-28	7.8		
Well 04 (2007)	SP 1702840-1	units				2017-03-07	7.4		
<b>Alkalinity</b>		mg/L			n/a			225	210 - 260
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	220		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	210		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	260		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	210		
<b>Aggressiveness Index</b>					n/a			12.3	12.0 - 12.6
Well 01 (1989)	SP 1702592-1					2017-02-28	12.6		
Well 01 (1989)	SP 1701637-1					2017-02-07	12.0		
Well 03 - Active	SP 1702589-1					2017-02-28	12.6		
Well 04 (2007)	SP 1702840-1					2017-03-07	12.1		
<b>Langelier Index</b>					n/a			0.47	0.08 - 0.8
Well 01 (1989)	SP 1702592-1					2017-02-28	0.7		
Well 01 (1989)	SP 1701637-1					2017-02-07	0.08		
Well 03 - Active	SP 1702589-1					2017-02-28	0.8		
Well 04 (2007)	SP 1702840-1					2017-03-07	0.3		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE									
		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
<b>Total Trihalomethanes (TTHMs)</b>		ppb		80	n/a			53.65	6 - 61
175 Rio Via - Stage 2 DBP	SP 1715865-1	ppb				2017-12-26	61		
175 Rio Via - Stage 2 DBP	SP 1711780-1	ppb				2017-09-26	51		
175 Rio Via - Stage 2 DBP	SP 1707741-1	ppb				2017-06-28	52		
175 Rio Via - Stage 2 DBP	SP 1703463-1	ppb				2017-03-21	50.6		
Average 175 Rio Via - Stage 2 DBP								53.65	
202 Valle Rio - Stage 2 DBP	SP 1715865-2	ppb				2017-12-26	6		
202 Valle Rio - Stage 2 DBP	SP 1711780-2	ppb				2017-09-26	7		
202 Valle Rio - Stage 2 DBP	SP 1707741-2	ppb				2017-06-28	12		
202 Valle Rio - Stage 2 DBP	SP 1703463-2	ppb				2017-03-21	14.3		
Average 202 Valle Rio - Stage 2 DBP								9.83	
<b>Chlorine</b>		ppm		4.0	4.0			3.14	.25 - 3.5
175 Rio Via	SP 1715214-1	ppm				2017-12-12	3.0		
175 Rio Via	SP 1713711-1	ppm				2017-11-07	3.0		
175 Rio Via	SP 1708196-1	ppm				2017-07-11	2.5		
175 Rio Via	SP 1707075-3	ppm				2017-06-13	3.0		
175 Rio Via	SP 1706748-1	ppm				2017-06-06	3.5		
175 Rio Via	SP 1704933-1	ppm				2017-04-25	3.5		



# Ventura River Water District

## CCR Login Linkage - 2017

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
SS - 1A	SP 1700980-1	2017-01-24	Coliform	1042 Moreno Dr. - Book 1A	Week 4 System Monitoring
	SP 1702839-1	2017-03-07	Coliform	1042 Moreno Dr. - Book 1A	Week 1 System Monitoring
	SP 1704337-1	2017-04-11	Coliform	1042 Moreno Dr. - Book 1A	Week 2 System Monitoring
	SP 1705861-1	2017-05-16	Coliform	1042 Moreno Dr. - Book 1A	Week 3 System Monitoring
	SP 1707742-1	2017-06-28	Coliform	1042 Moreno Dr. - Book 1A	Week 4 System Monitoring
	SP 1709232-1	2017-08-02	Coliform	1042 Moreno Dr. - Book 1A	Week 1 System Monitoring
	SP 1710746-1	2017-09-05	Coliform	1042 Moreno Dr. - Book 1A	Week 2 System Monitoring
	SP 1712814-1	2017-10-17	Coliform	1042 Moreno Dr. - Book 1A	Week 3 System Monitoring
	SP 1714671-1	2017-11-28	Coliform	1042 Moreno Dr. - Book 1A	Week 4 System Monitoring
11078 Rodeo Dr.	SP 1607324-17	2016-06-28	Metals, Total	11078 Rodeo Dr.	Lead & Copper Monitoring
113 Valle Rio A	SP 1712120-2	2017-10-03	Coliform	113 Valle Rio Ave.	Drinking Water Monitoring
11551 N. Oakcre	SP 1607324-2	2016-06-28	Metals, Total	11551 N. Oakcrest Ave.	Lead & Copper Monitoring
1210 Woodland A	SP 1607324-12	2016-06-28	Metals, Total	1210 Woodland Ave.	Lead & Copper Monitoring
1211 Avila Dr.	SP 1607324-25	2016-06-28	Metals, Total	1211 Avila Dr.	Lead & Copper Monitoring
172 Burnham Rd.	SP 1607324-20	2016-06-28	Metals, Total	172 Burnham Rd.	Lead & Copper Monitoring
SS - Wk4	SP 1700021-1	2017-01-03	Coliform	175 Rio Via	Week 1 System Monitoring
	SP 1700021-1	2017-01-03	Field Test	175 Rio Via	Week 1 System Monitoring
	SP 1701964-1	2017-02-14	Field Test	175 Rio Via	Week 2 System Monitoring
	SP 1701964-1	2017-02-14	Coliform	175 Rio Via	Week 2 System Monitoring
	SP 1703462-1	2017-03-21	Coliform	175 Rio Via	Week 3 System Monitoring
	SP 1703462-1	2017-03-21	Field Test	175 Rio Via	Week 3 System Monitoring
	SP 1704933-1	2017-04-25	Field Test	175 Rio Via	Week 4 System Monitoring
	SP 1704933-1	2017-04-25	Coliform	175 Rio Via	Week 4 System Monitoring
	SP 1706748-1	2017-06-06	Field Test	175 Rio Via	Week 1 System Monitoring
	SP 1706748-1	2017-06-06	Coliform	175 Rio Via	Week 1 System Monitoring
	SP 1707075-3	2017-06-13	Coliform	175 Rio Via	Week 2 System Monitoring
	SP 1707075-3	2017-06-13	Field Test	175 Rio Via	Week 2 System Monitoring
	SP 1708196-1	2017-07-11	Field Test	175 Rio Via	Week 2 System Monitoring
	SP 1708196-1	2017-07-11	Coliform	175 Rio Via	Week 2 System Monitoring
	SP 1713711-1	2017-11-07	Field Test	175 Rio Via	Week 1 System Monitoring
	SP 1713711-1	2017-11-07	Coliform	175 Rio Via	Week 1 System Monitoring
	SP 1715214-1	2017-12-12	Field Test	175 Rio Via	Week 2 System Monitoring
	SP 1715214-1	2017-12-12	Coliform	175 Rio Via	Week 2 System Monitoring
DBP 175RioVia	SP 1703463-1	2017-03-21	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1703463-1	2017-03-21	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1707741-1	2017-06-28	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1707741-1	2017-06-28	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1709869-1	2017-08-15	Coliform	175 RIO VIA - STAGE 2 DBP	Week 3 System Monitoring
	SP 1709869-1	2017-08-15	Field Test	175 RIO VIA - STAGE 2 DBP	Week 3 System Monitoring
	SP 1711778-1	2017-09-26	Field Test	175 RIO VIA - STAGE 2 DBP	Week 4 System Monitoring
	SP 1711780-1	2017-09-26	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1711778-1	2017-09-26	Coliform	175 RIO VIA - STAGE 2 DBP	Week 4 System Monitoring
	SP 1711780-1	2017-09-26	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1715865-1	2017-12-26	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1715865-1	2017-12-26	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
1991 Country Pl	SP 1607324-8	2016-06-28	Metals, Total	1991 Country Pl.	Lead & Copper Monitoring
DBP 202ValleRio	SP 1703463-2	2017-03-21	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1703463-2	2017-03-21	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1707741-2	2017-06-28	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1707741-2	2017-06-28	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1711780-2	2017-09-26	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1711780-2	2017-09-26	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1715865-2	2017-12-26	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1715865-2	2017-12-26	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
SS - 10A	SP 1700980-2	2017-01-24	Coliform	202 Valle Rio Ave. - Book 10A	Week 4 System Monitoring

	SP 1702839-2	2017-03-07	Coliform	202 Valle Rio Ave. - Book 10A	Week 1 System Monitoring
	SP 1704337-2	2017-04-11	Coliform	202 Valle Rio Ave. - Book 10A	Week 2 System Monitoring
	SP 1705861-2	2017-05-16	Coliform	202 Valle Rio Ave. - Book 10A	Week 3 System Monitoring
	SP 1707742-2	2017-06-28	Coliform	202 Valle Rio Ave. - Book 10A	Week 4 System Monitoring
	SP 1709232-2	2017-08-02	Coliform	202 Valle Rio Ave. - Book 10A	Week 1 System Monitoring
	SP 1710746-2	2017-09-05	Coliform	202 Valle Rio Ave. - Book 10A	Week 2 System Monitoring
	SP 1712814-2	2017-10-17	Coliform	202 Valle Rio Ave. - Book 10A	Week 3 System Monitoring
	SP 1714671-2	2017-11-28	Coliform	202 Valle Rio Ave. - Book 10A	Week 4 System Monitoring
209 Carillo Rd.	SP 1607324-19	2016-06-28	Metals, Total	209 Carillo Rd.	Lead & Copper Monitoring
SS - 9B	SP 1701635-1	2017-02-07	Coliform	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
	SP 1703140-1	2017-03-14	Coliform	2096 Sumac Dr. - Book 9B	Week 2 System Monitoring
	SP 1704654-1	2017-04-18	Coliform	2096 Sumac Dr. - Book 9B	Week 3 System Monitoring
	SP 1706212-1	2017-05-23	Coliform	2096 Sumac Dr. - Book 9B	Week 4 System Monitoring
	SP 1707975-1	2017-07-05	Coliform	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
	SP 1709511-1	2017-08-08	Coliform	2096 Sumac Dr. - Book 9B	Week 2 System Monitoring
	SP 1711454-1	2017-09-19	Coliform	2096 Sumac Dr. - Book 9B	Week 3 System Monitoring
	SP 1713115-1	2017-10-24	Coliform	2096 Sumac Dr. - Book 9B	Week 4 System Monitoring
	SP 1715053-1	2017-12-07	Coliform	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
2131 Burnham Rd	SP 1607324-23	2016-06-28	Metals, Total	2131 Burnham Rd.	Lead & Copper Monitoring
2187 Woodland A	SP 1607324-1	2016-06-28	Metals, Total	2187 Woodland Ave.	Lead & Copper Monitoring
2235 Los Encino	SP 1607324-11	2016-06-28	Metals, Total	2235 Los Encinos Rd.	Lead & Copper Monitoring
2256 Los Encino	SP 1607324-10	2016-06-28	Metals, Total	2256 Los Encinos Rd.	Lead & Copper Monitoring
SS - 9A	SP 1700021-2	2017-01-03	Coliform	265 E. Villanova Rd. Book 9A	Week 1 System Monitoring
	SP 1701964-2	2017-02-14	Coliform	265 E. Villanova Rd. Book 9A	Week 2 System Monitoring
	SP 1703462-2	2017-03-21	Coliform	265 E. Villanova Rd. Book 9A	Week 3 System Monitoring
	SP 1704933-2	2017-04-25	Coliform	265 E. Villanova Rd. Book 9A	Week 4 System Monitoring
	SP 1706748-2	2017-06-06	Coliform	265 E. Villanova Rd. Book 9A	Week 1 System Monitoring
	SP 1708196-2	2017-07-11	Coliform	265 E. Villanova Rd. Book 9A	Week 2 System Monitoring
	SP 1709869-2	2017-08-15	Field Test	265 E. Villanova Rd. Book 9A	Week 3 System Monitoring
	SP 1709869-2	2017-08-15	Coliform	265 E. Villanova Rd. Book 9A	Week 3 System Monitoring
	SP 1711778-2	2017-09-26	Coliform	265 E. Villanova Rd. Book 9A	Week 4 System Monitoring
	SP 1713711-2	2017-11-07	Coliform	265 E. Villanova Rd. Book 9A	Week 1 System Monitoring
	SP 1715214-2	2017-12-12	Coliform	265 E. Villanova Rd. Book 9A	Week 2 System Monitoring
SS - 8	SP 1700630-2	2017-01-17	Field Test	290 Alto Dr. - Book 8	Week 3 System Monitoring
	SP 1700630-2	2017-01-17	Coliform	290 Alto Dr. - Book 8	Week 3 System Monitoring
	SP 1702593-2	2017-02-28	Coliform	290 Alto Dr. - Book 8	Week 4 System Monitoring
	SP 1704056-2	2017-04-04	Coliform	290 Alto Dr. - Book 8	Week 1 System Monitoring
	SP 1705519-2	2017-05-09	Coliform	290 Alto Dr. - Book 8	Week 2 System Monitoring
	SP 1707359-2	2017-06-20	Coliform	290 Alto Dr. - Book 8	Week 3 System Monitoring
	SP 1708926-2	2017-07-25	Coliform	290 Alto Dr. - Book 8	Week 4 System Monitoring
	SP 1711046-2	2017-09-12	Coliform	290 Alto Dr. - Book 8	Week 1 System Monitoring
	SP 1712451-2	2017-10-10	Coliform	290 Alto Dr. - Book 8	Week 2 System Monitoring
	SP 1714468-2	2017-11-21	Coliform	290 Alto Dr. - Book 8	Week 3 System Monitoring
	SP 1715864-2	2017-12-26	Coliform	290 Alto Dr. - Book 8	Week 4 System Monitoring
305 Cabrillo At	SP 1714784-1	2017-11-30	Field Test	305 Cabrillo At Hydrant	Bacti Monitoring
	SP 1714784-1	2017-11-30	Coliform	305 Cabrillo At Hydrant	Bacti Monitoring
365 Burnham Rd.	SP 1607324-9	2016-06-28	Metals, Total	365 Burnham Rd.	Lead & Copper Monitoring
400 Burnham Rd.	SP 1607324-21	2016-06-28	Metals, Total	400 Burnham Rd.	Lead & Copper Monitoring
45 Almond Ave.	SP 1607324-13	2016-06-28	Metals, Total	45 Almond Ave.	Lead & Copper Monitoring
45 Almond Ave	SP 1611582-1	2016-09-29	Metals, Total	45 Almond Ave.	CU & PB-Resample
478 Burnham Rd.	SP 1607324-22	2016-06-28	Metals, Total	478 Burnham Rd.	Lead & Copper Monitoring
56 Grapevine Rd	SP 1607324-14	2016-06-28	Metals, Total	56 Grapevine Rd.	Lead & Copper Monitoring
573 E. Katherin	SP 1607324-15	2016-06-28	Metals, Total	573 E. Katherine Ave.	Lead & Copper Monitoring
SS - 7	SP 1701635-2	2017-02-07	Coliform	595 Riverside Rd. - Book 7	Week 1 System Monitoring
	SP 1703140-2	2017-03-14	Coliform	595 Riverside Rd. - Book 7	Week 2 System Monitoring
	SP 1704654-2	2017-04-18	Coliform	595 Riverside Rd. - Book 7	Week 3 System Monitoring
	SP 1706212-2	2017-05-23	Coliform	595 Riverside Rd. - Book 7	Week 4 System Monitoring
	SP 1707975-2	2017-07-05	Coliform	595 Riverside Rd. - Book 7	Week 1 System Monitoring
	SP 1709511-2	2017-08-08	Coliform	595 Riverside Rd. - Book 7	Week 2 System Monitoring
	SP 1711454-2	2017-09-19	Coliform	595 Riverside Rd. - Book 7	Week 3 System Monitoring

	SP 1713115-2	2017-10-24	Coliform	595 Riverside Rd. - Book 7	Week 4 System Monitoring
	SP 1715053-2	2017-12-07	Coliform	595 Riverside Rd. - Book 7	Week 1 System Monitoring
617 Country Dr.	SP 1607324-3	2016-06-28	Metals, Total	617 Country Dr.	Lead & Copper Monitoring
640 Holly	SP 1607324-5	2016-06-28	Metals, Total	640 Holly	Lead & Copper Monitoring
SS - 5A	SP 1700312-2	2017-01-10	Field Test	72 Catalina Dr. - Book 5A	Week 2 System Monitoring
	SP 1700312-2	2017-01-10	Coliform	72 Catalina Dr. - Book 5A	Week 2 System Monitoring
	SP 1702236-2	2017-02-21	Coliform	72 Catalina Dr. - Book 5A	Week 3 System Monitoring
	SP 1703754-2	2017-03-28	Coliform	72 Catalina Dr. - Book 5A	Week 4 System Monitoring
	SP 1705216-2	2017-05-02	Coliform	72 Catalina Dr. - Book 5A	Week 1 System Monitoring
	SP 1707075-2	2017-06-13	Coliform	72 Catalina Dr. - Book 5A	Week 2 System Monitoring
	SP 1708583-2	2017-07-18	Coliform	72 Catalina Dr. - Book 5A	Week 3 System Monitoring
	SP 1710243-2	2017-08-22	Coliform	72 Catalina Dr. - Book 5A	Week 4 System Monitoring
	SP 1712119-2	2017-10-03	Coliform	72 Catalina Dr. - Book 5A	Week 1 System Monitoring
	SP 1714082-2	2017-11-14	Coliform	72 Catalina Dr. - Book 5A	Week 2 System Monitoring
	SP 1715579-2	2017-12-19	Coliform	72 Catalina Dr. - Book 5A	Week 3 System Monitoring
80 Pathelen Ave	SP 1607324-16	2016-06-28	Metals, Total	80 Pathelen Ave.	Lead & Copper Monitoring
85 Almond AVE	SP 1700312-1	2017-01-10	Field Test	85 Almond Ave. - Book 6B	Week 2 System Monitoring
	SP 1700312-1	2017-01-10	Coliform	85 Almond Ave. - Book 6B	Week 2 System Monitoring
	SP 1702236-1	2017-02-21	Coliform	85 Almond Ave. - Book 6B	Week 3 System Monitoring
	SP 1703754-1	2017-03-28	Coliform	85 Almond Ave. - Book 6B	Week 4 System Monitoring
	SP 1705216-1	2017-05-02	Coliform	85 Almond Ave. - Book 6B	Week 1 System Monitoring
	SP 1707075-1	2017-06-13	Coliform	85 Almond Ave. - Book 6B	Week 2 System Monitoring
	SP 1708583-1	2017-07-18	Coliform	85 Almond Ave. - Book 6B	Week 3 System Monitoring
	SP 1710243-1	2017-08-22	Coliform	85 Almond Ave. - Book 6B	Week 4 System Monitoring
	SP 1712119-1	2017-10-03	Coliform	85 Almond Ave. - Book 6B	Week 1 System Monitoring
	SP 1714082-1	2017-11-14	Coliform	85 Almond Ave. - Book 6B	Week 2 System Monitoring
	SP 1715579-1	2017-12-19	Coliform	85 Almond Ave. - Book 6B	Week 3 System Monitoring
SS - 14	SP 1700630-1	2017-01-17	Field Test	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1700630-1	2017-01-17	Coliform	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1702593-1	2017-02-28	Coliform	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1702593-1	2017-02-28	Field Test	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1704056-1	2017-04-04	Field Test	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1704056-1	2017-04-04	Coliform	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1705519-1	2017-05-09	Field Test	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1705519-1	2017-05-09	Coliform	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1707359-1	2017-06-20	Field Test	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1707359-1	2017-06-20	Coliform	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1708926-1	2017-07-25	Field Test	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1708926-1	2017-07-25	Coliform	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1711046-1	2017-09-12	Coliform	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1711046-1	2017-09-12	Field Test	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1712451-1	2017-10-10	Coliform	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1712451-1	2017-10-10	Field Test	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1714468-1	2017-11-21	Coliform	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1714468-1	2017-11-21	Field Test	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1715027-1	2017-12-06	Coliform	9148 Nye Rd. - Book 14	NYE RD
	SP 1715027-1	2017-12-06	Field Test	9148 Nye Rd. - Book 14	NYE RD
	SP 1715055-1	2017-12-07	Coliform	9148 Nye Rd. - Book 14	Nye Rd.
	SP 1715055-1	2017-12-07	Field Test	9148 Nye Rd. - Book 14	Nye Rd.
	SP 1715864-1	2017-12-26	Coliform	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1715864-1	2017-12-26	Field Test	9148 Nye Rd. - Book 14	Week 4 System Monitoring
98 Wormwood St.	SP 1607324-7	2016-06-28	Metals, Total	98 Wormwood St.	Lead & Copper Monitoring
Bald Tnk 2	SP 1700241-2	2017-01-09	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
	SP 1700313-2	2017-01-10	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
	SP 1700339-2	2017-01-11	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
	SP 1700430-2	2017-01-12	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
	SP 1700479-2	2017-01-13	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
	SP 1700629-2	2017-01-17	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
	SP 1700656-2	2017-01-18	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
Warf Head Corne	SP 1709234-1	2017-08-02	Coliform	Warf Head Corner Market	Warf Head Corner Market

Well 01	SP 1302831-1	2013-03-19	Asbestos	Well 01 (1989)	Source Asbestos - Wells 1,3,4
	SP 1302830-1	2013-03-19	Radio Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1305549-1	2013-06-04	Radio Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1700023-1	2017-01-03	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1700241-1	2017-01-09	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1700313-1	2017-01-10	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1700339-1	2017-01-11	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1700430-1	2017-01-12	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1700479-1	2017-01-13	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1700629-1	2017-01-17	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1700656-1	2017-01-18	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1700983-1	2017-01-24	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1701339-1	2017-01-31	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1701636-1	2017-02-07	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1701637-1	2017-02-07	General Mineral	Well 01 (1989)	Well 01 - Water Quality
	SP 1701637-1	2017-02-07	Wet Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1701965-1	2017-02-14	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1702592-1	2017-02-28	General Mineral	Well 01 (1989)	Well 01 - Water Quality
	SP 1704661-1	2017-04-18	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1705862-1	2017-05-16	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1706749-1	2017-06-06	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1707971-1	2017-07-05	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1710238-1	2017-08-22	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1711453-1	2017-09-19	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1712450-1	2017-10-10	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1713697-1	2017-11-07	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1715213-1	2017-12-12	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
Well 03	SP 1302833-1	2013-03-19	Radio Chemistry	Well 03 - Active	Well 03 - Radio Monitoring
	SP 1305552-1	2013-06-04	Radio Chemistry	Well 03 - Active	Well 03 - Radio Monitoring
	SP 1702595-1	2017-02-28	Wet Chemistry	Well 03 - Active	Well 03 - Water Quality
	SP 1702589-1	2017-02-28	General Mineral	Well 03 - Active	Well 03 - Water Quality
	SP 1702589-1	2017-02-28	Wet Chemistry	Well 03 - Active	Well 03 - Water Quality
	SP 1704661-2	2017-04-18	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1705862-2	2017-05-16	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1706749-2	2017-06-06	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1707971-2	2017-07-05	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1710238-2	2017-08-22	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1711453-2	2017-09-19	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1712450-2	2017-10-10	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1713697-2	2017-11-07	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1715213-2	2017-12-12	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
Well 04	SP 1001299-1	2010-02-09	Radio Chemistry	Well 04 (2007)	Gross Alpha/Radium Well #4
	SP 1005996-1	2010-06-22	Radio Chemistry	Well 04 (2007)	Well #4 Radioactive/Radium
	SP 1702840-1	2017-03-07	General Mineral	Well 04 (2007)	Well 04 - Water Quality
	SP 1702840-1	2017-03-07	Wet Chemistry	Well 04 (2007)	Well 04 - Water Quality
	SP 1704661-3	2017-04-18	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1705862-3	2017-05-16	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1706749-3	2017-06-06	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1707971-3	2017-07-05	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1710238-3	2017-08-22	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1711453-3	2017-09-19	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1712450-3	2017-10-10	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1713697-3	2017-11-07	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1715213-3	2017-12-12	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring



## Casitas Water Quality Table 2017 Data

LAKE CASITAS TREATED WATER											
Turbidity (NTU)	MCL or [MRDL]	PHG (MCLG) [MRDLG]	AVERAGE		RANGE		YEAR TESTED		Lake or Distribution System	Mira Monte Well <sup>1</sup>	SOURCE OF CONSTITUENT
			AVERAGE	RANGE	AVERAGE	RANGE	2017	2016			
Filter Effluent Turbidity (NTU) <sup>a</sup>	1 NTU	NA	Highest value = 0.10		NA		2017	2016	NA	NA	Soil run-off
	95% < 0.2 NTU		100% of turbidity measurements were < 0.2 NTU				2017	2016	NA		
			100% = lowest monthly % of samples meeting turbidity limits								
			TT Violation:		Fails to maintain at least 0.2 ppm chlorine residual at entry point to distribution system <sup>a</sup>		12/5/2017				
Microbiological											
			AVERAGE		RANGE		YEAR TESTED				
Total Coliform Bacteria <sup>b</sup>	> 1 positive sample/month	(0)	0		0		2017	2016	NA	Naturally present in the environment	
E. Coli Bacteria	> 1 positive sample/month	(0)	0		0		2017	2016	NA	Human and animal fecal waste	
Inorganic Chemicals											
			Lake Casitas Treated		Mira Monte Well		Distribution System				
			AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE			
Barium (ppm)	1	2	0.1	NA	0.1	NA	NA	NA	2017	2016	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Fluoride (ppm)	2.0	1	0.5	NA	0.6	NA	NA	NA	2017	2016	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate as N (ppm) <sup>c</sup>	10	10	ND	NA	10.8	7.6-12.6	0.9	0.5-1.2	2017	2016	Runoff and leaching from fertilizer use; leaching from tanks and sewerage; erosion from natural products
DISINFECTION BY-PRODUCTS AND DISINFECTANT RESIDUALS											
			AVERAGE		RANGE		YEAR TESTED				
Chloramines (ppm)	[4.0]	[4.0]	2.7		0.7-3.6		2017	2016	NA	Drinking water disinfectant added for treatment	
Tribalohmethanes (ppb)	80	NA	48.6		27.6-56		2017	2016	NA	By-product of drinking water disinfection	
Haloacetic acids (ppb)	60	NA	41		24-52		2017	2016	NA	By-product of drinking water disinfection	
INDIVIDUAL TAP MONITORING FOR LEAD AND COPPER											
			Regulatory Action Level (RAL)	PHG	Number of Samples Collected	Homes above RAL	Level Detected at 90th percentile		Year Tested		
Lead (ppb) <sup>d</sup>	15	0.2	20	0	ND		2017	2016	NA	Internal corrosion of household plumbing systems; discharges from industrial manufacturers; erosion of natural products	
Lead school					Number of schools requesting lead sampling = 4						
Copper (ppm) <sup>e</sup>	1.3	0.3	20	1	1.0		2017	2016	NA	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	

### Secondary Aesthetic Standards

CONSTITUENTS	State MCL	PHG	Lake Casitas Treated		Mira Monte Well		Distribution System		YEAR TESTED		Source of Constituent
			AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE	Lake	Well <sup>1</sup>	
Turbidity (NTU)	5	NA	0.4	NA	0.2	NA	NA	NA	2017	2016	Soil run-off
Total Dissolved Solids (ppm)	1000	NA	390	NA	380	NA	NA	NA	2017	2016	Run-off/leaching from natural deposits
Specific Conductance (uS/cm)	1600	NA	641	NA	633	NA	NA	NA	2017	2016	Substances that form ions in water; sewerage influence
Chloride (ppm)	500	NA	24	NA	58	NA	NA	NA	2017	2016	Run-off/leaching from natural deposits; sewerage influence
Sulfate (ppm)	500	NA	166	NA	37.9	NA	NA	NA	2017	2016	Run-off/leaching from natural deposits; industrial wastes
Zinc (ppm)	5	NA	ND	NA	0.12	0.09-0.15	NA	NA	2017	2016	Run-off/leaching from natural deposits; industrial wastes

### Additional Monitoring

ICMR 3 Monitoring	MCL	PHG	Lake Casitas Treated		Mira Monte Well		Distribution System		YEAR TESTED		Source of Constituent
			AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE	Lake	Well <sup>1</sup>	
Chlorate (ppb)	800	NA	ND	ND	176	65-290	ND	ND	2013	2013	A disinfection by-product
Molybdenum (ppb)	NA	NA	3.3	3.1-3.4	1.0	ND-1.9	3.4	3.2-3.5	2013	2013	A naturally-occurring element found in ores and present in plants, animals and bacteria
Selenium (ppb)	NA	NA	703	660-750	520	470-570	723	670-770	2013	2013	A naturally-occurring element
Vanadium (ppb)	50	NA			See footnote g				2013	2013	A naturally-occurring elemental metal
Additional Constituents (Unregulated)			PHG (NL)	Lake Casitas Treated		Mira Monte Well		YEAR TESTED		SOURCE OF CONSTITUENT	
				AVERAGE	RANGE	AVERAGE	RANGE	Lake	Well <sup>1</sup>		
Alkalinity (Total as CaCO <sub>3</sub> ppm)	NA	NA	130	NA	150		NA	2017	2016	A measure of the capacity to neutralize acid	
pH (units)	6.5-8.5 US EPA	NA	6.8	NA	6.7		NA	2017	2016	A measure of acidity or alkalinity	
Bicarbonate Alkalinity (HCO <sub>3</sub> )	NA	NA	160	140	180		NA	2017	2016		
Boron (ppb)	NA	(1000)	200	NA	ND		NA	2017	2016	A naturally-occurring element	
Calcium (ppm)	NA	NA	51	NA	47		NA	2017	2016	A naturally-occurring element	
Magnesium (ppm)	NA	NA	26	NA	14		NA	2017	2016	A naturally-occurring element	
Potassium (ppm)	NA	NA	3	NA	ND		NA	2017	2016	A naturally-occurring element	
Total Hardness (ppm)	NA	NA	<sup>234</sup> (13.7 grains/gal)	NA	175		NA	2017	2016	"Hardness" is the sum of polyvalent cations present in the water, generally magnesium and calcium. The cations are usually naturally occurring.	
Sodium (ppm)	NA	NA	30	NA	50		NA	2017	2016	"Sodium" refers to the salt present in the water and is generally naturally occurring.	

*TT Violation	Explanation	Length	Steps Taken to Correct the Violation	Possible Contaminants	Health Effects
On December 5th 2017, disinfectant levels temporarily dropped below 0.2 milligrams per liter (mg/L) for 4.5 hours. The standard is that levels may not drop below 0.2 mg/L for more than four hours.	The Treatment Plant staff were forced to evacuate the plant due to the close proximity of the "Thomas Fire".	4 hours, 25 minutes	Staff returned to treatment plant when it was safe to do so. As directed by the State Water Resources Control Board, a "Boil Water Notification" was issued to the affected areas. After disinfection resumed, and special testing was completed, the "Boil Water Notification" was cancelled. The filtration process continued uninterrupted during this time.	<i>Giardia lamblia</i> <sup>h</sup> , Viruses, Heterotrophic Plate Count bacteria, <i>Legionella</i> , <i>Cryptosporidium</i> <sup>h</sup>	Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

### Abbreviations and Definitions:

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the taste and appearance of drinking water.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a disinfectant in drinking water below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Notification Level:** Health based advisory levels established by the State Board for chemicals in drinking water that lack MCLs.

NA - Not Applicable  
 ND - None Detected  
 NL - Notification Level  
 NS - No Sample

NTU - Nephelometric Turbidity Units (a measure of turbidity)  
 ppt - Parts per trillion or nanograms per liter (ng/L)  
 pCi/L - Picocuries per liter (a measure of radiation)  
 ppm - Parts per million, or milligrams per liter (mg/L)  
 ppb - Parts per billion, or micrograms per liter (ug/L)

**Primary Drinking Water Standards (PDWS):** MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Regulatory Action Level (RAL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Secondary Drinking Water Standards (SDWS):** MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWS do not affect the health at the MCL levels.

**Treatment Techniques:** A required process intended to reduce the level of a contaminant in drinking water.

**ICMR 3: Unregulated Monitoring Rule (Third round):** This monitoring helps the EPA and the State Board determine where certain contaminants occur and whether the contaminants need to be regulated.

uS/cm - Micro Siemens per Centimeter (a measure of specific conductance).

**Water Quality Table Footnotes:**

a) Turbidity is a measure of the cloudiness of water and is a good measure of water quality and filtration performance; 100% of the samples tested for turbidity were below the required TT level of 0.2 NTU and 100% is the lowest monthly percentage of samples meeting the turbidity limits.

b) During 2017 Casitas collected 156 samples for total coliform bacteria testing according to the Total Coliform Rule. Total Coliform bacteria were not detected in any of these samples.

c) Mira Monte Well can be above the MCL for nitrate, however the well water is blended with lake Casitas water with the resulting nitrate level averaging 0.9 ppm as nitrogen.

d) The State allows us to monitor for some contaminants less than once per year because the concentration of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

e) Casitas has implemented a corrosion control plan by adding a small amount of phosphate to the water to lower corrosivity and reduce copper levels.

f) These results are below the detection limits for reporting and can only be used as an estimate. For vanadium sampling the highest level (in ppb) for the lake was 1.2 (ND for 2014), the well was 0.78 and 1.2 for the distribution system.

g) Vanadium results of the treated water for 2017 were ND.

h) During 2017 the treated treatment plant influent had negative results for monthly testing of *Giardia* and *Cryptosporidium*.