

2018 Consumer Confidence Report

Water System Name: VENTURA RIVER WATER DISTRICT

Report Date: April 2019

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2018.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: According to SWRCB records, the Sources Well 01 and Well 02 are Groundwater. This Assessment was done using the Default Groundwater System Method. Information regarding the type of water source of Well 03, Well 04, and Well 07 is not available, as these sources do not have a completed assessment on file. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

Your water comes from 5 source(s): Well 01 (1989), Well 02, Well 03 - Active, Well 04 (2007) and Well 07 (New) **and from 1 treated location(s):** Baldwin Tank #2 - NO3 BLEND

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled water board or city/county council meetings currently are not held.

For more information about this report, or any questions relating to your drinking water, please call (805) 646-3403 and ask for Bert Rapp.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER						
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Lead (ug/L)	22 (2016)	3.1	1	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers, erosion of natural deposits
Copper (mg/L)	22 (2016)	0.54	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2014 - 2017)	44	38 - 49	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2014 - 2017)	396	371 - 419	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Aluminum (mg/L)	(2014 - 2017)	ND	ND - 0.06	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes

Fluoride (mg/L)	(2014 - 2017)	0.4	ND - 0.5	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.
Nitrate as N (mg/L)	(2014 - 2018)	3.7	1.2 - 6.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2014 - 2017)	2.1	1.2 - 4.2	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2010 - 2016)	1.281	ND - 3.43	15	(0)	Erosion of natural deposits.

Table 4 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Nitrate as N (mg/L)	(2018)	3.2	2.5 - 3.7	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2014 - 2017)	44	28 - 57	500	n/a	Runoff/leaching from natural deposits; seawater influence
Iron (ug/L)	(2014 - 2017)	ND	ND - 100	300	n/a	Leaching from natural deposits; Industrial wastes
Specific Conductance (umhos/cm)	(2014 - 2017)	959	888 - 1020	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2014 - 2017)	216	177 - 241	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2014 - 2017)	657	590 - 720	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2014 - 2017)	0.7	ND - 1.3	5	n/a	Soil runoff

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2014 - 2017)	0.6	0.5 - 0.7	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

Table 7 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2014 - 2017)	111	106 - 116	n/a	n/a
Magnesium (mg/L)	(2014 - 2017)	29	26 - 32	n/a	n/a
pH (units)	(2014 - 2017)	7.4	6.7 - 7.8	n/a	n/a
Alkalinity (mg/L)	(2014 - 2017)	218	180 - 260	n/a	n/a
Aggressiveness Index	(2014 - 2017)	12.2	11.5 - 12.6	n/a	n/a
Langelier Index	(2014 - 2017)	0.33	-0.4 - 0.8	n/a	n/a

Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2018)	62	4 - 75	80	n/a	No	By-product of drinking water disinfection
Chlorine (mg/L)	(2018)	3.39	.8 - 3.5	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2018)	48.25	ND - 55	60	n/a	No	By-product of drinking water disinfection

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Ventura River Water District* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

About our Lead: Infants and children who drink water containing lead in excess of the action level may experience delays in their physical or mental development. Children may show slight deficits in attention span and learning abilities. Adults who drink this water over many years may develop kidney problems or high blood pressure.

2018 Consumer Confidence Report Drinking Water Assessment Information

Assessment Information

VRWD has five active groundwater wells as its groundwater sources. The active wells are Wells 1, 2, 3, 4 and 7. There are no sewer lines or sewage disposal facilities located within 50 and 100 feet of well sites, respectively. The five well sites are fenced for security. The wells are located about 700 feet from an active stream (when water is flowing). VRWD conducted the drinking water source assessment of its active wells. Well 1 and 2' s assessments was completed back in August 2001; Well 4' s assessment was completed in March 2007.

- Well 01 (1989) -) - Moderate physical barrier effectiveness.
Possible Contaminating Activities (top ranked):
Sewer collection systems; animal grazing; low density septic systems, agricultural drainage; agricultural wells; NPDES/WDR permitted discharges; historic waste dumps/ landfills; storm drain discharge; storm water detention facility, roads and freeways; surface water
- Well 02 - Low physical barrier effectiveness.
Possible Contaminating Activities (top ranked):
Sewer collection systems; utility stations; green waste transfer station; animal grazing; high and low density septic systems, agricultural drainage; agricultural wells; irrigated crops; NPDES/WDR permitted discharges; historic gas stations; historic waste dumps/ landfills; abandoned wells; storm drain discharge; storm water detention facility; roads and freeways; surface water
- Well 03 - Active - - --- physical barrier effectiveness.
Possible Contaminating Activities (top ranked):
Septic systems
- Well 04 (2007) - - Moderate physical barrier effectiveness.
Possible Contaminating Activities (top ranked):
Sewer collection systems; green waste processing; high and low density septic systems; animal grazing; agricultural drainage; agricultural wells; fertilizer, pesticide/ herbicide application; NPDES/WDR permitted discharges; historic gas stations and waste dumps/ landfills; underground storage tanks [confirmed]; above ground storage tanks; storm drain discharge; storm water detention facility; surface water
- Well 07 (New) - Moderate physical barrier effectiveness.
Possible Contaminating Activities (top ranked):
Sewer collection systems; animal grazing; low density septic systems, agricultural drainage; agricultural wells; NPDES/WDR permitted discharges; historic waste dumps/ landfills; storm drain discharge; storm water detention facility, roads and freeways; surface water

Acquiring Information

A copy of the complete assessment may be viewed at:
SWRCB Division of Drinking Water District Office
1180 Eugenia Place
Suite 200
Carpinteria, CA 930135

You may request a summary of the assessment be sent to you by contacting:
Jeff Densmore
District Engineer
(805) 566-1326
jeff.densmore@cdph.ca.gov

A copy of the report can also be downloaded at:
<http://venturariverwd.com/news-and-events/>

Casitas Water Quality Table 2018 Data

LAKE CASITAS TREATED WATER											
TURBIDITY	MCL or [MRDL]	PHG, (MCLG) [MRDLG]	AVERAGE		RANGE		YEAR TESTED		SOURCE OF CONSTITUENT		
			Lake or Distribution System	Mira Monte Well ^a	Lake or Distribution System	Mira Monte Well ^a	Lake or Distribution System	Mira Monte Well ^a			
Filter Effluent Turbidity (NTU) ^b	1 NTU	NA	Highest Value = 0.07		0.01-0.07		2018	NA	Soil run-off		
	95% < 0.2 NTU		100% of turbidity measurements were < 0.2 NTU				2018	NA			
			100% = lowest monthly % of samples meeting turbidity limits								
MICROBIOLOGICAL											
Total Coliform Bacteria ^c	> 1 positive sample/month	(0)	0		0		2018	NA	Naturally present in the environment		
E. Coli Bacteria	> 1 positive sample/month	(0)	0		0		2018	NA	Human and animal fecal waste		
INORGANIC CHEMICALS											
Barium (ppm)	1	2	Water		Mira Monte Well		Distribution System		2018	2016	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
			AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE			
			0.1	NA	0.1	NA	NA	NA			
Fluoride (ppm)	2.0	1	0.4	NA	0.6	NA	NA	NA	2018	2016	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate as N (ppm) ^d	10	10	ND	NA	9.3	7.4-10.5	0.8	0.5-1.0	2018	2018	Runoff and leaching from fertilizer use; leaching from tanks and sewerage; erosion from natural products
DISINFECTION BY PRODUCTS AND DISINFECTANT RESIDUALS											
Chloramines(ppm)	[4.0]	[4.0]	AVERAGE		RANGE		2018	NA	Drinking water disinfectant added for treatment		
			2.5		0.8-3.8						
Trihalomethanes (ppb)	80	NA	62		46-69		2018	NA	By-product of drinking water disinfection		
Halacetic acids (ppb)	60	NA	48		21-61		2018	NA	By-product of drinking water disinfection		

INDIVIDUAL TAP MONITORING FOR LEAD AND COPPER:

	Regulatory Action Level (RAL)	PHG	Number of Samples Collect.	Homes above RAL	Level Detected at 90th percentile	Year Tested		
Lead (ppb) ^e	15	0.2	20	0	ND	2017	NA	Internal corrosion of household plumbing systems; discharges from industrial manufacturers; erosion of natural products
Copper (ppm) ^f	1.3	0.3	20	1	1.0	2017	NA	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead school			Number of schools requesting lead sampling = 4			2017		Internal corrosion of end-user plumbing systems; discharges from industrial manufacturers; erosion of natural products

SECONDARY AESTHETIC STANDARDS

CONSTITUENTS	State MCL	PHG	Lake Casitas Treated		Mira Monte Well		Distribution System		YEAR TESTED		Source of Constituent
			AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE	Lake/Dist. Syst.	Well ^g	
Turbidity (NTU)	5	NA	0.2	NA	0.2	NA	0.3 ^h	0.1-0.9 ^h	2018	2016	Soil run-off
Total Dissolved Solids (ppm)	1000	NA	390	NA	380	NA	NA	NA	2018	2016	Run-off/leaching from natural deposits
Specific Conductance (uS/cm)	1600	NA	652	NA	633	NA	648 ^h	568-687 ^h	2018	2016	Substances that form ions in water; seawater influence
Chloride (ppm)	500	NA	24	NA	58	NA	NA	NA	2018	2016	Run-off/leaching from natural deposits; seawater influence
Sulfate (ppm)	500	NA	163	NA	37.9	NA	NA	NA	2018	2016	Run-off /leaching from natural deposits; industrial wastes
Zinc (ppm)	5	NA	ND	NA	0.12	0.09-0.15	NA	NA	2018	2016	Run-off /leaching from natural deposits; industrial wastes

ADDITIONAL CONSTITUENTS

UCMR 3 Monitoring	NL	PHG	Water		Mira Monte Well		Distribution System		Year Tested		SOURCE OF CONSTITUENT
			AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE	Lake	Well ^g	
Chlorate (ppb)	800	NA	ND	ND	176	65-290	ND	ND	2013	2013	A disinfection by-product
Molybdenum (ppb)	NA	NA	3.3	3.1-3.4	1.0	ND-1.9	3.4	3.2-3.5	2013	2013	A naturally-occurring element found in ores and present in plants, animals and bacteria
Strontium (ppb)	NA	NA	703	660-750	520	470-570	723	670-770	2013	2013	A naturally-occurring element
Vanadium (ppb) ⁱ	50	NA	See footnote f						2013	2013	A naturally-occurring elemental metal
Additional Constituents (Unregulated)			Lake Casitas Treated		Mira Monte Well		Distribution System		Year Tested		SOURCE OF CONSTITUENT
		PHG (NL)	AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE	Lake	Well ^g	
Alkalinity Total as CaCO3 (ppm)	NA	NA	130	NA	150	NA	NA	NA	2018	2016	A measure of the capacity to neutralize acid
pH(units)	6.5-8.5 US EPA	NA	7.8	NA	6.7	NA	NA	NA	2018	2016	A measure of acidity or alkalinity
Bicarbonate Alkalinity HCO3 (ppm)	NA	NA	160	NA	180	NA	NA	NA	2018	2016	A measure of the capacity to neutralize acid
Boron (ppb)	NA	(1000)	200	NA	ND	NA	NA	NA	2018	2016	A naturally-occurring element
Calcium (ppm)	NA	NA	52	NA	47	NA	NA	NA	2018	2016	A naturally-occurring element
Magnesium (ppm)	NA	NA	25	NA	14	NA	NA	NA	2018	2016	A naturally-occurring element
Potassium (ppm)	NA	NA	3	NA	ND	NA	NA	NA	2018	2016	A naturally-occurring element
Total Hardness (ppm)	NA	NA	233 (13.6 grains/gal)	NA	175	NA	NA	NA	2018	2016	"Hardness" is the sum of polyvalent cations present in the water, generally magnesium and calcium. The cations are usually naturally occurring.
Sodium (ppm)	NA	NA	30	NA	50	NA	NA	NA	2018	2016	"Sodium" refers to the salt present in the water and is generally naturally occurring.

Abbreviations and Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the taste and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Maximum Residual Disinfectant Level (MRDL): MCLs for disinfectants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Notification Level: Health based advisory levels established by the State Board for chemicals in drinking water that lack MCLs.

NA - Not Applicable

ND - None Detected

NL - Notification Level

NS - No Sample

NTU - Nephelometric Turbidity Units (a measure of turbidity)

pc/L: Picoocuries per liter (a measure of radiation)

ppm - Parts per million, or milligrams per liter (mg/L)

ppb - Parts per billion, or micrograms per liter (ug/L)

ppt - Parts per trillion or nanograms per liter (ng/L)

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Regulatory Action Level (RAL): The concentration of a contaminant in drinking water which, if exceeded, triggers treatment or other requirements which a water system must follow.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

UCMR 3: Unregulated Monitoring Contaminant Rule (Third round): This monitoring helps the EPA and the State Board determine where certain contaminants occur and whether the contaminants need to be regulated.

uS/cm: Micro Siemens per Centimeter (a measure of specific conductance)

Water Quality Table Footnotes:

a) Turbidity is a measure of the cloudiness of water and is a good measure of water quality and filtration performance; 100% of the samples tested for turbidity were below the required TT level of 0.2 NTU

and 100% is the lowest monthly percentage of samples meeting the turbidity limits.

b) During 2018 Casitas collected 156 samples for total coliform bacteria testing according to the Total Coliform Rule. Total Coliform bacteria were not detected in any of these samples.

c) Mira Monte Well can be above the MCL for nitrate, however the well water is blended with lake Casitas water with the resulting nitrate level averaging 0.8 ppm as nitrogen.

d) The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

e) Casitas has implemented a corrosion control plan by adding a small amount of phosphate to the water to lower corrosivity and reduce copper levels.

f) These results are below the detection limits for reporting and can only be used as an estimate. For vanadium sampling the highest level (in ppb) for the lake was 1.2 (ND for 2014), the well was 0.78 and 1.2 for the distribution system.

Vanadium results of the treated water for 2018 were ND.

g) During 2018 the treated treatment plant influent had negative results for monthly testing of Giardia and Cryptosporidium.

h) Distribution system measurements taken with field kits (not certified laboratory results).

Ventura River Water District

Analytical Results By FGL - 2018

LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Lead		ug/L	0	15	0.2			3.1	22
11078 Rodeo Dr.	SP 1607324-17	ug/L				2016-06-28	ND		
11551 N. Oakcrest Ave.	SP 1607324-2	ug/L				2016-06-28	ND		
1210 Woodland Ave.	SP 1607324-12	ug/L				2016-06-28	ND		
1211 Avila Dr.	SP 1607324-25	ug/L				2016-06-28	ND		
172 Burnham Rd.	SP 1607324-20	ug/L				2016-06-28	ND		
1991 Country Pl.	SP 1607324-8	ug/L				2016-06-28	ND		
209 Carillo Rd.	SP 1607324-19	ug/L				2016-06-28	ND		
2131 Burnham Rd.	SP 1607324-23	ug/L				2016-06-28	ND		
2187 Woodland Ave.	SP 1607324-1	ug/L				2016-06-28	ND		
2235 Los Encinos Rd.	SP 1607324-11	ug/L				2016-06-28	ND		
2256 Los Encinos Rd.	SP 1607324-10	ug/L				2016-06-28	ND		
365 Burnham Rd.	SP 1607324-9	ug/L				2016-06-28	ND		
400 Burnham Rd.	SP 1607324-21	ug/L				2016-06-28	ND		
45 Almond Ave.	SP 1611582-1	ug/L				2016-09-29	ND		
45 Almond Ave.	SP 1607324-13	ug/L				2016-06-28	24.7		
478 Burnham Rd.	SP 1607324-22	ug/L				2016-06-28	ND		
56 Grapevine Rd.	SP 1607324-14	ug/L				2016-06-28	ND		
573 E. Katherine Ave.	SP 1607324-15	ug/L				2016-06-28	ND		
617 Country Dr.	SP 1607324-3	ug/L				2016-06-28	ND		
640 Holly	SP 1607324-5	ug/L				2016-06-28	ND		
80 Pathelen Ave.	SP 1607324-16	ug/L				2016-06-28	5.6		
98 Wormwood St.	SP 1607324-7	ug/L				2016-06-28	ND		
Copper		mg/L		1.3	.3			0.54	22
11078 Rodeo Dr.	SP 1607324-17	mg/L				2016-06-28	0.17		
11551 N. Oakcrest Ave.	SP 1607324-2	mg/L				2016-06-28	0.06		
1210 Woodland Ave.	SP 1607324-12	mg/L				2016-06-28	0.08		
1211 Avila Dr.	SP 1607324-25	mg/L				2016-06-28	0.09		
172 Burnham Rd.	SP 1607324-20	mg/L				2016-06-28	0.41		
1991 Country Pl.	SP 1607324-8	mg/L				2016-06-28	0.14		
209 Carillo Rd.	SP 1607324-19	mg/L				2016-06-28	0.17		
2131 Burnham Rd.	SP 1607324-23	mg/L				2016-06-28	0.57		
2187 Woodland Ave.	SP 1607324-1	mg/L				2016-06-28	0.10		
2235 Los Encinos Rd.	SP 1607324-11	mg/L				2016-06-28	0.35		
2256 Los Encinos Rd.	SP 1607324-10	mg/L				2016-06-28	0.54		
365 Burnham Rd.	SP 1607324-9	mg/L				2016-06-28	0.13		
400 Burnham Rd.	SP 1607324-21	mg/L				2016-06-28	0.09		
45 Almond Ave.	SP 1611582-1	mg/L				2016-09-29	0.12		
45 Almond Ave.	SP 1607324-13	mg/L				2016-06-28	0.13		
478 Burnham Rd.	SP 1607324-22	mg/L				2016-06-28	0.73		
56 Grapevine Rd.	SP 1607324-14	mg/L				2016-06-28	0.86		
573 E. Katherine Ave.	SP 1607324-15	mg/L				2016-06-28	0.32		
617 Country Dr.	SP 1607324-3	mg/L				2016-06-28	0.14		
640 Holly	SP 1607324-5	mg/L				2016-06-28	0.13		
80 Pathelen Ave.	SP 1607324-16	mg/L				2016-06-28	0.10		
98 Wormwood St.	SP 1607324-7	mg/L				2016-06-28	0.13		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			44	38 - 49
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	44		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	49		

Well 02	SP 1405147-1	mg/L				2014-05-06	45		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	38		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	40		
Well 07 (New)	SP 1611959-1	mg/L				2016-10-07	48		
Hardness		mg/L		none	none			396	371 - 419
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	395		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	403		
Well 02	SP 1405147-1	mg/L				2014-05-06	409		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	378		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	371		
Well 07 (New)	SP 1611959-1	mg/L				2016-10-07	419		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Aluminum		mg/L		1	0.6			ND	ND - 0.06
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	ND		
Well 02	SP 1405147-1	mg/L				2014-05-06	ND		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	ND		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	ND		
Well 07 (New)	SP 1611959-1	mg/L				2016-10-07	0.06		
Fluoride		mg/L		2	1			0.4	ND - 0.5
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	0.5		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	0.5		
Well 02	SP 1405147-1	mg/L				2014-05-06	ND		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	0.4		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	0.5		
Well 07 (New)	SP 1611959-1	mg/L				2016-10-07	0.5		
Nitrate as N		mg/L		10	10			3.7	1.15 - 6.7
Well 01 (1989)	SP 1816774-1	mg/L				2018-12-18	2.1		
Well 01 (1989)	SP 1814748-1	mg/L				2018-11-06	4.0		
Well 01 (1989)	SP 1813160-1	mg/L				2018-10-02	3.4		
Well 01 (1989)	SP 1811704-1	mg/L				2018-09-04	2.7		
Well 01 (1989)	SP 1810613-1	mg/L				2018-08-14	2.5		
Well 01 (1989)	SP 1808934-1	mg/L				2018-07-10	2.4		
Well 01 (1989)	SP 1807663-1	mg/L				2018-06-12	2.1		
Well 01 (1989)	SP 1806123-1	mg/L				2018-05-08	2.4		
Well 01 (1989)	SP 1804434-1	mg/L				2018-04-03	2.8		
Well 01 (1989)	SP 1802968-1	mg/L				2018-03-06	3.4		
Well 01 (1989)	SP 1802249-1	mg/L				2018-02-20	3.4		
Well 01 (1989)	SP 1801885-1	mg/L				2018-02-13	3.2		
Well 01 (1989)	SP 1800024-1	mg/L				2018-01-02	3.1		
Well 02	SP 1406653-1	mg/L				2014-06-10	2.60		
Well 02	SP 1405147-1	mg/L				2014-05-06	1.15		
Well 03 - Active	SP 1814748-2	mg/L				2018-11-06	6.7		
Well 03 - Active	SP 1813160-2	mg/L				2018-10-02	6.4		
Well 03 - Active	SP 1811704-2	mg/L				2018-09-04	5.9		
Well 03 - Active	SP 1810613-2	mg/L				2018-08-14	6.1		
Well 03 - Active	SP 1808934-2	mg/L				2018-07-10	5.8		
Well 03 - Active	SP 1807663-2	mg/L				2018-06-12	6.1		
Well 03 - Active	SP 1806123-2	mg/L				2018-05-08	4.9		
Well 03 - Active	SP 1804434-2	mg/L				2018-04-03	5.4		
Well 03 - Active	SP 1803752-1	mg/L				2018-03-20	5.5		
Well 03 - Active	SP 1802968-2	mg/L				2018-03-06	5.5		
Well 03 - Active	SP 1801885-2	mg/L				2018-02-13	5.2		
Well 03 - Active	SP 1800024-2	mg/L				2018-01-02	4.3		
Well 04 (2007)	SP 1810613-3	mg/L				2018-08-14	2.8		
Well 04 (2007)	SP 1808934-3	mg/L				2018-07-10	3.0		
Well 04 (2007)	SP 1807663-3	mg/L				2018-06-12	2.3		
Well 04 (2007)	SP 1806123-3	mg/L				2018-05-08	2.5		

Well 04 (2007)	SP 1804434-3	mg/L				2018-04-03	3.1		
Well 04 (2007)	SP 1803750-1	mg/L				2018-03-20	3.7		
Well 04 (2007)	SP 1802968-3	mg/L				2018-03-06	3.8		
Well 04 (2007)	SP 1801885-3	mg/L				2018-02-13	3.5		
Well 04 (2007)	SP 1800024-3	mg/L				2018-01-02	3.3		
Well 07 (New)	SP 1816774-3	mg/L				2018-12-18	1.8		
Well 07 (New)	SP 1814748-3	mg/L				2018-11-06	2.6		
Well 07 (New)	SP 1813160-3	mg/L				2018-10-02	2.4		
Well 07 (New)	SP 1811704-3	mg/L				2018-09-04	2.2		
Nitrate + Nitrite as N		mg/L		10	10			2.1	1.2 - 4.2
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	1.7		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	1.6		
Well 02	SP 1405147-1	mg/L				2014-05-06	1.2		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	2.3		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	1.6		
Well 07 (New)	SP 1611959-1	mg/L				2016-10-07	4.2		
Gross Alpha		pCi/L		15	(0)			1.281	ND - 3.43
Well 01 (1989)	SP 1305549-1	pCi/L				2013-06-04	1.62		
Well 01 (1989)	SP 1302830-1	pCi/L				2013-03-19	1.29		
Well 02	SP 1105600-1	pCi/L				2011-06-07	ND		
Well 02	SP 1102665-1	pCi/L				2011-03-15	ND		
Well 03 - Active	SP 1305552-1	pCi/L				2013-06-04	2.51		
Well 03 - Active	SP 1302833-1	pCi/L				2013-03-19	1.27		
Well 04 (2007)	SP 1005996-1	pCi/L				2010-06-22	ND		
Well 04 (2007)	SP 1001299-1	pCi/L				2010-02-09	1.41		
Well 07 (New)	SP 1611959-1	pCi/L				2016-10-07	3.43		

TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Nitrate as N		mg/L		10	10			3.2	2.5 - 3.7
Baldwin Tank #2 - NO3 BLEND	SP 1816774-4	mg/L				2018-12-18	2.5		
Baldwin Tank #2 - NO3 BLEND	SP 1814748-4	mg/L				2018-11-06	3.7		
Baldwin Tank #2 - NO3 BLEND	SP 1813160-4	mg/L				2018-10-02	3.4		
Baldwin Tank #2 - NO3 BLEND	SP 1811704-4	mg/L				2018-09-04	3.1		
Baldwin Tank #2 - NO3 BLEND	SP 1810613-4	mg/L				2018-08-14	3.1		

SECONDARY DRINKING WATER STANDARDS (SDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride		mg/L		500	n/a			44	28 - 57
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	47		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	53		
Well 02	SP 1405147-1	mg/L				2014-05-06	41		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	28		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	40		
Well 07 (New)	SP 1611959-1	mg/L				2016-10-07	57		
Iron		ug/L		300	n/a			ND	ND - 100
Well 01 (1989)	SP 1702592-1	ug/L				2017-02-28	ND		
Well 01 (1989)	SP 1701637-1	ug/L				2017-02-07	ND		
Well 02	SP 1405147-1	ug/L				2014-05-06	100		
Well 03 - Active	SP 1702589-1	ug/L				2017-02-28	ND		
Well 04 (2007)	SP 1702840-1	ug/L				2017-03-07	ND		
Well 07 (New)	SP 1611959-1	ug/L				2016-10-07	ND		
Specific Conductance		umhos/cm		1600	n/a			959	888 - 1020
Well 01 (1989)	SP 1702592-1	umhos/cm				2017-02-28	1000		
Well 01 (1989)	SP 1701637-1	umhos/cm				2017-02-07	1000		
Well 02	SP 1405147-1	umhos/cm				2014-05-06	914		
Well 03 - Active	SP 1702589-1	umhos/cm				2017-02-28	888		
Well 04 (2007)	SP 1702840-1	umhos/cm				2017-03-07	932		

Well 07 (New)	SP 1611959-1	umhos/cm				2016-10-07	1020		
Sulfate		mg/L		500	n/a			216	177 - 241
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	225		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	218		
Well 02	SP 1405147-1	mg/L				2014-05-06	241		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	177		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	224		
Well 07 (New)	SP 1611959-1	mg/L				2016-10-07	209		
Total Dissolved Solids		mg/L		1000	n/a			657	590 - 720
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	660		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	690		
Well 02	SP 1405147-1	mg/L				2014-05-06	630		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	590		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	650		
Well 07 (New)	SP 1611959-1	mg/L				2016-10-07	720		
Turbidity		NTU		5	n/a			0.7	ND - 1.3
Well 01 (1989)	SP 1701637-1	NTU				2017-02-07	0.8		
Well 02	SP 1405147-1	NTU				2014-05-06	ND		
Well 03 - Active	SP 1702589-1	NTU				2017-02-28	0.5		
Well 04 (2007)	SP 1702840-1	NTU				2017-03-07	1.3		
Well 07 (New)	SP 1611959-1	NTU				2016-10-07	0.7		

UNREGULATED CONTAMINANTS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			0.6	0.5 - 0.7
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	0.6		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	0.7		
Well 02	SP 1405147-1	mg/L				2014-05-06	0.6		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	0.5		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	0.6		
Well 07 (New)	SP 1611959-1	mg/L				2016-10-07	0.5		

ADDITIONAL DETECTIONS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			111	106 - 116
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	112		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	112		
Well 02	SP 1405147-1	mg/L				2014-05-06	116		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	107		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	106		
Well 07 (New)	SP 1611959-1	mg/L				2016-10-07	115		
Magnesium		mg/L			n/a			29	26 - 32
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	28		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	30		
Well 02	SP 1405147-1	mg/L				2014-05-06	29		
Well 03 - Active	SP 1702589-1	mg/L				2017-02-28	27		
Well 04 (2007)	SP 1702840-1	mg/L				2017-03-07	26		
Well 07 (New)	SP 1611959-1	mg/L				2016-10-07	32		
pH		units			n/a			7.4	6.7 - 7.8
Well 01 (1989)	SP 1702592-1	units				2017-02-28	7.8		
Well 01 (1989)	SP 1701637-1	units				2017-02-07	7.2		
Well 02	SP 1405147-1	units				2014-05-06	7.7		
Well 03 - Active	SP 1702589-1	units				2017-02-28	7.8		
Well 04 (2007)	SP 1702840-1	units				2017-03-07	7.4		
Well 07 (New)	SP 1611959-1	units				2016-10-07	6.7		
Alkalinity		mg/L			n/a			218	180 - 260
Well 01 (1989)	SP 1702592-1	mg/L				2017-02-28	220		
Well 01 (1989)	SP 1701637-1	mg/L				2017-02-07	210		

Well 02	SP 1405147-1	mg/L			2014-05-06	180		
Well 03 - Active	SP 1702589-1	mg/L			2017-02-28	260		
Well 04 (2007)	SP 1702840-1	mg/L			2017-03-07	210		
Well 07 (New)	SP 1611959-1	mg/L			2016-10-07	230		
Aggressiveness Index					n/a		12.2	11.5 - 12.6
Well 01 (1989)	SP 1702592-1				2017-02-28	12.6		
Well 01 (1989)	SP 1701637-1				2017-02-07	12.0		
Well 02	SP 1405147-1				2014-05-06	12.4		
Well 03 - Active	SP 1702589-1				2017-02-28	12.6		
Well 04 (2007)	SP 1702840-1				2017-03-07	12.1		
Well 07 (New)	SP 1611959-1				2016-10-07	11.5		
Langelier Index					n/a		0.33	-0.4 - 0.8
Well 01 (1989)	SP 1702592-1				2017-02-28	0.7		
Well 01 (1989)	SP 1701637-1				2017-02-07	0.08		
Well 02	SP 1405147-1				2014-05-06	0.5		
Well 03 - Active	SP 1702589-1				2017-02-28	0.8		
Well 04 (2007)	SP 1702840-1				2017-03-07	0.3		
Well 07 (New)	SP 1611959-1				2016-10-07	-0.4		

DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Total Trihalomethanes (TTHMs)		ug/L		80	n/a			62	4 - 75
175 Rio Via - Stage 2 DBP	SP 1817113-1	ug/L				2018-12-26	75		
175 Rio Via - Stage 2 DBP	SP 1812860-1	ug/L				2018-09-25	51		
175 Rio Via - Stage 2 DBP	SP 1807331-1	ug/L				2018-06-05	56		
175 Rio Via - Stage 2 DBP	SP 1802969-1	ug/L				2018-03-06	66		
Average 175 Rio Via - Stage 2 DBP								62	
202 Valle Rio - Stage 2 DBP	SP 1817113-2	ug/L				2018-12-26	4		
202 Valle Rio - Stage 2 DBP	SP 1812860-2	ug/L				2018-09-25	6		
202 Valle Rio - Stage 2 DBP	SP 1807331-2	ug/L				2018-06-05	5		
202 Valle Rio - Stage 2 DBP	SP 1802969-2	ug/L				2018-03-06	6		
Average 202 Valle Rio - Stage 2 DBP								5.25	
Chlorine		mg/L		4.0	4.0			3.39	.8 - 3.5
175 Rio Via	SP 1817110-1	mg/L				2018-12-26	3.0		
175 Rio Via	SP 1815392-1	mg/L				2018-11-20	2.6		
175 Rio Via	SP 1813488-1	mg/L				2018-10-09	2.5		
175 Rio Via	SP 1811703-1	mg/L				2018-09-04	3.0		
175 Rio Via	SP 1804443-1	mg/L				2018-04-03	2.8		
175 Rio Via	SP 1802628-1	mg/L				2018-02-27	3.0		
Average 175 Rio Via								2.82	
175 RIO VIA - STAGE 2 DBP	SP 1809732-1	mg/L				2018-07-24	3.0		
175 RIO VIA - STAGE 2 DBP	SP 1808012-1	mg/L				2018-06-19	3.0		
175 RIO VIA - STAGE 2 DBP	SP 1806126-1	mg/L				2018-05-08	3.0		
175 RIO VIA - STAGE 2 DBP	SP 1800613-1	mg/L				2018-01-16	3.0		
Average 175 RIO VIA - STAGE 2 DBP								3	
2096 Sumac Dr. - Book 9B	SP 1805764-1	mg/L				2018-05-01	.8		
Average 2096 Sumac Dr. - Book 9B								0.8	
595 Riverside Rd. - Book 7	SP 1805764-2	mg/L				2018-05-01	.8		
Average 595 Riverside Rd. - Book 7								0.8	
9148 Nye Rd. - Book 14	SP 1816019-1	mg/L				2018-12-04	3.0		
9148 Nye Rd. - Book 14	SP 1814130-1	mg/L				2018-10-23	3.5		
9148 Nye Rd. - Book 14	SP 1812518-1	mg/L				2018-09-18	3.5		
9148 Nye Rd. - Book 14	SP 1810295-1	mg/L				2018-08-07	3.5		
9148 Nye Rd. - Book 14	SP 1808732-1	mg/L				2018-07-03	3.0		
9148 Nye Rd. - Book 14	SP 1806787-1	mg/L				2018-05-22	3.5		
9148 Nye Rd. - Book 14	SP 1805148-1	mg/L				2018-04-17	3.5		
9148 Nye Rd. - Book 14	SP 1803356-1	mg/L				2018-03-13	3.5		

Ventura River Water District

CCR Login Linkage - 2018

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
SS - 1A	SP 1800023-1	2018-01-02	Coliform	1042 Moreno Dr. - Book 1A	Week 1 System Monitoring
	SP 1801886-1	2018-02-13	Coliform	1042 Moreno Dr. - Book 1A	Week 2 System Monitoring
	SP 1803751-1	2018-03-20	Coliform	1042 Moreno Dr. - Book 1A	Week 3 System Monitoring
	SP 1805462-1	2018-04-24	Coliform	1042 Moreno Dr. - Book 1A	Week 4 System Monitoring
	SP 1816422-1	2018-12-11	Coliform	1042 Moreno Dr. - Book 1A	Week 2 System Monitoring
1092 Moremo Dr	SP 1812864-1	2018-09-25	Coliform	1092 Moremo Dr	Week 4 System Monitoring
1092 Moreno Dr	SP 1807351-1	2018-06-05	Coliform	1092 Moreno Dr	Week 1 System Monitoring
	SP 1814747-1	2018-11-06	Coliform	1092 Moreno Dr	Week 1 System Monitoring
1092 Morroo Dr	SP 1808976-1	2018-07-10	Coliform	1092 Morroo Dr	Week 2 System Monitoring
	SP 1810614-1	2018-08-14	Coliform	1092 Morroo Dr	Week 3 System Monitoring
11078 Rodeo Dr.	SP 1607324-17	2016-06-28	Metals, Total	11078 Rodeo Dr.	Lead & Copper Monitoring
11551 N. Oakcre	SP 1607324-2	2016-06-28	Metals, Total	11551 N. Oakcrest Ave.	Lead & Copper Monitoring
1210 Woodland A	SP 1607324-12	2016-06-28	Metals, Total	1210 Woodland Ave.	Lead & Copper Monitoring
1211 Avila Dr.	SP 1607324-25	2016-06-28	Metals, Total	1211 Avila Dr.	Lead & Copper Monitoring
172 Burnham Rd.	SP 1607324-20	2016-06-28	Metals, Total	172 Burnham Rd.	Lead & Copper Monitoring
SS - Wk4	SP 1802628-1	2018-02-27	Coliform	175 Rio Via	Week 4 System Monitoring
	SP 1802628-1	2018-02-27	Field Test	175 Rio Via	Week 4 System Monitoring
	SP 1804443-1	2018-04-03	Field Test	175 Rio Via	Week 1 System Monitoring
	SP 1804443-1	2018-04-03	Coliform	175 Rio Via	Week 1 System Monitoring
	SP 1811703-1	2018-09-04	Coliform	175 Rio Via	Week 1 System Monitoring
	SP 1811703-1	2018-09-04	Field Test	175 Rio Via	Week 1 System Monitoring
	SP 1813488-1	2018-10-09	Field Test	175 Rio Via	Week 2 System Monitoring
	SP 1813488-1	2018-10-09	Coliform	175 Rio Via	Week 2 System Monitoring
	SP 1815392-1	2018-11-20	Coliform	175 Rio Via	Week 3 System Monitoring
	SP 1815392-1	2018-11-20	Field Test	175 Rio Via	Week 3 System Monitoring
	SP 1817110-1	2018-12-26	Coliform	175 Rio Via	Week 4 System Monitoring
	SP 1817110-1	2018-12-26	Field Test	175 Rio Via	Week 4 System Monitoring
DBP 175RioVia	SP 1800613-1	2018-01-16	Coliform	175 RIO VIA - STAGE 2 DBP	Week 3 System Monitoring
	SP 1800613-1	2018-01-16	Field Test	175 RIO VIA - STAGE 2 DBP	Week 3 System Monitoring
	SP 1802969-1	2018-03-06	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1802969-1	2018-03-06	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1806126-1	2018-05-08	Field Test	175 RIO VIA - STAGE 2 DBP	Week 2 System Monitoring
	SP 1806126-1	2018-05-08	Coliform	175 RIO VIA - STAGE 2 DBP	Week 2 System Monitoring
	SP 1807331-1	2018-06-05	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1807331-1	2018-06-05	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1808012-1	2018-06-19	Field Test	175 RIO VIA - STAGE 2 DBP	Week 3 System Monitoring
	SP 1808012-1	2018-06-19	Coliform	175 RIO VIA - STAGE 2 DBP	Week 3 System Monitoring
	SP 1809732-1	2018-07-24	Coliform	175 RIO VIA - STAGE 2 DBP	Week 4 System Monitoring
	SP 1809732-1	2018-07-24	Field Test	175 RIO VIA - STAGE 2 DBP	Week 4 System Monitoring
	SP 1812520-1	2018-09-18	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1812860-1	2018-09-25	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1817113-1	2018-12-26	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1817113-1	2018-12-26	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
1991 Country Pl	SP 1607324-8	2016-06-28	Metals, Total	1991 Country Pl.	Lead & Copper Monitoring
DBP 202ValleRio	SP 1802969-2	2018-03-06	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1802969-2	2018-03-06	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1805462-2	2018-04-24	Coliform	202 VALLE RIO - STAGE 2 DBP	Week 4 System Monitoring
	SP 1807331-2	2018-06-05	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1807331-2	2018-06-05	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1807351-2	2018-06-05	Coliform	202 VALLE RIO - STAGE 2 DBP	Week 1 System Monitoring
	SP 1812520-2	2018-09-18	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1812860-2	2018-09-25	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1817113-2	2018-12-26	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 1817113-2	2018-12-26	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
SS - 10A	SP 1800023-2	2018-01-02	Coliform	202 Valle Rio Ave. - Book 10A	Week 1 System Monitoring

	SP 1801886-2	2018-02-13	Coliform	202 Valle Rio Ave. - Book 10A	Week 2 System Monitoring
	SP 1803751-2	2018-03-20	Coliform	202 Valle Rio Ave. - Book 10A	Week 3 System Monitoring
	SP 1808976-2	2018-07-10	Coliform	202 Valle Rio Ave. - Book 10A	Week 2 System Monitoring
	SP 1810614-2	2018-08-14	Coliform	202 Valle Rio Ave. - Book 10A	Week 3 System Monitoring
	SP 1812864-2	2018-09-25	Coliform	202 Valle Rio Ave. - Book 10A	Week 4 System Monitoring
	SP 1814747-2	2018-11-06	Coliform	202 Valle Rio Ave. - Book 10A	Week 1 System Monitoring
	SP 1816422-2	2018-12-11	Coliform	202 Valle Rio Ave. - Book 10A	Week 2 System Monitoring
209 Carillo Rd.	SP 1607324-19	2016-06-28	Metals, Total	209 Carillo Rd.	Lead & Copper Monitoring
SS - 9B	SP 1800337-1	2018-01-10	Coliform	2096 Sumac Dr. - Book 9B	Week 2 System Monitoring
	SP 1802248-1	2018-02-20	Coliform	2096 Sumac Dr. - Book 9B	Week 3 System Monitoring
	SP 1804072-1	2018-03-27	Coliform	2096 Sumac Dr. - Book 9B	Week 4 System Monitoring
	SP 1805764-1	2018-05-01	Coliform	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
	SP 1805764-1	2018-05-01	Field Test	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
	SP 1809370-1	2018-07-17	Coliform	2096 Sumac Dr. - Book 9B	Week 3 System Monitoring
	SP 1810956-1	2018-08-22	Coliform	2096 Sumac Dr. - Book 9B	Week 4 System Monitoring
	SP 1813180-1	2018-10-02	Coliform	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
	SP 1815037-1	2018-11-13	Coliform	2096 Sumac Dr. - Book 9B	Week 2 System Monitoring
	SP 1816779-1	2018-12-18	Coliform	2096 Sumac Dr. - Book 9B	Week 3 System Monitoring
2131 Burnham Rd	SP 1607324-23	2016-06-28	Metals, Total	2131 Burnham Rd.	Lead & Copper Monitoring
2187 Woodland A	SP 1607324-1	2016-06-28	Metals, Total	2187 Woodland Ave.	Lead & Copper Monitoring
2235 Los Encino	SP 1607324-11	2016-06-28	Metals, Total	2235 Los Encinos Rd.	Lead & Copper Monitoring
2256 Los Encino	SP 1607324-10	2016-06-28	Metals, Total	2256 Los Encinos Rd.	Lead & Copper Monitoring
265 E Villanova	SP 1811703-2	2018-09-04	Coliform	265 E Villanova Rd	Week 1 System Monitoring
SS - 9A	SP 1800613-2	2018-01-16	Coliform	265 E. Villanova Rd. Book 9A	Week 3 System Monitoring
	SP 1802628-2	2018-02-27	Coliform	265 E. Villanova Rd. Book 9A	Week 4 System Monitoring
	SP 1804443-2	2018-04-03	Coliform	265 E. Villanova Rd. Book 9A	Week 1 System Monitoring
	SP 1806126-2	2018-05-08	Coliform	265 E. Villanova Rd. Book 9A	Week 2 System Monitoring
	SP 1808012-2	2018-06-19	Coliform	265 E. Villanova Rd. Book 9A	Week 3 System Monitoring
	SP 1809732-2	2018-07-24	Coliform	265 E. Villanova Rd. Book 9A	Week 4 System Monitoring
	SP 1813488-2	2018-10-09	Coliform	265 E. Villanova Rd. Book 9A	Week 2 System Monitoring
	SP 1815392-2	2018-11-20	Coliform	265 E. Villanova Rd. Book 9A	Week 3 System Monitoring
SS - 8	SP 1801551-2	2018-02-06	Coliform	290 Alto Dr. - Book 8	Week 1 System Monitoring
	SP 1803356-2	2018-03-13	Coliform	290 Alto Dr. - Book 8	Week 2 System Monitoring
	SP 1805148-2	2018-04-17	Coliform	290 Alto Dr. - Book 8	Week 3 System Monitoring
	SP 1806787-2	2018-05-22	Coliform	290 Alto Dr. - Book 8	Week 4 System Monitoring
	SP 1808732-2	2018-07-03	Coliform	290 Alto Dr. - Book 8	Week 1 System Monitoring
	SP 1810295-2	2018-08-07	Coliform	290 Alto Dr. - Book 8	Week 2 System Monitoring
	SP 1812518-2	2018-09-18	Coliform	290 Alto Dr. - Book 8	Week 3 System Monitoring
	SP 1814130-2	2018-10-23	Coliform	290 Alto Dr. - Book 8	Week 4 System Monitoring
	SP 1816019-2	2018-12-04	Coliform	290 Alto Dr. - Book 8	Week 1 System Monitoring
296 Sumac Dr	SP 1807662-1	2018-06-12	Coliform	296 Sumac Dr	Week 2 System Monitoring
365 Burnham Rd.	SP 1607324-9	2016-06-28	Metals, Total	365 Burnham Rd.	Lead & Copper Monitoring
365 E. Villanov	SP 1817110-2	2018-12-26	Coliform	365 E. Villanova	Week 4 System Monitoring
400 Burnham Rd.	SP 1607324-21	2016-06-28	Metals, Total	400 Burnham Rd.	Lead & Copper Monitoring
45 Almond Ave.	SP 1607324-13	2016-06-28	Metals, Total	45 Almond Ave.	Lead & Copper Monitoring
45 Almond Ave	SP 1611582-1	2016-09-29	Metals, Total	45 Almond Ave.	CU & PB-Resample
478 Burnham Rd.	SP 1607324-22	2016-06-28	Metals, Total	478 Burnham Rd.	Lead & Copper Monitoring
56 Grapevine Rd	SP 1607324-14	2016-06-28	Metals, Total	56 Grapevine Rd.	Lead & Copper Monitoring
573 E. Katherin	SP 1607324-15	2016-06-28	Metals, Total	573 E. Katherine Ave.	Lead & Copper Monitoring
SS - 7	SP 1800337-2	2018-01-10	Coliform	595 Riverside Rd. - Book 7	Week 2 System Monitoring
	SP 1802248-2	2018-02-20	Coliform	595 Riverside Rd. - Book 7	Week 3 System Monitoring
	SP 1804072-2	2018-03-27	Coliform	595 Riverside Rd. - Book 7	Week 4 System Monitoring
	SP 1805764-2	2018-05-01	Coliform	595 Riverside Rd. - Book 7	Week 1 System Monitoring
	SP 1805764-2	2018-05-01	Field Test	595 Riverside Rd. - Book 7	Week 1 System Monitoring
	SP 1807662-2	2018-06-12	Coliform	595 Riverside Rd. - Book 7	Week 2 System Monitoring
	SP 1809370-2	2018-07-17	Coliform	595 Riverside Rd. - Book 7	Week 3 System Monitoring
	SP 1810956-2	2018-08-22	Coliform	595 Riverside Rd. - Book 7	Week 4 System Monitoring
	SP 1813180-2	2018-10-02	Coliform	595 Riverside Rd. - Book 7	Week 1 System Monitoring
	SP 1815037-2	2018-11-13	Coliform	595 Riverside Rd. - Book 7	Week 2 System Monitoring
	SP 1816779-2	2018-12-18	Coliform	595 Riverside Rd. - Book 7	Week 3 System Monitoring

617 Country Dr.	SP 1607324-3	2016-06-28	Metals, Total	617 Country Dr.	Lead & Copper Monitoring
640 Holly	SP 1607324-5	2016-06-28	Metals, Total	640 Holly	Lead & Copper Monitoring
SS - 5A	SP 1801015-2	2018-01-23	Coliform	72 Catalina Dr.	Week 4 System Monitoring
	SP 1802967-2	2018-03-06	Coliform	72 Catalina Dr.	Week 1 System Monitoring
	SP 1804762-2	2018-04-10	Coliform	72 Catalina Dr.	Week 2 System Monitoring
	SP 1806448-2	2018-05-15	Coliform	72 Catalina Dr.	Week 3 System Monitoring
	SP 1808435-2	2018-06-26	Coliform	72 Catalina Dr.	Week 4 System Monitoring
	SP 1809999-2	2018-07-31	Coliform	72 Catalina Dr.	Week 1 System Monitoring
	SP 1812106-2	2018-09-11	Coliform	72 Catalina Dr.	Week 2 System Monitoring
	SP 1813815-2	2018-10-16	Coliform	72 Catalina Dr.	Week 3 System Monitoring
	SP 1815638-2	2018-11-27	Coliform	72 Catalina Dr.	Week 4 System Monitoring
80 Pathelen Ave	SP 1607324-16	2016-06-28	Metals, Total	80 Pathelen Ave.	Lead & Copper Monitoring
85 Almond AVE	SP 1801015-1	2018-01-23	Coliform	85 Almond Ave.	Week 4 System Monitoring
	SP 1802967-1	2018-03-06	Coliform	85 Almond Ave.	Week 1 System Monitoring
	SP 1804762-1	2018-04-10	Coliform	85 Almond Ave.	Week 2 System Monitoring
	SP 1806448-1	2018-05-15	Coliform	85 Almond Ave.	Week 3 System Monitoring
	SP 1808435-1	2018-06-26	Coliform	85 Almond Ave.	Week 4 System Monitoring
	SP 1809999-1	2018-07-31	Coliform	85 Almond Ave.	Week 1 System Monitoring
	SP 1812106-1	2018-09-11	Coliform	85 Almond Ave.	Week 2 System Monitoring
	SP 1813815-1	2018-10-16	Coliform	85 Almond Ave.	Week 3 System Monitoring
	SP 1815638-1	2018-11-27	Coliform	85 Almond Ave.	Week 4 System Monitoring
SS - 14	SP 1801551-1	2018-02-06	Coliform	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1801551-1	2018-02-06	Field Test	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1803356-1	2018-03-13	Field Test	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1803356-1	2018-03-13	Coliform	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1805148-1	2018-04-17	Coliform	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1805148-1	2018-04-17	Field Test	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1806787-1	2018-05-22	Field Test	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1806787-1	2018-05-22	Coliform	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1808732-1	2018-07-03	Coliform	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1808732-1	2018-07-03	Field Test	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1810295-1	2018-08-07	Coliform	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1810295-1	2018-08-07	Field Test	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 1812518-1	2018-09-18	Coliform	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1812518-1	2018-09-18	Field Test	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 1814130-1	2018-10-23	Coliform	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1814130-1	2018-10-23	Field Test	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 1816019-1	2018-12-04	Field Test	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 1816019-1	2018-12-04	Coliform	9148 Nye Rd. - Book 14	Week 1 System Monitoring
98 Wormwood St.	SP 1607324-7	2016-06-28	Metals, Total	98 Wormwood St.	Lead & Copper Monitoring
Baldwin Tank #1	SP 1814231-1	2018-10-25	Coliform	Baldwin Tank #1	Baldwin Tank #1
Bald Tnk 2	SP 1810613-4	2018-08-14	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
	SP 1811704-4	2018-09-04	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
	SP 1813160-4	2018-10-02	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
	SP 1814748-4	2018-11-06	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
	SP 1816774-4	2018-12-18	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
Well 01	SP 1302830-1	2013-03-19	Radio Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1305549-1	2013-06-04	Radio Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1700023-1	2017-01-03	Sampling	Well 01 (1989)	Nitrate Monitoring
	SP 1700023-1	2017-01-03	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1700241-1	2017-01-09	Sampling	Well 01 (1989)	Nitrate Monitoring
	SP 1701637-1	2017-02-07	General Mineral	Well 01 (1989)	Well 01 - Water Quality
	SP 1701637-1	2017-02-07	Metals, Total	Well 01 (1989)	Well 01 - Water Quality
	SP 1701637-1	2017-02-07	Wet Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1702592-1	2017-02-28	General Mineral	Well 01 (1989)	Well 01 - Water Quality
	SP 1800024-1	2018-01-02	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1801885-1	2018-02-13	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1802249-1	2018-02-20	Wet Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1802968-1	2018-03-06	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1804434-1	2018-04-03	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring

	SP 1806123-1	2018-05-08	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1807663-1	2018-06-12	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1808934-1	2018-07-10	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1810613-1	2018-08-14	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1811704-1	2018-09-04	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1813160-1	2018-10-02	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1814748-1	2018-11-06	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 1816774-1	2018-12-18	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
Well 02	SP 1102665-1	2011-03-15	Radio Chemistry	Well 02	Well 02 Title 22 Monitoring
	SP 1105600-1	2011-06-07	Radio Chemistry	Well 02	Well 02 Title 22 Monitoring
	SP 1405147-1	2014-05-06	Metals, Total	Well 02	Well 02 - Water Quality
	SP 1405147-1	2014-05-06	Wet Chemistry	Well 02	Well 02 - Water Quality
	SP 1405147-1	2014-05-06	General Mineral	Well 02	Well 02 - Water Quality
	SP 1406653-1	2014-06-10	Wet Chemistry	Well 02	Well 02 - Water Quality
Well 03	SP 1302833-1	2013-03-19	Radio Chemistry	Well 03 - Active	Well 03 - Radio Monitoring
	SP 1305552-1	2013-06-04	Radio Chemistry	Well 03 - Active	Well 03 - Radio Monitoring
	SP 1702589-1	2017-02-28	Wet Chemistry	Well 03 - Active	Well 03 - Water Quality
	SP 1702589-1	2017-02-28	General Mineral	Well 03 - Active	Well 03 - Water Quality
	SP 1702589-1	2017-02-28	Metals, Total	Well 03 - Active	Well 03 - Water Quality
	SP 1800024-2	2018-01-02	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1801885-2	2018-02-13	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1802968-2	2018-03-06	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1803752-1	2018-03-20	Wet Chemistry	Well 03 - Active	Well 03 - Water Quality
	SP 1804434-2	2018-04-03	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1806123-2	2018-05-08	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1807663-2	2018-06-12	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1808934-2	2018-07-10	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1810613-2	2018-08-14	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1811704-2	2018-09-04	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1813160-2	2018-10-02	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
	SP 1814748-2	2018-11-06	Wet Chemistry	Well 03 - Active	Nitrate Monitoring
Well 04	SP 1001299-1	2010-02-09	Radio Chemistry	Well 04 (2007)	Gross Alpha/Radium Well #4
	SP 1005996-1	2010-06-22	Radio Chemistry	Well 04 (2007)	Well #4 Radioactive/Radium
	SP 1702840-1	2017-03-07	General Mineral	Well 04 (2007)	Well 04 - Water Quality
	SP 1702840-1	2017-03-07	Wet Chemistry	Well 04 (2007)	Well 04 - Water Quality
	SP 1702840-1	2017-03-07	Metals, Total	Well 04 (2007)	Well 04 - Water Quality
	SP 1800024-3	2018-01-02	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1801885-3	2018-02-13	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1802968-3	2018-03-06	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1803750-1	2018-03-20	Wet Chemistry	Well 04 (2007)	Well 04 - Water Quality
	SP 1804434-3	2018-04-03	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1806123-3	2018-05-08	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1807663-3	2018-06-12	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1808934-3	2018-07-10	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
	SP 1810613-3	2018-08-14	Wet Chemistry	Well 04 (2007)	Nitrate Monitoring
New WELL 07	SP 1611959-1	2016-10-07	General Mineral	Well 07 (New)	Well 7 - Title 22
	SP 1611959-1	2016-10-07		Well 07 (New)	Well 7 - Title 22
	SP 1611959-1	2016-10-07	Metals, Total	Well 07 (New)	Well 7 - Title 22
	SP 1611959-1	2016-10-07	Wet Chemistry	Well 07 (New)	Well 7 - Title 22
	SP 1611959-1	2016-10-07	Radio Chemistry	Well 07 (New)	Well 7 - Title 22
Well 07 New	SP 1811704-3	2018-09-04	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 1813160-3	2018-10-02	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 1814748-3	2018-11-06	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 1816774-3	2018-12-18	Wet Chemistry	Well 07 (New)	Nitrate Monitoring