


Consumer Confidence Report Certification Form

(to be submitted with a copy of the CCR)

(to certify electronic delivery of the CCR, use the certification form on the State Water Board's website at http://www.swrcb.ca.gov/drinking_water/certlic/drinkingwater/CCR.shtml)

Water System Name:	VENTURA RIVER WATER DISTRICT
Water System Number:	5610022

The water system named above hereby certifies that its Consumer Confidence Report was distributed on _____ (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the State Water Resources Control Board, Division of Drinking Water.

Certified By:	Name:	Bert J. Rapp	
	Signature:		
	Title:	General Manager	
	Phone Number:	(805) 646-3403	Date: May 21, 2021

To summarize report delivery used and good-faith efforts taken, please complete the form below by checking all items that apply and fill-in where appropriate:

CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used:

"Good faith" efforts were used to reach non-bill paying customers. Those efforts included the following methods:

- Posted the CCR on the internet at <http://www.VenturaRiverWD.com>
- Mailed the CCR to postal patrons within the service area (attach zip codes used)
- Advertised the availability of the CCR in news media (attach a copy of press release)
- Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of the newspaper and date published)
- Posted the CCR in public places (attach a list of locations)
- Delivery of multiple copies of CCR to single bill addresses serving several persons, such as apartments, businesses, and schools
- Delivery to community organizations (attach a list of organizations)
- Other (attach a list of other methods used)

For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: <http://>_____

For investor-owned utilities: Delivered the CCR to the California Public Utilities Commission

(This form is provided as a convenience and may be used to meet the certification requirement of section 64483(c), California Code of Regulations.)

2020 Consumer Confidence Report

Water System Name: VENTURA RIVER WATER DISTRICT Report Date: March 2021

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: This Sources Well 01, Well 02, Well 03, Well 04, Well 06 and Well 7 are Groundwater. Please see the Drinking Water Source Assessment Information section located at the end of this report for more details.

Your water comes from 6 source(s): Well 01 (1989), Well 02, Well 03, Well 04 (2007), Well 06 and Well 07 (New) **and from 2 treated location(s):** Baldwin Tank #2 and Baldwin Tank #2 - NO3 BLEND

Opportunities for public participation in decisions that affect drinking water quality: Regularly-scheduled Water District Board meetings held on the third Wednesday of the month at 3:00 p.m. at 409 Old Baldwin Road.

For more information about this report, or any questions relating to your drinking water, please call 8056463403 and ask for Bert Rapp or email Bert@VenturaRiverWD.com or visit our website at www.VenturaRiverWD.com.

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for the contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for the contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

mg/L: milligrams per liter or parts per million (ppm)

ug/L: micrograms per liter or parts per billion (ppb)

pCi/L: picocuries per liter (a measure of radiation)

NTU: Nephelometric Turbidity Units

umhos/cm: micro mhos per centimeter

The sources of drinking water: (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resource Control Board (State Water Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Water Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, 6, 7 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Water Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Table 1 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER							
Lead and Copper (complete if lead or copper detected in last sample set)	Sample Date	No. of Samples	90th percentile level detected	No. Sites Exceeding AL	AL	PHG	Typical Sources of Contaminant
Copper (mg/L)	(2019)	20	0.22	0	1.3	.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Table 2 - SAMPLING RESULTS FOR SODIUM AND HARDNESS						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Sodium (mg/L)	(2014 - 2020)	50	38 - 74	none	none	Salt present in the water and is generally naturally occurring
Hardness (mg/L)	(2014 - 2020)	406	378 - 433	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Table 3 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Fluoride (mg/L)	(2014 - 2020)	0.4	ND - 0.5	2	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Nitrate as N (mg/L)	(2014 - 2020)	1.6	1.0 - 4.0	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Nitrate + Nitrite as N (mg/L)	(2014 - 2020)	1.8	1 - 3.8	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Gross Alpha (pCi/L)	(2013 - 2020)	1.515	ND - 2.51	15	(0)	Erosion of natural deposits.

Table 4 - TREATED DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Sources of Contaminant
Nitrate as N (mg/L)	(2016 - 2019)	3.5	2.0 - 5.0	10	10	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits

Table 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Sources of Contaminant
Chloride (mg/L)	(2014 - 2020)	62	28 - 194	500	n/a	Runoff/leaching from natural deposits; seawater influence
Color (Units)	(2014 - 2020)	1	ND - 5	15	n/a	Naturally-occurring organic materials
Iron (ug/L)	(2014 - 2020)	ND	ND - 100	300	n/a	Leaching from natural deposits; Industrial wastes
Manganese (ug/L)	(2014 - 2020)	ND	ND - 20	50	n/a	Leaching from natural deposits
Specific Conductance (umhos/cm)	(2014 - 2020)	1016	888 - 1260	1600	n/a	Substances that form ions when in water; seawater influence
Sulfate (mg/L)	(2014 - 2020)	233	154 - 279	500	n/a	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (mg/L)	(2014 - 2020)	697	590 - 810	1000	n/a	Runoff/leaching from natural deposits
Turbidity (NTU)	(2014 - 2020)	0.4	ND - 1.0	5	n/a	Soil runoff
Zinc (mg/L)	(2014 - 2020)	0.07	ND - 0.39	5	n/a	Runoff/leaching from natural deposits

Table 6 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Boron (mg/L)	(2014 - 2020)	0.6	0.1 - 0.8	1	Boron exposures resulted in decreased fetal weight (developmental effects) in newborn rats.

Table 7 - ADDITIONAL DETECTIONS

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	Notification Level	Typical Sources of Contaminant
Calcium (mg/L)	(2014 - 2020)	115	107 - 122	n/a	n/a
Magnesium (mg/L)	(2014 - 2020)	29	27 - 33	n/a	n/a
pH (units)	(2014 - 2020)	7.6	7.2 - 7.8	n/a	n/a
Alkalinity (mg/L)	(2014 - 2020)	207	180 - 260	n/a	n/a
Aggressiveness Index	(2014 - 2020)	12.3	11.9 - 12.6	n/a	n/a
Langelier Index	(2014 - 2020)	0.46	0.03 - 0.8	n/a	n/a

Table 8 - DETECTION OF DISINFECTANT/DISINFECTANT BYPRODUCT RULE

Chemical or Constituent (and reporting units)	Sample Date	Average Level Detected	Range of Detections	MCL (MRDL)	PHG (MCLG)	Violation	Typical Sources of Contaminant
Total Trihalomethanes (TTHMs) (ug/L)	(2020)	47	4 - 63	80	n/a	No	By-product of drinking water disinfection
Chlorine (mg/L)	(2020)	3.24	2.4 - 3.5	4.0	4.0	No	Drinking water disinfectant added for treatment.
Haloacetic Acids (five) (ug/L)	(2020)	45.25	ND - 64	60	n/a	No	By-product of drinking water disinfection

Any violation of MCL, AL or MRDL is highlighted. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with the service lines and home plumbing. *Ventura River Water District* is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL,MRDL,AL,TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken To Correct the Violation	Health Effects Language
Haloacetic Acids (five)	The exceedance occurred in Casitas Water served to Monte Via neighborhood and Casitas Springs	Dec. 2019 to March 2020	Casitas adjusted their treatment system.	Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

2020 Consumer Confidence Report

Drinking Water Assessment Information

Assessment Information

VRWD has six active groundwater wells as its groundwater sources. The active wells are Wells 1, 2, 3, 4, 6 and 7. There are no sewer lines or sewage disposal facilities located within 50 feet of well sites. The six well sites are fenced for security. The wells are located about 700 feet from an active stream (when water is flowing). VRWD conducted the drinking water source assessment of its active wells in May of 2020.

Discussion of Vulnerability

There have been no contaminants detected in the water supply, however the wells are still considered vulnerable to activities located near the drinking water source.

Wells # 1, 2, 3, 4 & 7 are drinking water sources for the VENTURA RIVER WATER DISTRICT water system, they are located in the Upper Ventura River Groundwater Basin located in the Ojai Valley near Hwy 150 and the Ventura River. The Ventura River watershed covers 226 square miles and is the source for the Upper Ventura River Groundwater Basin. General land use is agricultural, urban, residential and National Forest.

The sources of contamination of Wells # 1, 2, 3, 4 & 7 that are of heightened concern are from onsite water treatment systems to the east of the wells, a sanitary sewer located 53-feet to 100-feet west of the wells and surface water in the Ventura River low flow channel located 1,000-feet west of the wells. Well # 1, 2, 3, 4 & 7 have been constructed with 50-foot deep sanitary seals and the first perforations vary from 72-feet to below the ground surface in Well #3 to 105-feet in Well #7. These design features will help protect against these three vulnerabilities.

Well #6: The most likely source of contamination of Well #6 is from onsite water treatment systems and an ephemeral drainage ditch located 180-feet north of the well. Well #6 has been constructed with a 120-foot deep sanitary seal and the first perforations are located 200-feet below the ground surface. These design features will help protect against these two vulnerabilities.

Acquiring Information

A copy of the complete assessment may be viewed at:
SWRCB Division of Drinking Water District Office
1180 Eugenia Place
Suite 200
Carpinteria, CA 930135

You may request a summary of the assessment be sent to you by contacting:

Jeff Densmore
District Engineer
(805) 566-1326
jeff.densmore@cdph.ca.gov

A copy of the reports can also be downloaded at:
<http://venturariverwd.com/reports>

Ventura River Water District

Analytical Results By FGL - 2020

LEAD AND COPPER RULE

		Units	MCLG	CA-MCL	PHG	Sampled	Result	90th Percentile	# Samples
Copper		mg/L		1.3	.3			0.22	20
11078 Rodeo Dr.	SP 1907248-17	mg/L				2019-06-04	0.22		
11551 Oakcrest Ave.	SP 1907335-5	mg/L				2019-06-04	ND		
1211 Avila Dr.	SP 1907248-25	mg/L				2019-06-04	0.10		
172 Burnham Rd.	SP 1907248-20	mg/L				2019-06-04	0.19		
1918 Country PL	SP 1907335-2	mg/L				2019-06-05	ND		
1991 Country Pl.	SP 1907248-8	mg/L				2019-06-04	0.07		
2131 Burnham Rd.	SP 1907335-4	mg/L				2019-06-05	0.08		
2187 Woodland Ave.	SP 1907248-1	mg/L				2019-06-04	0.07		
2235 Los Encinos Rd.	SP 1907248-11	mg/L				2019-06-04	ND		
2256 Los Encinos Rd.	SP 1907248-10	mg/L				2019-06-04	ND		
365 Burnham Rd.	SP 1907248-9	mg/L				2019-06-04	0.13		
400 Burnham Rd.	SP 1907335-1	mg/L				2019-06-05	ND		
45 Almond Ave.	SP 1907335-3	mg/L				2019-06-05	0.05		
478 Burnham Rd.	SP 1907248-22	mg/L				2019-06-04	0.32		
56 Grapevine Rd.	SP 1907248-14	mg/L				2019-06-04	0.15		
573 E. Katherine Ave.	SP 1907248-15	mg/L				2019-06-04	0.22		
617 Country Dr.	SP 1907248-3	mg/L				2019-06-04	0.09		
710 Heather St.	SP 1907248-4	mg/L				2019-06-04	0.13		
80 Pathelen Ave.	SP 1907248-16	mg/L				2019-06-04	0.13		
98 Wormwood St.	SP 1907248-7	mg/L				2019-06-04	0.08		

SAMPLING RESULTS FOR SODIUM AND HARDNESS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Sodium		mg/L		none	none			50	38 - 74
Well 01 (1989)	SP 2002008-1	mg/L				2020-02-11	48		
Well 02	SP 1405147-1	mg/L				2014-05-06	45		
Well 03	SP 1702589-1	mg/L				2017-02-28	38		
Well 04 (2007)	SP 2004090-1	mg/L				2020-03-24	51		
Well 06	SP 1809849-1	mg/L				2018-07-26	74		
Well 07 (New)	SP 2004227-1	mg/L				2020-03-27	43		
Hardness		mg/L		none	none			406	378 - 433
Well 01 (1989)	SP 2002008-1	mg/L				2020-02-11	432		
Well 02	SP 1405147-1	mg/L				2014-05-06	409		
Well 03	SP 1702589-1	mg/L				2017-02-28	378		
Well 04 (2007)	SP 2004090-1	mg/L				2020-03-24	433		
Well 06	SP 1809849-1	mg/L				2018-07-26	403		
Well 07 (New)	SP 2004227-1	mg/L				2020-03-27	382		

PRIMARY DRINKING WATER STANDARDS (PDWS)

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Fluoride		mg/L		2	1			0.4	ND - 0.5
Well 01 (1989)	SP 2002008-1	mg/L				2020-02-11	0.5		
Well 02	SP 1405147-1	mg/L				2014-05-06	ND		
Well 03	SP 1702589-1	mg/L				2017-02-28	0.4		
Well 04 (2007)	SP 2004090-1	mg/L				2020-03-24	0.5		
Well 06	SP 1809849-1	mg/L				2018-07-26	0.4		
Well 07 (New)	SP 2004227-1	mg/L				2020-03-27	0.5		
Nitrate as N		mg/L		10	10			1.6	1 - 4.0
Well 01 (1989)	SP 2016931-1	mg/L				2020-12-08	1.6		
Well 01 (1989)	SP 2015152-1	mg/L				2020-11-03	1.8		

Well 01 (1989)	SP 2014096-1	mg/L				2020-10-13	1.9		
Well 01 (1989)	SP 2012177-1	mg/L				2020-09-08	2.1		
Well 01 (1989)	SP 2010337-1	mg/L				2020-08-04	1.6		
Well 01 (1989)	SP 2008825-1	mg/L				2020-07-07	1.3		
Well 01 (1989)	SP 2007178-1	mg/L				2020-06-02	1.2		
Well 01 (1989)	SP 2005852-1	mg/L				2020-05-05	1		
Well 01 (1989)	SP 2004952-1	mg/L				2020-04-14	1		
Well 01 (1989)	SP 2003363-1	mg/L				2020-03-10	1.3		
Well 01 (1989)	SP 2002315-1	mg/L				2020-02-18	1.1		
Well 01 (1989)	SP 2002008-1	mg/L				2020-02-11	1		
Well 01 (1989)	SP 2000217-1	mg/L				2020-01-07	1.1		
Well 02	SP 1406653-1	mg/L				2014-06-10	2.60		
Well 02	SP 1405147-1	mg/L				2014-05-06	1.15		
Well 03	SP 1904031-1	mg/L				2019-03-26	2.4		
Well 04 (2007)	SP 2004090-1	mg/L				2020-03-24	1.1		
Well 06	SP 2005852-3	mg/L				2020-05-05	3.8		
Well 06	SP 2002315-3	mg/L				2020-02-18	4.0		
Well 07 (New)	SP 2016931-2	mg/L				2020-12-08	1.4		
Well 07 (New)	SP 2015152-2	mg/L				2020-11-03	1.5		
Well 07 (New)	SP 2014096-2	mg/L				2020-10-13	1.6		
Well 07 (New)	SP 2012177-2	mg/L				2020-09-08	1.7		
Well 07 (New)	SP 2010337-2	mg/L				2020-08-04	1.4		
Well 07 (New)	SP 2008825-2	mg/L				2020-07-07	1.2		
Well 07 (New)	SP 2007178-2	mg/L				2020-06-02	1.1		
Well 07 (New)	SP 2005852-2	mg/L				2020-05-05	1		
Well 07 (New)	SP 2004952-2	mg/L				2020-04-14	1		
Well 07 (New)	SP 2004227-1	mg/L				2020-03-27	1.2		
Well 07 (New)	SP 2003363-2	mg/L				2020-03-10	1.2		
Well 07 (New)	SP 2002315-2	mg/L				2020-02-18	1.1		
Well 07 (New)	SP 2000217-2	mg/L				2020-01-07	1.3		
Nitrate + Nitrite as N		mg/L		10	10			1.8	1 - 3.8
Well 01 (1989)	SP 2002008-1	mg/L				2020-02-11	1		
Well 02	SP 1405147-1	mg/L				2014-05-06	1.2		
Well 03	SP 1702589-1	mg/L				2017-02-28	2.3		
Well 04 (2007)	SP 2004090-1	mg/L				2020-03-24	1.1		
Well 06	SP 1809849-1	mg/L				2018-07-26	3.8		
Well 07 (New)	SP 2004227-1	mg/L				2020-03-27	1.2		
Gross Alpha		pCi/L		15	(0)			1.515	ND - 2.51
Well 01 (1989)	SP 1305549-1	pCi/L				2013-06-04	1.62		
Well 01 (1989)	SP 1302830-1	pCi/L				2013-03-19	1.29		
Well 03	SP 1305552-1	pCi/L				2013-06-04	2.51		
Well 03	SP 1302833-1	pCi/L				2013-03-19	1.27		
Well 04 (2007)	SP 1902985-1	pCi/L				2019-03-05	1.89		
Well 06	SP 2017325-1	pCi/L				2020-12-15	1.33		
Well 06	SP 2012588-1	pCi/L				2020-09-15	2.24		
Well 06	SP 2007587-1	pCi/L				2020-06-09	1.03		
Well 06	SP 2003739-1	pCi/L				2020-03-17	1.97		
Well 07 (New)	SP 2004227-1	pCi/L				2020-03-27	ND		

TREATED PRIMARY DRINKING WATER STANDARDS (PDWS)

	Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Nitrate as N	mg/L		10	10			3.5	2.0 - 5.0
Baldwin Tank #2	SP 1607831-3	mg/L			2016-07-12	5.0		
Baldwin Tank #2 - NO3 BLEND	SP 1900306-4	mg/L			2019-01-08	2.0		

SECONDARY DRINKING WATER STANDARDS (SDWS)

	Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Chloride	mg/L		500	n/a			62	28 - 194

Well 01 (1989)	SP 2002008-1	mg/L			2020-02-11	37		
Well 02	SP 1405147-1	mg/L			2014-05-06	41		
Well 03	SP 1702589-1	mg/L			2017-02-28	28		
Well 04 (2007)	SP 2004090-1	mg/L			2020-03-24	35		
Well 06	SP 1809849-1	mg/L			2018-07-26	194		
Well 07 (New)	SP 2004227-1	mg/L			2020-03-27	37		
Color		Units		15	n/a		1	ND - 5
Well 01 (1989)	SP 2002008-1	Units			2020-02-11	ND		
Well 02	SP 1405147-1	Units			2014-05-06	ND		
Well 03	SP 1702589-1	Units			2017-02-28	ND		
Well 04 (2007)	SP 2004090-1	Units			2020-03-24	ND		
Well 06	SP 1809849-1	Units			2018-07-26	ND		
Well 07 (New)	SP 2004227-1	Units			2020-03-27	5		
Iron		ug/L		300	n/a		ND	ND - 100
Well 01 (1989)	SP 2002008-1	ug/L			2020-02-11	ND		
Well 02	SP 1405147-1	ug/L			2014-05-06	100		
Well 03	SP 1702589-1	ug/L			2017-02-28	ND		
Well 04 (2007)	SP 2004090-1	ug/L			2020-03-24	ND		
Well 06	SP 1809849-1	ug/L			2018-07-26	ND		
Well 07 (New)	SP 2004227-1	ug/L			2020-03-27	ND		
Manganese		ug/L		50	n/a		ND	ND - 20
Well 01 (1989)	SP 2002008-1	ug/L			2020-02-11	ND		
Well 02	SP 1405147-1	ug/L			2014-05-06	ND		
Well 03	SP 1702589-1	ug/L			2017-02-28	ND		
Well 04 (2007)	SP 2004090-1	ug/L			2020-03-24	ND		
Well 06	SP 1809849-1	ug/L			2018-07-26	20		
Well 07 (New)	SP 2004227-1	ug/L			2020-03-27	ND		
Specific Conductance		umhos/cm		1600	n/a		1016	888 - 1260
Well 01 (1989)	SP 2002008-1	umhos/cm			2020-02-11	953		
Well 02	SP 1405147-1	umhos/cm			2014-05-06	914		
Well 03	SP 1702589-1	umhos/cm			2017-02-28	888		
Well 04 (2007)	SP 2004090-1	umhos/cm			2020-03-24	1040		
Well 06	SP 1809849-1	umhos/cm			2018-07-26	1260		
Well 07 (New)	SP 2004227-1	umhos/cm			2020-03-27	1040		
Sulfate		mg/L		500	n/a		233	154 - 279
Well 01 (1989)	SP 2002008-1	mg/L			2020-02-11	274		
Well 02	SP 1405147-1	mg/L			2014-05-06	241		
Well 03	SP 1702589-1	mg/L			2017-02-28	177		
Well 04 (2007)	SP 2004090-1	mg/L			2020-03-24	272		
Well 06	SP 1809849-1	mg/L			2018-07-26	154		
Well 07 (New)	SP 2004227-1	mg/L			2020-03-27	279		
Total Dissolved Solids		mg/L		1000	n/a		697	590 - 810
Well 01 (1989)	SP 2002008-1	mg/L			2020-02-11	710		
Well 02	SP 1405147-1	mg/L			2014-05-06	630		
Well 03	SP 1702589-1	mg/L			2017-02-28	590		
Well 04 (2007)	SP 2004090-1	mg/L			2020-03-24	720		
Well 06	SP 1809849-1	mg/L			2018-07-26	810		
Well 07 (New)	SP 2004227-1	mg/L			2020-03-27	720		
Turbidity		NTU		5	n/a		0.4	ND - 1.0
Well 01 (1989)	SP 2002008-1	NTU			2020-02-11	0.5		
Well 02	SP 1405147-1	NTU			2014-05-06	ND		
Well 03	SP 1702589-1	NTU			2017-02-28	0.5		
Well 04 (2007)	SP 2004090-1	NTU			2020-03-24	1.0		
Well 06	SP 1809849-1	NTU			2018-07-26	0.3		
Well 07 (New)	SP 2004227-1	NTU			2020-03-27	0.2		
Zinc		mg/L		5	n/a		0.07	ND - 0.39
Well 01 (1989)	SP 2002008-1	mg/L			2020-02-11	ND		
Well 02	SP 1405147-1	mg/L			2014-05-06	ND		
Well 03	SP 1702589-1	mg/L			2017-02-28	ND		
Well 04 (2007)	SP 2004090-1	mg/L			2020-03-24	ND		

Well 06	SP 1809849-1	mg/L				2018-07-26	0.39		
Well 07 (New)	SP 2004227-1	mg/L				2020-03-27	ND		

UNREGULATED CONTAMINANTS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Boron		mg/L		NS	n/a			0.6	0.1 - 0.8
Well 01 (1989)	SP 2002008-1	mg/L				2020-02-11	0.8		
Well 02	SP 1405147-1	mg/L				2014-05-06	0.6		
Well 03	SP 1702589-1	mg/L				2017-02-28	0.5		
Well 04 (2007)	SP 2004090-1	mg/L				2020-03-24	0.8		
Well 06	SP 1809849-1	mg/L				2018-07-26	0.1		
Well 07 (New)	SP 2004227-1	mg/L				2020-03-27	0.7		

ADDITIONAL DETECTIONS

		Units	MCLG	CA-MCL	PHG	Sampled	Result	Avg. Result(a)	Range (b)
Calcium		mg/L			n/a			115	107 - 122
Well 01 (1989)	SP 2002008-1	mg/L				2020-02-11	122		
Well 02	SP 1405147-1	mg/L				2014-05-06	116		
Well 03	SP 1702589-1	mg/L				2017-02-28	107		
Well 04 (2007)	SP 2004090-1	mg/L				2020-03-24	119		
Well 06	SP 1809849-1	mg/L				2018-07-26	117		
Well 07 (New)	SP 2004227-1	mg/L				2020-03-27	107		
Magnesium		mg/L			n/a			29	27 - 33
Well 01 (1989)	SP 2002008-1	mg/L				2020-02-11	31		
Well 02	SP 1405147-1	mg/L				2014-05-06	29		
Well 03	SP 1702589-1	mg/L				2017-02-28	27		
Well 04 (2007)	SP 2004090-1	mg/L				2020-03-24	33		
Well 06	SP 1809849-1	mg/L				2018-07-26	27		
Well 07 (New)	SP 2004227-1	mg/L				2020-03-27	28		
pH		units			n/a			7.6	7.2 - 7.8
Well 01 (1989)	SP 2002008-1	units				2020-02-11	7.7		
Well 02	SP 1405147-1	units				2014-05-06	7.7		
Well 03	SP 1702589-1	units				2017-02-28	7.8		
Well 04 (2007)	SP 2004090-1	units				2020-03-24	7.5		
Well 06	SP 1809849-1	units				2018-07-26	7.2		
Well 07 (New)	SP 2004227-1	units				2020-03-27	7.5		
Alkalinity		mg/L			n/a			207	180 - 260
Well 01 (1989)	SP 2002008-1	mg/L				2020-02-11	200		
Well 02	SP 1405147-1	mg/L				2014-05-06	180		
Well 03	SP 1702589-1	mg/L				2017-02-28	260		
Well 04 (2007)	SP 2004090-1	mg/L				2020-03-24	210		
Well 06	SP 1809849-1	mg/L				2018-07-26	180		
Well 07 (New)	SP 2004227-1	mg/L				2020-03-27	210		
Aggressiveness Index					n/a			12.3	11.9 - 12.6
Well 01 (1989)	SP 2002008-1					2020-02-11	12.5		
Well 02	SP 1405147-1					2014-05-06	12.4		
Well 03	SP 1702589-1					2017-02-28	12.6		
Well 04 (2007)	SP 2004090-1					2020-03-24	12.3		
Well 06	SP 1809849-1					2018-07-26	11.9		
Well 07 (New)	SP 2004227-1					2020-03-27	12.2		
Langelier Index					n/a			0.46	0.03 - 0.8
Well 01 (1989)	SP 2002008-1					2020-02-11	0.6		
Well 02	SP 1405147-1					2014-05-06	0.5		
Well 03	SP 1702589-1					2017-02-28	0.8		
Well 04 (2007)	SP 2004090-1					2020-03-24	0.4		
Well 06	SP 1809849-1					2018-07-26	0.03		
Well 07 (New)	SP 2004227-1					2020-03-27	0.4		

Ventura River Water District

CCR Login Linkage - 2020

FGL Code	Lab ID	Date_Sampled	Method	Description	Property
1092MORENO	SP 2001608-1	2020-02-04	Coliform	1092 Moreno Dr	Week 1 System Monitoring
	SP 2003364-1	2020-03-10	Coliform	1092 Moreno Dr	Week 2 System Monitoring
	SP 2005259-1	2020-04-21	Coliform	1092 Moreno Dr	Week 3 System Monitoring
	SP 2006866-1	2020-05-26	Coliform	1092 Moreno Dr	Week 4 System Monitoring
	SP 2009650-1	2020-07-21	Coliform	1092 Moreno Dr	Week 1 System Monitoring
	SP 2010733-1	2020-08-11	Coliform	1092 Moreno Dr	Week 2 System Monitoring
	SP 2012587-1	2020-09-15	Coliform	1092 Moreno Dr	Week 3 System Monitoring
	SP 2014828-1	2020-10-27	Coliform	1092 Moreno Dr	Week 4 System Monitoring
	SP 2016486-1	2020-12-01	Coliform	1092 Moreno Dr	Week 1 System Monitoring
11078 Rodeo Dr.	SP 1907248-17	2019-06-04	Metals, Total	11078 Rodeo Dr.	Lead & Copper Monitoring
11551 Oakcrest	SP 1907335-5	2019-06-04	Metals, Total	11551 Oakcrest Ave.	Lead & Copper Monitoring
1211 Avila Dr.	SP 1907248-25	2019-06-04	Metals, Total	1211 Avila Dr.	Lead & Copper Monitoring
172 Burnham Rd.	SP 1907248-20	2019-06-04	Metals, Total	172 Burnham Rd.	Lead & Copper Monitoring
SS - Wk4	SP 2000607-1	2020-01-14	Coliform	175 Rio Via	Week 2 System Monitoring
	SP 2000607-1	2020-01-14	Field Test	175 Rio Via	Week 2 System Monitoring
	SP 2004091-1	2020-03-24	Coliform	175 Rio Via	Week 4 System Monitoring
	SP 2004091-1	2020-03-24	Field Test	175 Rio Via	Week 4 System Monitoring
	SP 2011472-1	2020-08-25	Coliform	175 Rio Via	Week 4 System Monitoring
	SP 2011472-1	2020-08-25	Field Test	175 Rio Via	Week 4 System Monitoring
	SP 2017328-1	2020-12-15	Coliform	175 Rio Via	Week 3 System Monitoring
	SP 2017328-1	2020-12-15	Field Test	175 Rio Via	Week 3 System Monitoring
	DBP 175RioVia	SP 2002313-1	2020-02-18	Field Test	175 RIO VIA - STAGE 2 DBP
SP 2002313-1		2020-02-18	Coliform	175 RIO VIA - STAGE 2 DBP	Week 3 System Monitoring
SP 2002986-1		2020-03-03	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
SP 2002986-1		2020-03-03	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
SP 2005853-1		2020-05-05	Field Test	175 RIO VIA - STAGE 2 DBP	Week 1 System Monitoring
SP 2005853-1		2020-05-05	Coliform	175 RIO VIA - STAGE 2 DBP	Week 1 System Monitoring
SP 2007588-1		2020-06-09	Coliform	175 RIO VIA - STAGE 2 DBP	Week 2 System Monitoring
SP 2007588-1		2020-06-09	Field Test	175 RIO VIA - STAGE 2 DBP	Week 2 System Monitoring
SP 2008378-1		2020-06-25	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
SP 2008378-1		2020-06-25	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
SP 2008828-1		2020-07-07	Coliform	175 RIO VIA - STAGE 2 DBP	Week 3 System Monitoring
SP 2008828-1		2020-07-07	Field Test	175 RIO VIA - STAGE 2 DBP	Week 3 System Monitoring
SP 2011858-1		2020-09-01	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
SP 2011858-1		2020-09-01	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring
SP 2013709-1		2020-10-06	Field Test	175 RIO VIA - STAGE 2 DBP	Week #1
SP 2013709-1		2020-10-06	Coliform	175 RIO VIA - STAGE 2 DBP	Week #1
SP 2015558-1		2020-11-10	Field Test	175 RIO VIA - STAGE 2 DBP	Week 2 System Monitoring
SP 2015558-1	2020-11-10	Coliform	175 RIO VIA - STAGE 2 DBP	Week 2 System Monitoring	
SP 2016487-1	2020-12-01	EPA 551.1	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring	
SP 2016487-1	2020-12-01	EPA 552.2	175 Rio Via - Stage 2 DBP	Stage 2 DBP Site Monitoring	
1918 Country PL	SP 1907335-2	2019-06-05	Metals, Total	1918 Country PL	Lead & Copper Monitoring
1991 Country Pl	SP 1907248-8	2019-06-04	Metals, Total	1991 Country Pl.	Lead & Copper Monitoring
DBP 202ValleRio	SP 2001608-2	2020-02-04	Coliform	202 VALLE RIO - STAGE 2 DBP	Week 1 System Monitoring
	SP 2001608-2	2020-02-04	Field Test	202 VALLE RIO - STAGE 2 DBP	Week 1 System Monitoring
	SP 2002986-2	2020-03-03	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 2002986-2	2020-03-03	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 2003364-2	2020-03-10	Coliform	202 VALLE RIO - STAGE 2 DBP	Week 2 System Monitoring
	SP 2008378-2	2020-06-25	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 2008378-2	2020-06-25	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 2009650-2	2020-07-21	Coliform	202 VALLE RIO - STAGE 2 DBP	Week 1 System Monitoring
	SP 2011858-2	2020-09-01	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 2011858-2	2020-09-01	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 2016487-2	2020-12-01	EPA 552.2	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring
	SP 2016487-2	2020-12-01	EPA 551.1	202 Valle Rio - Stage 2 DBP	Stage 2 DBP Site Monitoring

SS - 10A	SP 2005259-2	2020-04-21	Coliform	202 Valle Rio Ave. - Book 10A	Week 3 System Monitoring
	SP 2006866-2	2020-05-26	Coliform	202 Valle Rio Ave. - Book 10A	Week 4 System Monitoring
	SP 2010733-2	2020-08-11	Coliform	202 Valle Rio Ave. - Book 10A	Week 2 System Monitoring
	SP 2012587-2	2020-09-15	Coliform	202 Valle Rio Ave. - Book 10A	Week 3 System Monitoring
	SP 2014828-2	2020-10-27	Coliform	202 Valle Rio Ave. - Book 10A	Week 4 System Monitoring
	SP 2016486-2	2020-12-01	Coliform	202 Valle Rio Ave. - Book 10A	Week 1 System Monitoring
SS - 9B	SP 2000218-1	2020-01-07	Coliform	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
	SP 2002007-1	2020-02-11	Coliform	2096 Sumac Dr. - Book 9B	Week 2 System Monitoring
	SP 2003740-1	2020-03-17	Coliform	2096 Sumac Dr. - Book 9B	Week 3 System Monitoring
	SP 2005561-1	2020-04-28	Coliform	2096 Sumac Dr. - Book 9B	Week 4 System Monitoring
	SP 2007177-1	2020-06-02	Coliform	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
	SP 2009252-1	2020-07-14	Coliform	2096 Sumac Dr. - Book 9B	Week 2 System Monitoring
	SP 2011122-1	2020-08-18	Coliform	2096 Sumac Dr. - Book 9B	Week 3 System Monitoring
	SP 2013032-1	2020-09-22	Coliform	2096 Sumac Dr. - Book 9B	Week 4 System Monitoring
	SP 2015151-1	2020-11-03	Coliform	2096 Sumac Dr. - Book 9B	Week 1 System Monitoring
	SP 2016930-1	2020-12-08	Coliform	2096 Sumac Dr. - Book 9B	Week 2 System Monitoring
2131 Burnham Rd	SP 1907335-4	2019-06-05	Metals, Total	2131 Burnham Rd.	Lead & Copper Monitoring
2187 Woodland A	SP 1907248-1	2019-06-04	Metals, Total	2187 Woodland Ave.	Lead & Copper Monitoring
2235 Los Encino	SP 1907248-11	2019-06-04	Metals, Total	2235 Los Encinos Rd.	Lead & Copper Monitoring
2256 Los Encino	SP 1907248-10	2019-06-04	Metals, Total	2256 Los Encinos Rd.	Lead & Copper Monitoring
SS - 9A	SP 2000607-2	2020-01-14	Coliform	265 E. Villanova Rd. Book 9A	Week 2 System Monitoring
	SP 2002313-2	2020-02-18	Coliform	265 E. Villanova Rd. Book 9A	Week 3 System Monitoring
	SP 2004091-2	2020-03-24	Coliform	265 E. Villanova Rd. Book 9A	Week 4 System Monitoring
	SP 2005853-2	2020-05-05	Coliform	265 E. Villanova Rd. Book 9A	Week 1 System Monitoring
	SP 2007588-2	2020-06-09	Coliform	265 E. Villanova Rd. Book 9A	Week 2 System Monitoring
	SP 2008828-2	2020-07-07	Coliform	265 E. Villanova Rd. Book 9A	Week 3 System Monitoring
	SP 2011472-2	2020-08-25	Coliform	265 E. Villanova Rd. Book 9A	Week 4 System Monitoring
	SP 2013709-2	2020-10-06	Coliform	265 E. Villanova Rd. Book 9A	Week #1
	SP 2015558-2	2020-11-10	Coliform	265 E. Villanova Rd. Book 9A	Week 2 System Monitoring
	SP 2017328-2	2020-12-15	Coliform	265 E. Villanova Rd. Book 9A	Week 3 System Monitoring
SS - 8	SP 2001285-2	2020-01-28	Coliform	290 Alto Dr. - Book 8	Week 4 System Monitoring
	SP 2002990-2	2020-03-03	Coliform	290 Alto Dr. - Book 8	Week 1 System Monitoring
	SP 2004953-1	2020-04-14	Coliform	290 Alto Dr. - Book 8	Week 2 System Monitoring
	SP 2006533-2	2020-05-19	Coliform	290 Alto Dr. - Book 8	Week 3 System Monitoring
	SP 2008252-2	2020-06-23	Coliform	290 Alto Dr. - Book 8	Week 4 System Monitoring
	SP 2010335-2	2020-08-04	Coliform	290 Alto Dr. - Book 8	Week 1 System Monitoring
	SP 2012176-2	2020-09-08	Coliform	290 Alto Dr. - Book 8	Week 2 System Monitoring
	SP 2014459-2	2020-10-20	Coliform	290 Alto Dr. - Book 8	Week 3 System Monitoring
	SP 2016289-2	2020-11-24	Coliform	290 Alto Dr. - Book 8	Week 4 System Monitoring
365 Burnham Rd.	SP 1907248-9	2019-06-04	Metals, Total	365 Burnham Rd.	Lead & Copper Monitoring
400 Burnham Rd.	SP 1907335-1	2019-06-05	Metals, Total	400 Burnham Rd.	Lead & Copper Monitoring
45 Almond Ave.	SP 1907335-3	2019-06-05	Metals, Total	45 Almond Ave.	Lead & Copper Monitoring
478 Burnham Rd.	SP 1907248-22	2019-06-04	Metals, Total	478 Burnham Rd.	Lead & Copper Monitoring
56 Grapevine Rd	SP 1907248-14	2019-06-04	Metals, Total	56 Grapevine Rd.	Lead & Copper Monitoring
573 E. Katherin	SP 1907248-15	2019-06-04	Metals, Total	573 E. Katherine Ave.	Lead & Copper Monitoring
SS - 7	SP 2000218-2	2020-01-07	Coliform	595 Riverside Rd. - Book 7	Week 1 System Monitoring
	SP 2002007-2	2020-02-11	Coliform	595 Riverside Rd. - Book 7	Week 2 System Monitoring
	SP 2003740-2	2020-03-17	Coliform	595 Riverside Rd. - Book 7	Week 3 System Monitoring
	SP 2005561-2	2020-04-28	Coliform	595 Riverside Rd. - Book 7	Week 4 System Monitoring
	SP 2007177-2	2020-06-02	Coliform	595 Riverside Rd. - Book 7	Week 1 System Monitoring
	SP 2009252-2	2020-07-14	Coliform	595 Riverside Rd. - Book 7	Week 2 System Monitoring
	SP 2011122-2	2020-08-18	Coliform	595 Riverside Rd. - Book 7	Week 3 System Monitoring
	SP 2013032-2	2020-09-22	Coliform	595 Riverside Rd. - Book 7	Week 4 System Monitoring
	SP 2015151-2	2020-11-03	Coliform	595 Riverside Rd. - Book 7	Week 1 System Monitoring
	SP 2016930-2	2020-12-08	Coliform	595 Riverside Rd. - Book 7	Week 2 System Monitoring
617 Country Dr.	SP 1907248-3	2019-06-04	Metals, Total	617 Country Dr.	Lead & Copper Monitoring
710 Heather St.	SP 1907248-4	2019-06-04	Metals, Total	710 Heather St.	Lead & Copper Monitoring
SS - 5A	SP 2000964-2	2020-01-21	Coliform	72 W. Catalina Dr.	Week 3 System Monitoring
	SP 2002643-2	2020-02-25	Coliform	72 W. Catalina Dr.	Week 4 System Monitoring
	SP 2004616-2	2020-04-07	Coliform	72 W. Catalina Dr.	Week 1 System Monitoring

	SP 2006200-2	2020-05-12	Coliform	72 W. Catalina Dr.	Week 2 System Monitoring
	SP 2007935-2	2020-06-16	Coliform	72 W. Catalina Dr.	Week 3 System Monitoring
	SP 2009977-2	2020-07-28	Coliform	72 W. Catalina Dr.	Week 4 System Monitoring
	SP 2011859-2	2020-09-01	Coliform	72 W. Catalina Dr.	Week 1 System Monitoring
	SP 2014094-2	2020-10-13	Coliform	72 W. Catalina Dr.	Week 2 System Monitoring
	SP 2015908-2	2020-11-17	Coliform	72 W. Catalina Dr.	Week 3 System Monitoring
	SP 2017699-2	2020-12-22	Coliform	72 W. Catalina Dr.	Week 4 System Monitoring
80 Pathelen Ave	SP 1907248-16	2019-06-04	Metals, Total	80 Pathelen Ave.	Lead & Copper Monitoring
85 Almond AVE	SP 2000964-1	2020-01-21	Coliform	85 Almond Ave.	Week 3 System Monitoring
	SP 2002643-1	2020-02-25	Coliform	85 Almond Ave.	Week 4 System Monitoring
	SP 2004616-1	2020-04-07	Coliform	85 Almond Ave.	Week 1 System Monitoring
	SP 2006200-1	2020-05-12	Coliform	85 Almond Ave.	Week 2 System Monitoring
	SP 2009977-1	2020-07-28	Coliform	85 Almond Ave.	Week 4 System Monitoring
	SP 2011859-1	2020-09-01	Coliform	85 Almond Ave.	Week 1 System Monitoring
	SP 2014094-1	2020-10-13	Coliform	85 Almond Ave.	Week 2 System Monitoring
	SP 2015908-1	2020-11-17	Coliform	85 Almond Ave.	Week 3 System Monitoring
	SP 2017699-1	2020-12-22	Coliform	85 Almond Ave.	Week 4 System Monitoring
SS - 6B	SP 2007935-1	2020-06-16	Coliform	85 Almond Ave. - Book 6B	Week 3 System Monitoring
SS - 14	SP 2001285-1	2020-01-28	Field Test	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 2001285-1	2020-01-28	Coliform	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 2002990-1	2020-03-03	Field Test	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 2002990-1	2020-03-03	Coliform	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 2004953-2	2020-04-14	Coliform	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 2004953-2	2020-04-14	Field Test	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 2006533-1	2020-05-19	Coliform	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 2006533-1	2020-05-19	Field Test	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 2008252-1	2020-06-23	Field Test	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 2008252-1	2020-06-23	Coliform	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 2010335-1	2020-08-04	Field Test	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 2010335-1	2020-08-04	Coliform	9148 Nye Rd. - Book 14	Week 1 System Monitoring
	SP 2012176-1	2020-09-08	Field Test	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 2012176-1	2020-09-08	Coliform	9148 Nye Rd. - Book 14	Week 2 System Monitoring
	SP 2014459-1	2020-10-20	Coliform	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 2014459-1	2020-10-20	Field Test	9148 Nye Rd. - Book 14	Week 3 System Monitoring
	SP 2016289-1	2020-11-24	Coliform	9148 Nye Rd. - Book 14	Week 4 System Monitoring
	SP 2016289-1	2020-11-24	Field Test	9148 Nye Rd. - Book 14	Week 4 System Monitoring
98 Wormwood St.	SP 1907248-7	2019-06-04	Metals, Total	98 Wormwood St.	Lead & Copper Monitoring
Bald Tnk 2	SP 1607831-3	2016-07-12	Wet Chemistry	Baldwin Tank #2	Nitrate Monitoring
	SP 1900306-4	2019-01-08	Wet Chemistry	Baldwin Tank #2 - NO3 BLEND	Nitrate Monitoring
Well 01	SP 1302830-1	2013-03-19	Radio Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 1305549-1	2013-06-04	Radio Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 2000217-1	2020-01-07	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 2002008-1	2020-02-11	Wet Chemistry	Well 01 (1989)	Well 01 - Water Quality
	SP 2002008-1	2020-02-11	General Mineral	Well 01 (1989)	Well 01 - Water Quality
	SP 2002315-1	2020-02-18	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 2003363-1	2020-03-10	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 2004952-1	2020-04-14	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 2005852-1	2020-05-05	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 2007178-1	2020-06-02	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 2008825-1	2020-07-07	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 2010337-1	2020-08-04	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 2012177-1	2020-09-08	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 2014096-1	2020-10-13	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 2015152-1	2020-11-03	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
	SP 2016931-1	2020-12-08	Wet Chemistry	Well 01 (1989)	Nitrate Monitoring
Well 02	SP 1405147-1	2014-05-06	General Mineral	Well 02	Well 02 - Water Quality
	SP 1405147-1	2014-05-06	Wet Chemistry	Well 02	Well 02 - Water Quality
	SP 1406653-1	2014-06-10	Wet Chemistry	Well 02	Well 02 - Water Quality
Well 03	SP 1302833-1	2013-03-19	Radio Chemistry	Well 03	Well 03 - Radio Monitoring
	SP 1305552-1	2013-06-04	Radio Chemistry	Well 03	Well 03 - Radio Monitoring

	SP 1702589-1	2017-02-28	General Mineral	Well 03	Well 03 - Water Quality
	SP 1702589-1	2017-02-28	Wet Chemistry	Well 03	Well 03 - Water Quality
	SP 1904031-1	2019-03-26	Wet Chemistry	Well 03	Well 03 - Water Quality
Well 04	SP 1902985-1	2019-03-05	Radio Chemistry	Well 04 (2007)	Well 04 - Radio Monitoring
	SP 2004090-1	2020-03-24	General Mineral	Well 04 (2007)	Well 04 - Water Quality
	SP 2004090-1	2020-03-24	Wet Chemistry	Well 04 (2007)	Well 04 - Water Quality
Well 6	SP 1809849-1	2018-07-26	General Mineral	Well 06	New Well 6 - Title 22
	SP 1809849-1	2018-07-26	Wet Chemistry	Well 06	New Well 6 - Title 22
	SP 2002315-3	2020-02-18	Wet Chemistry	Well 06	Nitrate Monitoring
	SP 2003739-1	2020-03-17	Radio Chemistry	Well 06	Well 06 - Water Quality
	SP 2005852-3	2020-05-05	Wet Chemistry	Well 06	Nitrate Monitoring
	SP 2007587-1	2020-06-09	Radio Chemistry	Well 06	Well 06 - Water Quality
	SP 2012588-1	2020-09-15	Radio Chemistry	Well 06	Well 06 - Water Quality
	SP 2017325-1	2020-12-15	Radio Chemistry	Well 06	Well 06 - Water Quality
Well 07 New	SP 2000217-2	2020-01-07	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 2002315-2	2020-02-18	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 2003363-2	2020-03-10	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 2004227-1	2020-03-27	General Mineral	Well 07 (New)	Well 7 - Water Quality
	SP 2004227-1	2020-03-27	Wet Chemistry	Well 07 (New)	Well 7 - Water Quality
	SP 2004227-1	2020-03-27	Radio Chemistry	Well 07 (New)	Well 7 - Water Quality
	SP 2004952-2	2020-04-14	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 2005852-2	2020-05-05	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 2007178-2	2020-06-02	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 2008825-2	2020-07-07	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 2010337-2	2020-08-04	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 2012177-2	2020-09-08	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 2014096-2	2020-10-13	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 2015152-2	2020-11-03	Wet Chemistry	Well 07 (New)	Nitrate Monitoring
	SP 2016931-2	2020-12-08	Wet Chemistry	Well 07 (New)	Nitrate Monitoring

Casitas Municipal Water District, PWS CA5610024 Water Quality Summary, 2020 Data

WATER CLARITY	MCL or [MRDL]	PHG, (MCLG)	LAKE CASITAS TREATED WATER				SAMPLE SOURCE & YEAR TESTED		SOURCE OF CONSTITUENT	
			FILTER EFFLUENT		RANGE		Filter Effluent			
Direct Filtration	Treatment Technique (TT)		Highest Value = 0.04		0.01-0.04		2020			
Filter Effluent Turbidity ^a (NTU)	TT < 1 NTU	NA	100% of turbidity measurements were < 0.2 NTU				2020		Soil run-off	
	95 % < 0.2 NTU	NA	100% = lowest monthly % of samples meeting turbidity limits				2020			
MICROBIOLOGICAL			DISTRIBUTION SYSTEM				Distribution System			
Total Coliform Bacteria ^b	> 1 positive sample/month	(0)	0		ND		2020		Naturally present in the environment	
E. Coli Bacteria	> 1 positive sample/month	(0)	0		ND		2020		Human and animal fecal waste	
INORGANIC CHEMICALS			Lake Casitas Treated Water		Mira Monte Well Treated		Lake Casitas Treated	Mira Monte Well		
Barium (ppm)	1	2	0.12	NA	0.12 ^g	0.10 - 0.12	2020	2019 ^d	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits	
Fluoride (ppm)	2.0	1	0.4	NA	0.4 ^g	0.4 - 0.5	2020	2019 ^d	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
Nitrate as N (ppm)	10	10	ND	NA	0.9 ^e	0.5 - 1.1 ^c	2020	2020	Runoff and leaching from fertilizer use; leaching from tanks and sewerage; erosion from natural products	
DISINFECTANT RESIDUALS AND DISINFECTION BY-PRODUCTS			DISTRIBUTION SYSTEM				Distribution System			
Chloramines as Cl ₂ (ppm)	Running Annual Average (RAA) MCL or [MRDL] [4.0]	PHG or [MRDLG] [4.0]	[2.3]		0.4-4.3		2020		Drinking water disinfectant added for treatment	
Trihalomethanes (ppb)	80	NA	58		38-61		2020		By-product of drinking water disinfection	
Haloacetic acids (ppb)	60	NA	59		14-76		2020		By-product of drinking water disinfection	
LEAD AND COPPER			Regulatory Action Level (RAL)	PHG	Number of Samples Collected	Homes above RAL	Level Detected at 90th percentile		Individual Taps	
Lead (ppb) ^e	15	0.2	30	0	ND		2020		Internal corrosion of household plumbing systems; discharges from industrial manufacturers; erosion of natural products	
Copper (ppm) ^e	1.3	0.3	30	0	1.0		2020		Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
Lead school	15	0.2	Number of schools requesting lead sampling = 4; Sample locations = 19; Locations above RAL = 0				2017 ^d		Internal corrosion of end-user plumbing systems; discharges from industrial manufacturers; erosion of natural products	

SECONDARY AESTHETIC STANDARDS

CONSTITUENTS	Secondary MCL	PHG	Lake Casitas Treated		Mira Monte Well Treated		Distribution System		Year Tested		SOURCE OF CONSTITUENT
			AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE	Lake/Dist. Syst.	Mira Monte Well ^d	
Turbidity (NTU)	5	NA	0.2	NA	0.2 ^g	0.2-0.2	0.3 ^f	0.1-1.2 ^f	2020	2019	Soil run-off
Total Dissolved Solids (ppm)	1000	NA	470	NA	467 ^g	390-470	NA	NA	2020	2019	Run-off / leaching from natural deposits
Specific Conductance (µS/cm)	1600	NA	705	NA	704 ^g	683-705	695 ^f	646-827 ^f	2020	2019	Substances that form ions in water; seawater influence
Chloride (ppm)	500	NA	23	NA	24 ^e	23-63	NA	NA	2020	2019	Run-off/leaching from natural deposits; seawater influence
Sulfate (ppm)	500	NA	176	NA	172 ^g	39-176	NA	NA	2020	2019	Run-off /leaching from natural deposits; industrial wastes

ADDITIONAL CONSTITUENTS

ADDITIONAL CONSTITUENTS (Unregulated)	Secondary MCL	PHG (NL)	Lake Casitas Treated		Mira Monte Well Treated		Distribution System		Year Tested		SOURCE OF CONSTITUENT
			AVERAGE	RANGE	AVERAGE	RANGE	AVERAGE	RANGE	Lake/Dist. Syst.	Mira Monte Well ^d	
Alkalinity - Total as CaCO ₃ (ppm)	NA	NA	140	NA	141 ^g	140-160	161 ^f	151 - 174 ^f	2020	2019	A measure of the capacity to neutralize acid
pH (pH standard units)	6.5-8.5 (US EPA)	NA	7.6	NA	7.6 ^g	7.3-7.6	7.5 ^f	7.2 - 8.0 ^f	2020	2019	A measure of acidity or alkalinity
Hardness - Total as CaCO ₃ (ppm)	NA	NA	295 (17.3 gpg)	NA	292 ^g (17.1 gpg)	198-295 (11.6-17.3 gpg)	NA	NA	2020	2019	"Hardness" is the sum of polyvalent cations present in the water, generally magnesium and calcium. The cations are usually naturally occurring
Corrosivity (Langlier Index) ^e	NA	NA	0.10	NA	0.09 ^g	-0.20-0.10	NA	NA	2020	2019	Indicator of corrosion. A positive Langlier Index indicates the water is non-corrosive
Boron (ppb)	NA	(1000)	200	NA	197 ^g	ND-200	NA	NA	2020	2019	A naturally-occurring element
Calcium (ppm)	NA	NA	72	NA	71 ^g	53-72	NA	NA	2020	2019	A naturally-occurring element
Magnesium (ppm)	NA	NA	28	NA	28 ^g	16-28	NA	NA	2020	2019	A naturally-occurring element
Potassium (ppm)	NA	NA	4	NA	4 ^g	ND-4	NA	NA	2020	2019	A naturally-occurring element
Bicarbonate (ppm)	NA	NA	170	NA	171 ^g	170-190	NA	NA	2020	2019	A measure of the capacity to neutralize acid
Sodium (ppm)	NA	NA	31	NA	32 ^g	31-50	NA	NA	2020	2019	"Sodium" refers to the salt present in the water and is generally naturally occurring.

Abbreviations and Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (US EPA).

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Running Annual Average (RAA): Some MCL's are determined based on the running annual average which is calculated by averaging all sample results within the previous four quarters. Locational running annual average includes results averaged over the previous four quarters for a specific sample site.

Notification Level: Health based advisory levels established by the State Board for chemicals in drinking water that lack MCLs.

Primary Drinking Water Standards (PDWS): MCLs, MRDLs and treatment techniques (TT) for contaminants that affect health, along with their monitoring and reporting requirements.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Regulatory Action Level (RAL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

NA - Not Applicable

ND - None Detected

NL - Notification Level

NS - No Sample

NTU - Nephelometric Turbidity Units (a measure of turbidity)

ppm - Parts per million, or milligrams per liter (mg/L)

ppb - Parts per billion, or micrograms per liter (ug/L)

RAA: Running Annual Average

µS/cm - Micro Siemens per Centimeter (a measure of specific conductance)

gpg - Grains per gallon, an alternative unit used to measure hardness

Water Quality Table Footnotes:

a) Turbidity is a measure of the cloudiness of water and is a good measure of water quality and filtration performance; 100 % of the samples tested for turbidity were below the required TT level of 0.2 NTU and 100% is the lowest monthly percentage of samples meeting the turbidity limits.

b) During 2020 Casitas collected 159 samples for total coliform bacteria testing according to the Total Coliform Rule. Total coliform bacteria were not detected in any of these samples.

c) Mira Monte Well water receives blending treatment with lake Casitas water and when operated, blended water is sampled weekly for nitrates with the resulting nitrate level averaging 0.9 ppm as nitrogen in 2020.

d) The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of these data, though representative, are more than one year old.

e) Casitas has implemented a corrosion control plan by adding a small amount of phosphate to the water to lower corrosivity and reduce copper levels.

f) Measurements taken with field kits (not certified laboratory results).

g) Mira Monte Well Treated is calculated as a weighted average using Lake Casitas Treated and Mira Monte Well sample results and average 2020 blended water production from each source.